

Summer maintenance based on July and August 2008

I looked at the data four different ways and took the average MW out on MO and PO during weekdays for 2008:

1. Straight average was 300 MW per day.
2. Removing one day outage of units bigger than 250 MW averaged 211 MW per day.
3. Removing all units on a one day outage averaged 186 MW per day.

There was one relatively large unit out for the month of July. If this is removed from numbers 2 and 3 above the averages drop to 128 MW and 103 MW respectfully.

Since none of the one day outages were on high load days I don't think they should be counted.

I would recommend staying with the 150 MW summer outage that we have been using.

Frank Vitale
6/26/09