

Request to Develop or Modify Reliability Rules (NYSRC Policy No. 1-4)

Submit request to raymond40@aol.com via the NYSRC site www.nysrc.org

Item	Response
1. Respondent	
Name	Robert Ganley
Organization	LIPA
Address	175 East Old Country Road, Hicksville N.Y. 11801
Phone & Fax numbers	516-545-4011
Email address	robert.ganley@service.lipower.org
2. Title of proposed rule change & PRR No.	Operating Reserves Reliability Rule Modification (PRR 100)
3. New rule or modification of NYSRC RR?	
If a new rule is proposed, provide any relevant citation to existing standards	N/A
If a modification to an existing rule is proposed, provide NYSRC RR reference	NYSRC D-R3; NPCC Document A -06
4. Wording of proposed rule change	<p>Rule D-R3:</p> <p>Change Heading from Availability and Category to Availability , Sustainability and Category</p> <p>Add Paragraph c. Synchronized Reserve, Ten Minute Reserve and Thirty Minute Reserve acquired by an Area , if activated , shall be sustainable for atleast one hour from the time of activation. Areas shall determine their sustainability requirement for regulating reserve based on their ability to achieve compliance with relevant standards, with due consideration of their operating characteristics.</p> <p>Renumber Previous Paragraph c as d.</p>
5. Rationale for proposed rule change	NYSRC Operating Reserve rule has been modified to assure consistency with recent NPCC criteria changes.
Identify advantages	See above rational for rule change
Identify disadvantages	None
6. Measurement(s)	
7. Full Compliance Statement	
8. Levels of Non-Compliance	
Level 1	
Level 2	
Level 3	
Level 4	
9. Responsible Entity	
10. Compliance Monitoring Entity	
11. Implementation Plan	
12. Comments	

13. Date Rule/Measurement Adopted	
14. PRR Revision Dates	2/5/09