

Request to Develop or Modify Reliability Rules (NYSRC Policy No. 1-4)

Submit request to raymond40@aol.com via the NYSRC site www.nysrc.org

Item	Response
1. Respondent	
Name	NYSRC Reliability Rules Subcommittee
Organization	
Address	
Phone & Fax numbers	
Email address	
2. Title of proposed rule change & PRR No.	
	Resource Availability Requirements (PRR #101)
3. New rule or modification of NYSRC RR?	
If a new rule is proposed, provide any relevant citation to existing standards	
If a modification to an existing rule is proposed, provide NYSRC RR reference	C-R2, C-M4 and C-M5
4. Wording of proposed rule change	
	<p>C-R2: Resource availability data required<u>needed to for the analysis and model the</u> of the reliability of the NYCA shall be collected and maintained <u>through the development of appropriate outage data reporting and review procedures.</u> Data shall include forced, partial, and maintenance outage and load response data statistics for resources located in/or serving the NYCA, covering an appropriate historical period.</p>
5. Rationale for proposed rule change	
Identify advantages	These Reliability Rule C-R2 and Measurement C-M4 & C-M5 changes will clarify and make more specific requirements for reporting resource outage data to the NYISO and review of the data after it has been received, for the purpose of ensuring the quality of data that is available for reliability studies.
Identify disadvantages	None.
6. Measurement(s)	
	<p>C-M4: The NYISO shall establish and maintain procedures and schedules for reporting of outage and load response data to the NYISO for those ICAP resources, as well as energy only resources, serving the NYCA. The NYISO shall establish and maintain procedures to address Installed Capacity Provider resource outage data reporting requirements and NYISO methods of processing resource outage data to ensure that consistent and accurate data is available to support NYSRC and NYISO reliability studies. This data shall include forced, partial, and maintenance outage statistics. The procedures shall include the following:</p> <ol style="list-style-type: none"> 1. Installed Capacity Provider outage data reporting instructions. 2. Installed Capacity Provider outage data reporting schedules. 3. Training programs or workshops for Installed Capacity Providers that focus on proper outage data collection and reporting methods for ensuring that accurate data is submitted to the NYISO.

	<p>4. The consequences to an Installed Capacity Provider of failing to submit complete, accurate, and timely data to the NYISO.</p> <p>5. Due diligence NYISO methods or processes for reviewing and screening of outage data received from Installed Capacity Providers, for ensuring that consistent and accurate data is available for NYSRC and NYISO reliability studies. On request by the NYSRC, the NYISO shall make available for inspection documentation covering its methods and processes for reviewing outage data.</p> <p>The NYISO shall notify the NYSRC within 30 days after it determines that misreported outage data has been used in NYSRC or NYISO reliability studies.</p> <p>C-M5: Owners of resources located in or serving the NYCA shall provide to the NYISO accurate resource outage and load response data on a timely basis for their units in accordance with NYISO procedures, tariffs and schedules. Installed Capacity Providers located in or serving the NYCA shall provide appropriate resource outage data for their resources in accordance with NYISO procedures, tariffs, and schedules for reporting outage data to the NYISO. The outage data that is submitted to the NYISO shall be complete and accurate prior to being used in NYSRC and NYISO reliability studies.</p>
7. Full Compliance Statement	(TBD by RCMS)
8. Levels of Non-Compliance	(TBD by RCMS)
Level 1	
Level 2	
Level 3	
Level 4	
9. Responsible Entity	NYISO
10. Compliance Monitoring Entity	RCMS
11. Implementation Plan	(TBD by RCMS)
12. Comments	
13. Date Rule/Measurement Adopted	
14. PRR Revision Dates	2/3/09