

**Request to Develop or Modify Reliability Rules (NYSRC Policy No. 1-4)**  
 Submit request to [raymond40@aol.com](mailto:raymond40@aol.com) via the NYSRC site [www.nysrc.org](http://www.nysrc.org)

| Item   | Response   |
|--|--|
| <b>1. Respondent</b>   |  |
| Name   | Robert Ganley  |
| Organization   | LIPA   |
| Address  | 175 East Old Country Road, Hicksville N.Y. 11801   |
| Phone & Fax numbers  | 516-545-4011   |
| Email address  | robert.ganley@service.lipower.org  |
|  |  |
| <b>2. Title of proposed rule change &amp; PRR No.</b>                          | Operating Reserves Reliability Rule Modification ( PRR 100 )   |
|  |  |
| <b>3. New rule or modification of NYSRC RR?</b>                                |  |
| If a new rule is proposed, provide any relevant citation to existing standards | N/A  |
| If a modification to an existing rule is proposed, provide NYSRC RR reference  | NYSRC D-R3; NPCC Document A -06  |
|  |  |
| <b>4. Wording of proposed rule change</b>                                      | <p>Rule D-R3:<br/> <b>Change Heading</b> from Availability and Category to Availability , Sustainability and Category<br/> <b>Add Paragraph c.</b> Synchronized Reserve, Ten Minute Reserve and Thirty Minute Reserve acquired by the NYISO , if activated , shall be sustainable for at least one hour from the time of activation.<br/> <b>Renumber Previous Paragraph c as d.</b></p> |
|  |  |
| <b>5. Rationale for proposed rule change</b>                                   | NYSRC Operating Reserve rule has been modified to assure consistency with recent NPCC criteria changes.  |
| Identify advantages  | See above rational for rule change   |
|  |  |
| Identify disadvantages   | None   |
|  |  |
| <b>6. Measurement(s)</b>   | No Changes   |
|  |  |
| <b>7. Full Compliance Statement</b>  | No Changes   |
|  |  |
| <b>8. Levels of Non-Compliance</b>   | No Changes   |
| Level 1  |  |
| Level 2  |  |
| Level 3  |  |
| Level 4  |  |
|  |  |
| <b>9. Responsible Entity</b>   | NYISO  |
|  |  |
| <b>10. Compliance Monitoring Entity</b>  | RCMS   |
|  |  |
| <b>11. Implementation Plan</b>   | The NYISO shall submit documentation to RCMS showing that NYISO procedures have been revised to reflect the Reliability Rule D-R3 modifications shown in PRR 100, within 60 days of adoption by the NYSRC Executive Committee.   |
|  |  |
| <b>12. Comments</b>  |  |
|  |  |

|  |                |
|--|----------------|
| <b>13. Date Rule/Measurement Adopted</b> |                |
|  |                |
| <b>14. PRR Revision Dates</b>            | 2/5/09, 2/6/09 |