

## Carol Lynch

---

**From:** Ganley, Robert J. [Robert.Ganley@service.lipower.org]  
**Sent:** Tuesday, May 12, 2009 11:23 AM  
**To:** Alan Adamson; Roger Clayton  
**Subject:** FW: NERC Proposed UFLS Continent Wide Standard Comment Form

**Attachments:** Project2007-01\_UFLS\_PRC-006-1\_2009April20.pdf



Project2007-01\_UF  
LS\_PRC-006-1\_...

Al,

Comments close on the attached standard on May 21. Through RRS I want to submit comments on the proposed UFLS standard because R10 can be interpreted that the Distribution provider has to constantly adjust the UFLS settings throughout the year. This is different then how we do it, which is once per year based on Normalized loads.

Proposed comment:

R10 The Distribution Provider once per calendar year shall review the forecasted loads it is serving and provide for UFLS in accordance with the UFLS program designed by the group of Planning Coordinators for each region in which it operates.

Thanks,  
Bob