

Request to Develop or Modify Reliability Rules (NYSRC Policy No. 1-4)

Submit request to raymond40@aol.com via the NYSRC site www.nysrc.org

Item	Response
1. Respondent	
Name	NYSRC Reliability Rules Subcommittee
Organization	
Address	
Phone & Fax numbers	
Email address	
2. Title of proposed rule change & PRR No.	
	Exceptions Review (PRR #105)
3. New rule or modification of NYSRC RR?	
If a new rule is proposed, provide any relevant citation to existing standards	
If a modification to an existing rule is proposed, provide NYSRC RR reference	E-M9, <u>E-M10</u>
4. Wording of proposed rule change	
5. Rationale for proposed rule change	
Identify advantages	Revises wording of measurement to be consistent with wording in Policy 1 so details of the exception review procedure may be removed from Policy 1. Also, clarifies certain aspects of the procedure and adds a new measurement, E-M10, which provides for Transmission Owner request for a review to remove its own exceptions.
Identify disadvantages	None.
6. Measurement(s)	
	<p>E-M9: The NYISO shall annually review <u>at least annually the list of</u> exceptions to the NYSRC Reliability Rules granted under NYSRC Policy 1, <i>Procedure for Reviewing, Developing, Modifying, and Disseminating NYSRC Reliability Rules</i>. This review shall verify that the basis for each exception is still valid <u>or whether the exception is still required due to changes in grid configuration or conditions, but not to question the original justification for the exception</u>. The NYISO shall notify the NYSRC when it has determined that an exception is no longer valid or required<u>applicable</u> and document the reasons <u>for its determination</u>why. <u>If the NYSRC concurs with the NYISO's determination, the exception will be removed and the NYISO and NYSRC will revise their list of exceptions accordingly</u>The NYISO shall revise the list of exceptions after the NYISO receives agreement from the NYSRC on the results of its review. (EC-R10)</p> <p>E-M10: <u>A Transmission Owner may request at any time, in</u></p>

	<u>writing, a review by the NYISO for removal of any of its current exceptions. Within 30 days, the NYISO shall notify the NYSRC of any adverse reliability impacts that would result from the removal of the exception. The NYSRC shall determine whether the exception should be removed, giving due consideration to any reliability impacts identified by the NYISO. The NYISO and NYSRC will then revise their list of exceptions accordingly.</u>
7. Full Compliance Statement	
8. Levels of Non-Compliance	
Level 1	
Level 2	
Level 3	
Level 4	
9. Responsible Entity	NYISO
10. Compliance Monitoring Entity	RCMS
11. Implementation Plan	
12. Comments	
13. Date Rule/Measurement Adopted	
14. PRR Revision Dates	10/1/09