

Request to Develop or Modify Reliability Rules (NYSRC Policy No. 1-4)

Submit request to raymond40@aol.com via the NYSRC site www.nysrc.org

Item	Response
1. Respondent	
Name	Roger Clayton (RRS) & Zach Smith (NYISO)
Organization	
Address	
Phone & Fax numbers	
Email address	
2. Title of proposed rule change & PRR No.	
	PRR 103. System Data Requirements
3. New rule or modification of NYSRC RR?	
If a new rule is proposed, provide any relevant citation to existing standards	
If a modification to an existing rule is proposed, provide NYSRC RR reference	C-R4, C-M9 and C-M11
4. Wording of proposed rule change	
	C-R4. Accurate load flow, short circuit and stability data bases required for planning and operating studies of the NYISO Bulk Power System shall be developed and maintained for use by the NYISO, and Market Participants and Developers . The data shall include appropriate detail from adjacent control areas.
5. Rationale for proposed rule change	
Identify advantages	The proposed changes to rule C-R4, and measurements C-M9 (NYISO requirements) and C-M11 (market participant requirements) will clarify and make more specific requirements for accurately reporting load flow, short circuit and stability data to the NYISO and review of the data after it has been received for the purpose of ensuring the quality of data that is available for reliability studies.
Identify disadvantages	None.
6. Measurement(s)	
	C-M9. The NYISO shall establish, and maintain and follow a procedures for the development and maintenance of load flow, short circuit and stability data bases. These procedures shall include: <ol style="list-style-type: none"> 1. Market pParticipant and Developer requirements to report to the NYISO and transmission owners verified changes to equipment parameters that affect these data bases. The procedure shall address appropriate time requirements for reporting such data base changes. 2. Due diligence NYISO processes for screening of all load flow, short circuit and stability data received from Transmission Owners and other Market Participants and Developers. These processes shall be designed to screen the data and replace identify potentially misreported or Suspect Data [ZS1]. with corrected or proxy data as necessary, and shall be employed by the NYISO before the data is used in NYISO or Market Participant reliability studies. The NYISO shall notify and request corrections for such data from the Transmission Owner or Market Participant or Developer. <p>C-M11.</p>

	<p>Transmission Owners and other designated Market Participants and Developers shall:</p> <ol style="list-style-type: none"> 1. Provide to the NYISO load flow, short circuit and stability data in the time frame and format as specified by NYISO procedures required under C-M9. This data will be used to maintain up-to-date data bases required under Measurement C-M10. (C-R4) 2. Perform due diligence analysis on Review and check load flow, short circuit and stability data bases provided to Transmission Owners or Market Participants or Developers by the NYISO for their own reliability studies, to ensure that the NYISO data bases properly represent their service territory or proposed transmission upgrade or generator interconnection. <u>The Market Participant or Developer shall notify the NYISO of any corrections to such data.</u>
7. Full Compliance Statement	
8. Levels of Non-Compliance	
Level 1	
Level 2	
Level 3	
Level 4	
9. Responsible Entity	Market Participant
10. Compliance Monitoring Entity	NYISO
11. Implementation Plan	
12. Comments	<p><u>A new term will be added to the NYSRC Glossary to define Developer, “An Eligible Customer (as defined by the NYISO Tariff) developing a generation project larger than 10 megawatts, or a merchant transmission project, proposing to connect to the New York State Transmission System, in compliance with the NYISO Minimum Interconnection Standard”.</u></p>
13. Date Rule/Measurement Adopted	
14. PRR Revision Dates	9/15/09, <u>10/2/09</u>