

Request to Develop or Modify Reliability Rules and Requirements (NYSRC Policy No. 1)

Submit request to herb@policyadvisorsllc.com via the NYSRC site www.nysrc.org

Item	Information
1. PRR No. & Title of Reliability Rule or	PRR-###-144 C.3: Outage Coordination - Requirement 4 and Requirement 6
2. Rule Change Requester	
Name	James Grant
Organization	NYISO
3. New rule or revision to existing rule?	Existing
4. Need for rule change, including advantages and disadvantages	The intent of existing R4 is for scheduled maintenance outage of facilities to be completed expeditiously in the event of an emergency. However, the NYISO cannot attest as to whether or not a facility owner has acted expeditiously in restoring an outage. The intent of existing R4 will be incorporated into the procedures stipulated in existing R6 of this Rule, so that facility owners are aware of their obligation to restore maintenance outages expeditiously in the case of an emergency. Existing R4 will be retired, and subsequent Requirements will be renumbered.
5. Related NYSRC rules	C.3 Requirements R2, R3, and R5.
6. Section A – Reliability Rule	
1. Reliability Rule	C.3: Outage Coordination
2. Associated NERC & NPCC	NERC: IRO-014, IRO-017 NPCC: Directory 1
3. Applicability	NYISO
7. Section B – Requirements	

Formatted Table

Requirements	<p>R4. Maintenance of facilities which impact the <i>reliability</i> of the <i>NYS Bulk Power System</i> shall be expedited.</p> <p>R5R4. Appropriate adjustments shall be made to NYCA operations to accommodate the impact of <i>protection group</i> outages.</p> <p>R5R4.1. For typical periods of forced or maintenance outage of a <i>protection group</i>, it can be assumed, unless there are indications to the contrary, that the remaining <i>protection</i> will function as designed.</p> <p>R5R4.2 If the <i>protection group</i> will be out of service for an extended period of time (as defined in NPCC criteria), additional adjustments to operations may be appropriate considering other system conditions and the consequences of possible failure of a remaining <i>protection group</i>.</p> <p>R6R5. The NYISO shall maintain procedures and systems which ensure that outages of transmission facilities are coordinated in such a manner to ensure <i>reliability</i>. <u>The procedures shall include a requirement that Transmission Owners expedite, to the extent practicable, maintenance of facilities which impact the reliability of the power system.</u> The NYISO must notify the NYSRC of any changes to these procedures and systems.</p> <p><u>R6. Each Transmission Owner shall establish and/or maintain procedures and systems which ensure that outages of transmission facilities are coordinated in such a manner to ensure <i>reliability</i>. The procedures shall include a requirement that Transmission Owners expedite, to the extent practicable, maintenance of facilities which impact the reliability of the power system. The Transmission Owner must notify the NYISO of any changes to these procedures.</u></p>
8. Section C – Compliance	
1. Measures	<p>M1. The NYISO maintained transmission outage coordination procedures and systems in accordance with R1 to R6R5. Any revisions to these procedures and systems were reported to the NYSRC.</p> <p><u>M2. The NYISO certified that each Transmission Owner maintained transmission outage coordination procedures and systems in accordance with R6. Any material revisions to these procedures and systems were reported to the NYISO.</u></p>

2. Levels of Non-	No change from existing
3. Compliance Monitoring	No change from existing
3.1 Compliance Monitoring	No change from existing
3.2 Reporting	No change from existing
3.3 Compliance Reporting	No change from existing
9. Implementation Plan	<p>The NYISO shall revise the Outage Scheduling Manual to explicitly include the intent in the new Requirement 6-5 that obligates facility owners to expedite maintenance outage restoration in the event of an emergency <u>within 90 days of Rule approval</u>.</p> <p><u>Each Transmission Owner shall develop and / or revise their outage scheduling procedures to include the intent in new Requirement 5 that obligates facility owners to expedite maintenance outage restoration in the event of an emergency within 90 days of Rule approval.</u></p>
10. Comments	
11. Date Rule Adopted	
12. PRR Revision Dates	January 24, 2019

DRAFT