

Case Number	Description	IRM	NYCA	Zone J	Zone K	Zone J	Zone K
		Δ	IRM	LCR	LCR	Δ	Δ
	<b>IRM 2018 Final Base Case</b>		18.2	80.7	103.2		
<b>1</b>	<b>Retirements</b>	<b>0.1</b>	<b>18.3</b>	79.4	104.2	-1.3	1.0
<b>2</b>	<b>Change Study Year</b>	<b>-0.2</b>	<b>18.1</b>	79.2	104.1	-0.2	-0.1
<b>3</b>	<b>MARS 3.22.6</b>	<b>-0.1</b>	<b>18.0</b>	79.1	104.0	-0.1	-0.1
<b>4</b>	<b>Use NYBA for LOLE criteria</b>	<b>-0.1</b>	<b>17.9</b>	79.0	103.9	-0.1	-0.1
<b>5</b>	<b>Wind Units and Shapes for 2013-2017</b>	<b>0.5</b>	<b>18.4</b>	79.0	103.9	0.0	0.0
<b>6</b>	<b>Gold Book 2019 Load Forecast &amp; Shapes</b>	<b>-0.6</b>	<b>17.8</b>	79.0	105.6	0.0	1.7
<b>7</b>	<b>Gold Book DMNCs</b>	<b>0.0</b>	<b>17.8</b>	79.2	104.4	0.2	-1.2
<b>8</b>	<b>Generator Transition Rates (EFORds) for 2013-2017</b>	<b>-0.5</b>	<b>17.3</b>	78.9	103.8	-0.3	-0.6
<b>9</b>	<b>NYCA Topology</b>	<b>0.1</b>	<b>17.4</b>	79.0	103.9	0.1	0.1
<b>10</b>	<b>New Thermals &amp; Rerates</b>	<b>-0.2</b>	<b>17.2</b>	79.6	103.1	0.6	-0.8
<b>11</b>	<b>Run of River Hydro Shapes for 2013-2017</b>	<b>-0.2</b>	<b>17.0</b>	79.5	102.9	-0.1	-0.2
<b>12</b>	<b>NYPA Sales 2019</b>	<b>0.0</b>	<b>17.0</b>	79.5	102.9	0.0	0.0
<b>13</b>	<b>Maintenance 2019</b>	<b>0.0</b>	<b>17.0</b>	79.5	102.9	0.0	0.0
<b>14</b>	<b>Con Ed Cable Transition Rates for 2013-2017</b>	<b>0.0</b>	<b>17.0</b>	79.5	102.9	0.0	0.0
<b>15</b>	<b>LIPA Cable Transition Rates for 2013-2017</b>	<b>-0.5</b>	<b>16.5</b>	79.1	102.4	-0.4	-0.5
<b>16</b>	<b>Update Non SCR/EDRP EOPs</b>	<b>-0.4</b>	<b>16.1</b>	78.8	102.0	-0.3	-0.4
<b>17</b>	<b>Update SCRs</b>	<b>0.2</b>	<b>16.3</b>	79.6	101.9	0.8	-0.1
<b>18*</b>	<b>Update External Control Area Data</b>		-	-	-		