

List of Sensitivities for the 2015-2016 IRM Study As Approved by the NYSRC EC on August 8, 2014

1. NYCA isolated
2. No internal NYCA transmission constraints
3. No load forecast uncertainty
4. No wind capacity
5. No SCRs and EDRP
6. Multi-load shape feature used with new peak logic feature turned off
7. Use the 2002 load shape without the multi-load shape feature
8. Set PJM LOLE capped at 0.15
9. Remove Danskammer from base case
10. Retire Indian Point Units 2 and 3
11. Model SCRs with a 6-hour obligation to perform