

## DRAFT Action Items List From Meeting #179 January 7, 2016

New York State Reliability Council - Installed Capacity Subcommittee

[Highlight denotes items that are behind schedule or due for the next meeting]

NO.	Action Item	Responsible Individual(s)	Sched./Actual Comp. Dates
161-5	The NYISO to provide justification to consider a different, less extreme, load shape than 2002. Consider alternative years for the multi-year load shapes - Currently using 2006, 2002, 2007 years for multi-year load shape feature. ICS will review various years' load shapes and make recommendations for any changes. The NYISO to align years across pools and collect missing data and make necessary corrections in Q1-Q2 2016. (Potential white paper)	NYISO/ Drake	TBD based on white paper prioritization
170-7	Consider alternative approaches when shifting capacity for sensitivities - Proposal will not change base case methodology. (Update milestone schedule to explicitly mention develop the sensitivity methodology). (Potential white paper)	Drake	TBD based on white paper prioritization
170-8	Investigate Energy Limited Resources and Capacity Limited Resources - Collect data on these resources by superzone/zone, operating limits ( <i>i.e.</i> , 4, 6, hour, <i>etc.</i> ) and provide reason for limitation without violating confidentiality. Depending on findings modeling assumptions may be adjusted.  The NYISO is currently collecting data and will provide NYCA wide numbers	NYISO/ Walters	
170-9	Develop IRM Study Guide document	Adams/ ICS	2/2016
173-1	ICS to ask GE to explore ways to model capacity limitation due to environmental regulations	ICS/ NYISO/ GE	2/2016
174-2	The NYISO to provide numerical example of the new load shape adjustment methodology	NYISO/ Drake	2/2016
177-1	ICS to discuss PJM wheel balance topology change	ICS/NYISO/ Lamanna	6/2016

178-1	The NYISO to evaluate multi-year wind shape functionality. (Potential White Paper)	NYISO	TBD based on white paper prioritization
178-2	Vijaya Ganugula to return to ICS to discuss an alternative method for determination of SCR values used in the IRM studies. (Potential White Paper)	NYISO/ Ganugula	3/2016
179-1	Modeling emergency assistance from external control areas. (As part of a potential white paper)	NYISO	
179-2	Review generator outage states for possible policy revision.	NYISO/ Walters	2/2016