


**2017 IRM Study
Summer Maintenance Assumption
2016 Summer Maintenance Analysis**

**John Adams
NYSRC Consultant
8/2/2017**




2016 Summer Maintenance Analysis

- Daily MW on maintenance for daily summer peak loads greater than 28,000 MW was developed from data provided by the NYISO.
- The data included 2016 hourly loads and unit planned and maintenance outage events including derates.
- There were 25 daily peak loads which were 28,000 MW or higher.
- The summer peak load was 32,282 MW or .97 per unit of the forecasted summer peak (PUFSP).
- 23 of the observations were at least .85 PUFSP or higher while 7 were at least .90 PUFSP or higher.
- The summer peak for 2015 was 31,138 MW or .93 PUFSP.

2016 Summer Maintenance Analysis Continued

- During the months of July, August and September there were 15 D4s (maintenance derates), 1 DMs (derate extension), 40 MOs (maintenance outages), 8 MEs (maintenance extensions), 10 POs (planned outage) and 7 PDs (planned derate) events were reported in the GADS data .
- For daily peak loads greater than 28,000 MW, the MWs on maintenance for the events included in the analysis totaled 3,626.9 MW.
- Plots of MW on maintenance VS daily peak loads was prepared for all daily peaks of 28,000 MW or more



Findings and Recommendations

- The plot of MW on maintenance is consistent with prior years observations.
- That is, the amount of capacity on maintenance is downward sloping VS. increasing daily peak loads.
- For daily peak loads of .90 PUFSP or higher maintenance outages drop off significantly.
- Recommend maintaining the summer maintenance at 50 MW with it with it distributed as in the 2016 IRM study in Zones J&K – 25 MW in each Zone.