

# NYSRC Area Selection to Remove Generation

Proposal to change methodology used  
in the calculation of minimum  
generation requirement for New York  
State

# Outline


- Background and current methodology
- Illustration of the challenge ( three examples)
- Market implications
- Conclusion

# Background and Current Methodology

- Remove generation from New York State
  - Reliability calculations perform using MARS
  - Loss of Load Expectation (LOLE) = 1 days/ 10 years = 0.1 days/year
- Where to remove generation (Zones A thru K) is in a Policy 5 procedure
  - Current policy is to remove generation from the excess generation areas until we reach the reliability criteria
    - The removed generation comes from areas that are generally most likely to have transmission constraints between their location and the load centers
  - Start with an LOLE of 0.05 days/year (system is more reliable than a system with an LOLE of 0.1 days/year)

# Background and Current Methodology

## Example #1: Bold Example



## Assumptions

- Total Load=7,000 MW
- Total Generation = 8,500 MW
- LOLE = 0.05 days/year
- No Transmission available

## Methodology


1. Remove 500 MW from Zone B
2. Remove 200 MW from Zone A

## Results

- LOLE = 0.1 days/year
- Min Reserve Margin =  $7800/7000 = 111.4\%$
- "Excess" Generation =  $8500/7800 = 8.97\%$

# Loss of 199 MW in Zone A

Example #2:



## Assumptions

- Total Load=7,000 MW
- Retired 199 MW of generation
- Total Generation = 8,301 MW
- **LOLE = 0.099 days/year**

## Methodology


1. Remove 500 MW from Zone B
2. Remove 1 MW from Zone A

## Results

- LOLE = 0.1 days/year
- Min Reserve Margin  
=7800/7000 = 111.4%
- Excess Generation = 8301/7800  
**=6.4%**

# Loss of 201 MW in Zone A

Example #3:



## Assumptions

- Total Load=7,000 MW
- Retired 201 MW of generation
- Total Generation = 8,299 MW
- **LOLE = 0.101 days/year**

## Methodology


1. Could Remove 500 MW from Zone B, no difference
2. Add 1 MW to Zone A. **Reliability criteria cannot be met need 1 MW in Zone A**

## Results

- LOLE = 0.100 days/year
- Min Reserve Margin  
=  $7800/7000 = 111.4\%$  or  
 $8300/7000 = 118.6\%$
- Excess Generation =  $8299/8300 =$   
 **$\sim 0\%$  or  $8299/7800 = 6.4\%?$**

# Proportional Removal of Capacity

Example #4:



## Assumptions

- Total Load=7,000 MW
- Total Generation = 8,500 MW
- LOLE = 0.05 days/year

## Methodology


1. Remove 12.5 MW from Zone B
2. Remove 200 MW from Zone A

## Results

- LOLE = 0.1 days/year
- Reserve Margin =  $8287.5/7000 = 118.4\%$
- Excess Generation =  $8500/8287.5 = 2.56\%$

# Proportional Removal of Capacity No Binding Transmission Limit

Example #5:



## Assumptions

- Total Load=7,000 MW
- Total Generation = 8,500 MW
- LOLE = 0.05 days/year

## Methodology

1. Remove 141 MW from Zone B
2. Remove 659 MW from Zone A

## Results


- LOLE = 0.1 days/year
- Reserve Margin =  $7800/7000 = 111.4\%$
- Excess Generation =  $8500/7800 = 8.97\%$



# Proportional Shifting Of Capacity

## Loss of 199 MW in Zone A

Example #6:



### Assumptions

- Total Load=7,000 MW
- Retired 199 MW of Generation
- Total Generation = 8,301 MW
- **LOLE = 0.099 days/year**

### Methodology

1. Remove 0.06 MW from Zone B
2. Remove 1 MW from Zone A


### Results

- LOLE = 0.1 days/year
- Reserve Margin =  $8299.94/7000 = 118.6\%$
- Excess Generation =  $8301/8299.94 = \mathbf{0\%}$

# Proportional Shifting Of Capacity

## Loss of 199 MW in Zone B

Example #7: With 199 MW retired and prop. methodology



### Assumptions

- Total Load=7,600 MW
- Total Generation = 8,500 MW
- Retired 199 MW of generation from Zone B
- LOLE = 0.05 days/year

### Methodology

1. Remove 7.5 MW from Zone B
2. Remove 200 MW from Zone A


### Results

- LOLE = 0.1 days/year
- Reserve Margin =  $8093.5/7000 = 115.6\%$
- Excess Generation =  $8301/8093.5 = 2.56\%$  remains the same as the case with 500 MW in Zone B

# Current Shifting Methodology

## Loss of 199 MW in Zone B

Example #8:



### Assumptions

- Total Load=7,000 MW
- Retired 199 MW of generation
- Total Generation = 8,301 MW
- LOLE = 0.05 days/year

### Methodology


1. Remove 301 MW from Zone B
2. Remove 200 MW from Zone A

### Results

- LOLE = 0.1 days/year
- Min Reserve Margin  
=7800/7000 = 111.4%
- Excess Generation = 8301/7800  
=6.4%

# Market Implications

Hypothetical Capacity Demand Curve for NY State (Summer)



# Conclusion

- Existing Policy 5 methodology calculates the “Minimum Requirement” implicitly incorporating the assumption that we can choose which capacity to eliminate
  - We do not have the ability to choose which generators retire
  - Because we cannot choose which units would retire, it does not send accurate signals about the tightness of the reliability conditions
- Current methodology provides least cost solution but compromising long term system reliability
- In certain cases the existing methodology can signal that there is substantial excess capacity when we are close to not meeting the minimum reliability requirements
- The proportional shifting methodology provides a more stable signal of the need for capacity across a wide range of varying generation assumptions
  - In all cases the proportional shifting methodology provided a more accurate representation of how much capacity could be lost before failing to meet the minimum reliability requirements.