

Request to Develop or Modify Reliability Rules (NYSRC Policy No. 1-4)

Submit request to raymond40@aol.com via the NYSRC site www.nysrc.org

Item	Response
1. Respondent	
Name	Installed Capacity Subcommittee
Organization	
Address	
Phone & Fax numbers	
Email address	
2. Title of proposed rule change & PRR No.	Special Case Resource Performance Data Reporting Requirements (PRR __)
3. New rule or modification of NYSRC RR?	
If a new rule is proposed, provide any relevant citation to existing standards	
If a modification to an existing rule is proposed, provide NYSRC RR reference	
4. Wording of proposed rule change	<u>Reliability Rule C-R2</u> Name: Generating Unit and Demand Side Resource Availability Accurate generating unit and demand side resource outage data needed to analyze and model the reliability of the NYCA shall be collected and maintained.
5. Rationale for proposed rule change	
Identify advantages	(To be added)
Identify disadvantages	
6. Measurement(s)	<u>Measurement C-M14 (New)</u> The NYISO shall establish, maintain and follow procedures to address Installed Capacity Provider reporting requirements for submitting performance data for all demand side resources utilized for providing installed capacity associated with Special Case Resources (SCRs), and requirements for processing SCR performance data. These procedures shall be designed to provide complete, consistent and accurate data to support NYSRC and NYISO reliability studies. NYISO outage data reporting and processing procedures shall include the following requirements: 1. Installed Capacity Provider SCR performance data reporting instructions. These instructions shall include requirements that Installed Capacity Providers submit data for any SCR test or event during which the SCR was called to perform. The data to be reported shall include both the data to enable the NYISO to calculate the performance relative to the NYISO ICAP valuation metric, using the NYISO's Average Coincident Load or its successor, and based upon the estimate of the customer's load in the absence of the call during the event, using the NYISO's Certified Base Load

	<p>methodology or its successor.</p> <ol style="list-style-type: none"> 2. Installed Capacity Provider SCR performance data reporting schedules. 3. NYISO procedures for processing SCR performance data received from Installed Capacity Providers. These procedures shall be designed to provide complete, consistent and accurate data. On request by the NYSRC, the NYISO shall make available for inspection documentation covering this process. 4. An annual report depicting SCR performance data, prepared in accordance with Requirement #3 and specified by the NYSRC. The report shall be submitted to the NYSRC in accordance with NYSRC time schedules. <p><u>Measurement C-M15 (New)</u></p> <p>Installed Capacity Providers located in or serving the NYCA shall provide performance data for their Special Case Resources (SCRs) in accordance with Measurement C-M14 and NYISO procedures, tariffs and schedules for reporting outage data to the NYISO.</p>
7. Full Compliance Statement	(To be added)
8. Levels of Non-Compliance	(To be added)
Level 1	
Level 2	
Level 3	
Level 4	
9. Compliance Documentation Reporting Entity	(To be added)
10. Compliance Monitoring Entity/Entites	(To be added)
11. Implementation Plan	(To be added)
12. Comments	
13. Date Rule/Measurement Adopted	
14. PRR Revision Dates	9/27/11