



NORTHEAST POWER COORDINATING COUNCIL, INC.
1040 AVE. OF THE AMERICAS, NEW YORK, NY 10018 (212) 840-1070 FAX (212) 302-2782

December 11th, 2013

NPCC Full Member Representatives and Alternates:

Subject: Open Process Posting of NPCC Directory#1 *Design and Operation of the Bulk Power System*

Attached for your review and comment is a draft version of Directory#1 *Design and Operation of the Bulk Power System* which has been reformatted to produce criteria requirements that are clear, measurable and consistent with the NERC ERO Rules of Procedure.

This draft was produced by a combined Working Group of the NPCC Task Force on Coordination of Planning (TFCP) and the Task Force on Coordination of Operation (TFCO) in response to a joint Task Force request to perform a collaborative review of the document.

The CO7/CP11 Working Group was instructed to review the draft as an integrated planning and operational document, examine all aspects of the criteria and return the draft of Directory#1 to the TFCP and the TFCO for their further assessment.

Highlights of the CO7/CP11 review include:

- A review of the criteria pertaining to Reliability Coordinator operations and their impact on other RC Areas.
- Consideration of the criteria surrounding operations under high risk conditions, reclosing operations, Special Protection Systems and load shedding.
- A review of the criteria pertaining to extreme contingencies, extreme system conditions and actions after a contingency including the use of available resources.
- The development of Planning and Operation criteria 'Tables' which now contain the relevant contingency events, fault types and performance requirements in order to present the criteria with added clarity.

- The inclusion of a 'boiler plate' Section as requested by the TFCO which addresses the applicability of the NPCC criteria.
- A comprehensive review of the Appendices including conforming changes to criteria references within the Appendices.

Subsequent to the CO7/CP11 review the draft was returned to the TFCO and TFCP and has received Task Force approval for its initial posting to the NPCC Open Process.

The NPCC Open Process Review may be accessed through the following link:

<https://www.npcc.org/Standards/SitePages/NonStandardsList.aspx>

Comments on Directory#1 *Design and Operation of the Bulk Power System* will be received for forty five days through January 25th, 2014 and all comments will be addressed by the TFCO and TFCP.

Please contact me with any questions regarding the NPCC Open Process review or the content of this document.

Thank you.

Gerry Dunbar
Northeast Power Coordinating Council, Inc.
212.840.1070 (p)
212.302.2782 (f)

gdunbar@npcc.org



NORTHEAST POWER COORDINATING COUNCIL, INC.
1040 AVE OF THE AMERICAS, NEW YORK, NY 10018 TELEPHONE (212) 840-1070 FAX (212) 302-2782

DRAFT 14: December 11th, 2013
Regional Reliability Reference Directory # 1
Design and Operation of the Bulk Power System

NPCC Open Process Review

Task Force on Coordination of Planning Revision Review Record:

Adopted by the Members of the Northeast Power Coordinating Council, Inc., on December 01, 2009 based on recommendation by the Reliability Coordinating Committee, in accordance with Section VIII of the NPCC Amended and Restated Bylaws dated July 24, 2007 as amended to date.

Revision History

Version	Date	Action	Change Tracking (New, Errata or Revisions)
0	December 1, 2009		New
1	4/20/2012	Errata Changes in Appendices B and E.	Errata

Table of Contents

1.0	Introduction	5
1.1	Title: Design and Operation of the Bulk Power System.....	5
1.2	Directory Number: 1	5
1.3	Objective:.....	5
1.4	Effective Date: December 1, 2009	5
1.5	Background	5
1.6	Applicability	6
1.6.1	Functional Entities	6
1.6.2	Applicability of NPCC Criteria:	6
2.0	Defined Terms:	6
3.0	NPCC Full Member, More Stringent Criteria:	7
4.0	Compliance:	11

Table 1 - Planning Design Criteria, Contingency events, Fault type, Performance requirements

Table 2 - Planning Criteria: Extreme Contingency and System Conditions, Fault type, Performance assessments

Table 3 - Operating Criteria, Contingency events, Fault type, Performance requirements

Appendix A - Reserved for Future Use.

Appendix B - Guidelines and Procedures for NPCC Area Transmission Review

Appendix C - Procedure for Testing and Analysis of Extreme Contingencies

Appendix D - Guidelines for Area Review of Resource Adequacy

Appendix E - Guidelines for Requesting Exclusions to Simultaneous Loss of Two Adjacent Transmission Circuits on a Multiple Circuit Tower

Appendix F - Procedure for Operational Planning Coordination

Appendix G - Procedures for Inter Reliability Coordinator Area Voltage Control

This document, when downloaded or printed, becomes UNCONTROLLED. Users should check the NPCC website for the current CONTROLLED version of this document.

1.0 Introduction

- 1.1 Title: Design and Operation of the Bulk Power System
- 1.2 Directory Number: 1
- 1.3 Objective:

The objective of this Directory is to provide a “design-based approach” to design and operate the **bulk power system** to a level of reliability that will not result in the loss or unintentional separation of a major portion of the system from any of the contingencies referenced in **R7** and **R14**.

In NPCC the technique for achieving this level of reliability is to require that the **bulk power system** be designed and operated to meet the performance requirements for the representative **contingencies** as specified in this Directory. Simulations shall be used to assess and analyze these **contingencies**.

Simulation of contingency events shall be applied on **bulk power system** elements and the resulting performance requirements shall be monitored on the **bulk power system**.

It is the responsibility of each Reliability Coordinator to ascertain that their portion of the **bulk power system** is operated in conformance with these criteria. It is the responsibility of each Transmission Planner and Planning Coordinator to ascertain that their portion of the **bulk power system** is designed in conformance with these criteria. Loss of small portions of a system (such as radial portions) may be tolerated provided these do not jeopardize the reliability of the remaining **bulk power system**.

The characteristics of a reliable **bulk power system** include adequate **resources** and transmission to reliably meet projected customer electricity demand and energy requirements as prescribed in this document.

- 1.4 Effective Date: December 1, 2009
- 1.5 Background

This Directory was developed from the NPCC A-2 criteria document - *Basic Criteria for the Design and Operation of Interconnected Power Systems* (May 6, 2004 version). Guidelines and Procedures for consideration in the implementation of this Directory are provided in the Appendices.

1.6 Applicability

1.6.1 Functional Entities

- Reliability Coordinators
- Transmission Operators
- Balancing Authorities
- Planning Coordinators
- Transmission Planners
- Resource Planners
- Generator Owners
- Transmission Owners

1.6.2 Applicability of NPCC Criteria:

The requirements of an NPCC Directory apply only to those NPCC transmission facilities defined as NPCC **bulk power system** elements and identified through the performance based methodology of NPCC Document A-10, “*Classification of Bulk Power System Elements*,” the list of which is maintained by the NPCC Task Force on System Studies and approved by the NPCC Reliability Coordinating Committee.”

Requirements to abide by an NPCC Directory may also reside in external tariff requirements, bilateral contracts and other agreements between facility owners and/or operators and their assigned Reliability Coordinator, Planning Coordinator, Transmission Operator, Balancing Authority and/or Transmission Owner as applicable and may be enforceable through those external tariff requirements, bilateral contracts and other agreements. NPCC will not enforce compliance to the NPCC Directory requirements in this document on any entity that is not an NPCC Member.

2.0 **Defined Terms:**

Unless specifically noted in this document terms in bold typeface are defined in the NPCC Glossary of Terms.

3.0 NPCC Full Member, More Stringent Criteria:

Information for Planning and Operational Assessments

- R1** Each Functional Entity that owns equipment shall annually verify the information it submits for **bulk power system** analysis representing the physical or control characteristics of the equipment.
- R2** Each Planning Coordinator and Reliability Coordinator shall collect, maintain and submit information needed for system modelling and reliability analysis of the **bulk power system**.
- R3** Each Reliability Coordinator shall share and coordinate forecast system information and real-time information to enable and enhance the analysis and modeling of the interconnected **bulk power system** by security application software on energy management systems.

Resource Adequacy

- R4** Each Planning Coordinator shall probabilistically evaluate resource adequacy of its Planning Coordinator **Area** portion of the **bulk power system** to demonstrate that the loss of **load** expectation (LOLE) of disconnecting **firm load** due to resource deficiencies shall be, on average, no more than 0.1 days per year.
 - R4.1** Make due allowances for demand uncertainty, scheduled outages and deratings, forced outages and deratings, assistance over interconnections with neighboring Planning Coordinator **Areas**, transmission transfer capabilities, and capacity and/or load relief from available operating procedures. In the calculation of available **resources**, supply- side purchases from neighbouring systems are limited to firm capacity backed purchases.
- R5** Each Planning Coordinator shall evaluate report and obtain Reliability Coordinating Committee (RCC) approval for its Review of **Resource Adequacy**. Appendix D provides guidance for the Area Review of **Resource Adequacy**.
 - R5.1** The Review of **Resource Adequacy** will be presented to the NPCC Task Force on Coordination of Planning (TFCP). Comprehensive and Interim reviews shall be presented to the TFCP before the beginning of the first time period covered by the assessment.
 - R5.2** A Comprehensive Review of **Resource Adequacy** is required every three years and will cover a time period of five years. If changes in planned facilities or forecasted system conditions warrant, TFCP may require a

Comprehensive Review of **Resource** Adequacy in less than 3 years.

R5.3 In subsequent years, each Planning Coordinator shall conduct an Annual Interim Review of **Resource** Adequacy that will cover, at a minimum, the remaining years studied in the Comprehensive Review of **Resource** Adequacy.

R6 Each Reliability Coordinator shall coordinate outages and deratings of **resources** to verify adequate **resources** will be available to meet the forecasted demand and **reserve** requirements. Appendix F provides guidance for Operational Planning Coordination.

R6.1 Perform a summer and winter reliability assessment every year.

Transmission Planning

R7 Each Transmission Planner and Planning Coordinator shall plan the system to meet the system conditions, contingencies and performance requirements contained within Table 1 in the design of its NPCC **bulk power system**.

R8 Each Transmission Planner and Planning Coordinator shall model credible combinations of system conditions which stress the system including, load forecast, inter-Area and intra-Area transfers, transmission configuration, active and reactive resources, generation availability and other dispatch scenarios.

R9 Each Transmission Planner and Planning Coordinator shall assess the impact of the extreme **contingencies** listed in Table 2. Appendix C provides guidance for testing and analyzing extreme contingencies.

R10 Each Transmission Planner and Planning Coordinator shall assess the impact of extreme system conditions, one condition at a time, subject to contingencies as listed in the “Extreme System Conditions” category of Table 2.

R11 Each Transmission Planner and Planning Coordinator shall have procedures and implement a system design that ensures equipment capabilities are adequate for fault current levels with all transmission and generation facilities in service for all operating conditions which are not prohibited by a procedure and coordinate these procedures with adjacent Planning Coordinator Areas.

R12 Each Planning Coordinator shall conduct and obtain Reliability Coordinating Committee (RCC) approval for its Transmission Review. Appendix B provides guidance for Transmission Reviews.

R12.1 A Comprehensive Transmission Review is required at least once every five years or if major or pervasive system changes have occurred. If changes in

the planned facilities or forecasted system conditions warrant, the Task Force on System Studies (TFSS) may require a Comprehensive Transmission Review in less than five years.

R12.2 The proposal for the type of annual Transmission Review shall be presented to TFSS by March of the year during which the review is conducted. Approval for the type of Transmission Review shall be obtained from the TFSS. The annual Transmission Review shall be presented to the TFSS by April of the following year.

R12.3 If the results of the Transmission Review indicate that the planned NPCC **bulk power system** will not be in conformance with NPCC Directory #1, the Transmission Review shall incorporate a corrective action plan to achieve conformance.

Special Protection Systems

R13 Each Functional Entity that proposes a new or modified SPS shall consider the complexity of the scheme and the consequences of correct or incorrect operation as well as its benefits.

R13.1 Provide a rationale and justification to the TFCP including factors such as project delays, temporary construction configurations, unusual combinations of system conditions, equipment outages and infrequent contingencies.

R13.2 Obtain approvals in accordance with Directory#7.

Transmission Operation

R14 Each Reliability Coordinator and Transmission Operator shall establish **normal transfer capabilities** and **emergency transfer capabilities**, and operate its portion of the **bulk power system** to meet the respective performance requirements and system conditions for the **contingencies** as specified in Table 3.

R15 Each Reliability Coordinator shall operate to **normal transfer capabilities** unless an **emergency**, in accordance with NPCC Directory# 2, is identified.

R16 Each Reliability Coordinator shall make system adjustments once an **emergency** has been identified, including the pre-**contingency** disconnection of **firm load**, to avoid exceeding emergency **transfer capabilities**.

R17 Each Reliability Coordinator and Transmission Operator shall assess the status of the **bulk power system** immediately after the occurrence of any **contingency** and prepare for the next **contingency**.

- R17.1** Voltage reduction and shedding of firm load shall be required to return the system to a secure state, if other system adjustments are not adequate. Voltage reduction need not be initiated and firm load need not be shed to observe a post contingency loading requirement until the **contingency** occurs, provided that adequate response time for this action is available.
- R17.2** System adjustments shall be completed as quickly as possible, but in all cases within 30 minutes after the occurrence of any **contingency** specified in Table 3.
- R18** Each Reliability Coordinator shall notify the applicable Reliability Coordinators of forced outages of any facility as per the NPCC Transmission Facilities Notification List and of any other condition which may impact inter-Area reliability.
- R19** Each Reliability Coordinator shall coordinate scheduled outages of facilities that are on the NPCC Transmission Facilities Notification List sufficiently in advance of the outage to permit the affected Reliability Coordinators to maintain reliability. Appendix F provides guidance for Operational Planning Coordination.
- R19.1** Review and update its Facilities Notification List and submit the list to the NPCC Task Force on Coordination of Operation (TFCO) annually.
- R20** Each Reliability Coordinator shall coordinate voltage control between Transmission Operator Areas. Appendix G provides guidance for Inter- Reliability Coordinator Area Voltage Control.
- R20.1** Metering for **reactive power** resources and voltage controller status shall be consistent between adjacent Transmission Operators.
- R20.2** Upon request from the TFCO, perform an Inter-Area Voltage Control Assessment.

4.0 Compliance:

Compliance with the requirements set forth in this Directory will be in accordance with the NPCC Criteria Compliance and Enforcement Program (CCEP).

Prepared by: Task Force on Coordination of Planning

Review and Approval: Revision to any portion of this Directory will be posted by the lead Task Force in the NPCC Open Process for a 45 day review and comment period. Upon addressing all the comments in this forum, the Directory document will be sent to the remaining Task Forces for their recommendation to seek RCC approval.

Upon approval of the RCC, this Directory will be sent to the Full Member Representatives for their final approval if sections pertaining to the Requirements and Criteria portion have been revised. All voting and approvals will be conducted according to the most current "NPCC. Bylaws" in effect at the time the ballots are cast.

Revisions pertaining to the Appendices or other portions of the document such as links, etc., only require RCC approval.
Errata may be corrected by the Lead Task Force at any time.

This Directory will be updated at least once every three years and as often as necessary to keep it current and consistent with NERC, Regional Reliability Standards and other NPCC documents.

References:

- NPCC Glossary of Terms*
- Emergency Operations* (NPCC Directory #2)
- Maintenance Criteria for Bulk Power System Protection* (NPCC Directory #3)
- Bulk Power System Protection Criteria* (NPCC Directory #4)
- Reserve* (NPCC Directory #5)
- Special Protection Systems* (NPCC Directory #7))
- Classification of Bulk Power System Elements* (A-10)

Table 1

Planning Design Criteria: Contingency events, Fault type and Performance requirements to be applied to bulk power system elements

Compliance with Directory#1 shall be demonstrated for all requirements listed in the table below that are not required for compliance with the NERC Reliability Standards.

Category	Contingency events Simulate the removal of all elements that protection systems, including Special Protection Systems, are expected to automatically disconnect for each event that involves an AC fault.	Fault type (permanent) On the listed elements where applicable	Performance requirements
I Single Event	1. Loss of any of the following: a. transmission circuit b. transformer c. shunt device d. generator e. bus section	Three-phase fault with normal fault clearing	i. to ix.
	2. Opening of any circuit breaker	No fault	
	3. Loss of single pole of a direct current facility	No fault	
	4. Loss of any of the following: a. transmission circuit b. transformer c. shunt device d. generator e. bus section	Phase to ground fault with delayed fault clearing	
	5. Loss of a circuit breaker	Phase to ground internal fault , with normal fault clearing	
	6. Simultaneous loss of two adjacent transmission circuits on a multiple circuit tower.	Phase to ground faults on different phases of each circuit, with normal fault clearing	
	7. Simultaneous permanent loss of both poles of a direct current bipolar facility	Without an ac fault	
	8. The failure of a circuit breaker to operate when initiated by a SPS after the loss of the following: a. transmission circuit b. transformer c. shunt device d. generator e. bus section f. opening of any circuit breaker (without a fault)	Phase to ground fault , with normal fault clearing	

NPCC Directory #1
Table 1

Category	Contingency events Simulate the removal of all elements that protection systems, including Special Protection Systems, are expected to automatically disconnect for each event that involves an AC fault.	Fault type (permanent) On the listed elements where applicable	Performance requirements
II Event(s) after a first loss and after System Adjustment	1. Following the loss of any critical : a. transmission circuit, b. transformer, c. series or shunt compensating device or d. generator e. Single pole of a direct current facility and after System Adjustment, Categories I Contingencies shall also apply.	Any Category I event as described above.	Performance requirements i to ix apply Area generation and power flows are adjusted between outages by the use of resources available within ten minutes following notification and other system adjustments such as HVDC and phase angle regulator adjustments that can be made within 30 minutes.

Performance Requirements:

- i. Loss of a major portion of the system or unintentional separation of a major portion of the system shall not occur.
- ii. Loss of small or radial portions of the system pre-determined by studies is acceptable provided the performance requirements are not violated for the remaining **bulk power system**.
- iii. Voltages and loadings shall be within limits for the applicable pre-**contingency** conditions.
- iv. Voltages and loadings shall be within **applicable emergency limits** for post-**contingency** conditions.
- v. Adequate reactive power resources and appropriate controls shall be available to maintain voltages within applicable limits.
- vi. The **stability** of the **bulk power system** shall be maintained during and following the most severe **contingencies**, with due regard to successful and unsuccessful automatic **reclosing**.
- vii. For each of the **contingencies** that involve a **normal fault clearing**, **stability** shall be maintained when the simulation is based on **fault clearing** initiated by the “**system A**” **protection group**, and also shall be maintained when the simulation is based on **fault clearing** initiated by the “**system B**” **protection group**. When applying this requirement to **contingency** Event *no 6*, the failure of a **protection group** shall apply only to one circuit at a time.
- viii. Regarding **contingency no 6**, if multiple circuit towers are used only for station entrance and exit purposes, and if they do not exceed five towers at each station, then this condition is an acceptable risk and therefore can be excluded. Other similar situations can be excluded on the basis of acceptable risk, provided that the Reliability Coordinating Committee specifically accepts each request for exclusion. (See Appendix E.)
- ix. Transient voltage response shall be within acceptable limits established by the Planning Coordinator and the Transmission Planner.

Table 2

Planning Criteria: Extreme Contingency and System Conditions, Fault type and Performance Assessments to be applied to bulk power system elements

Compliance with Directory#1 shall be demonstrated for all requirements listed in the table below that are not required for compliance with the NERC Reliability Standards.

Category	Contingency events Simulate the removal of all elements that protection systems, including Special Protection Systems, are expected to automatically disconnect for each event that involves an AC fault.	Fault type (permanent) and/or condition applied On the listed elements where applicable	Performance to be assessed
Extreme Contingency	1. Loss of the entire capability of a generating station.	No Fault	i, ii, iii.
	2. Loss of all transmission circuits emanating from a generating station, switching station, substation or dc terminal.	No Fault	
	3. Loss of all transmission circuits on a common right-of-way.	No Fault	
	4. Loss of any of the following: a. transmission circuit b. transformer c. shunt device d. generator e. bus section	Three-phase fault with delayed fault clearing (with due regard to successful and unsuccessful automatic reclosing .)	
	5. Loss of a circuit breaker	Three-phase internal fault , with normal fault clearing	
	6. Sudden loss of a large load or major load center.	No Fault	
	7. The effect of severe power swings arising from disturbances outside the Council's interconnected systems.	Fault applied as necessary.	
	8. Failure of a Special Protection System , to operate when required following the normal contingencies listed in Table 1, Category I, Single Event.	As listed in Table 1, Category I, Single Event.	
	9. The operation or partial operation of a Special Protection System for an event or condition for which it was not intended to operate.	No Fault	
	10. Sudden loss of fuel delivery system to multiple plants, (e.g. gas pipeline contingencies).	No Fault.	
Any additional extreme contingencies identified by each Planning Coordinator Area.	Fault applied as necessary.	i, ii, iii.	
Extreme System Conditions	Contingency events listed in Table 1, Category I, Single Event		Peak load conditions resulting from extreme weather. Generating unit(s) fuel shortage (e.g. gas supply adequacy or low hydro) under normal weather peak conditions

Performance Assessment

- i. Model the following pre-contingency conditions:
 - a. transfers within or between Transmission Planner and Planning Coordinator Areas should be studied at values not expected to be exceeded more than 25% of the time.
 - b. highly probable dispatch patterns of generation for the transfers being studied
 - c. appropriate load representation (e.g. active and reactive power as a function of voltage) for transient tests and post transient load flows.
- ii. Examine post contingency steady state conditions, as well as stability, overload, cascading outages and voltage collapse to obtain an indication of system robustness and determine the extent of any widespread system disturbance
- iii. Where assessment concludes there are serious consequences, an evaluation of implementing a change to design or operating practices to address such contingencies shall be conducted.

Table 3

Operating Criteria: Contingency events, Fault type and Performance requirements to be applied to bulk power system elements to establish transfer capabilities.

Compliance with Directory#1 shall be demonstrated for all requirements listed in the table below that are not required for compliance with the NERC Reliability Standards.

Category	Contingency events Simulate the removal of all elements that protection systems, including Special Protection Systems, are expected to automatically disconnect for each event that involves an AC fault.	Fault type (permanent) On the listed elements where applicable	Performance requirements	
			<u>Normal Transfer Capability</u>	<u>Emergency Transfer Capability</u> (only after an Emergency is identified)
I Single Event	1. Loss of any of the following: a. transmission circuit b. transformer c. shunt device d. generator e. bus section	Three-phases fault , with normal fault clearing	i. to xi.	i, ii, iii, iv, v, vi, vii ix, x, xii,
	2. Opening of any circuit breaker	No fault		
	3. Loss of single pole of a direct current facility	No fault		
	4. Loss of any of the following: a. transmission circuit b. transformer c. shunt device d. generator e. bus section	Phase to ground fault, with delayed fault clearing		
	5. Loss of a circuit breaker	Phase to ground internal fault , with normal fault clearing		
	6. Simultaneous loss of two adjacent transmission circuits on a multiple circuit tower.	Phase to ground faults on different phases of each circuit, with normal fault clearing		
	7. Simultaneous permanent loss of both poles of a direct current bipolar facility	Without an ac fault		
	8. The failure of a circuit breaker to operate when initiated by a SPS after the loss of the following: a. transmission circuit b. transformer c. shunt device d. generator e. bus section f. opening of any circuit breaker (without a fault)	Phase to ground fault , with normal fault clearing		

Performance Requirements

- i. Loss of a major portion of the system or unintentional separation of a major portion of the system shall not occur.
- ii. Loss of small or radial portions of the system pre-determined by studies is acceptable provided it does not violate the performance requirements for the remaining BPS.
- iii. Voltages and loadings shall be within limits for the applicable pre-**contingency** conditions.
- iv. Voltages and loadings shall be within **applicable emergency limits** for post-**contingency** conditions.
- v. Adequate reactive power resources and appropriate controls shall be available to maintain voltages within applicable limits.
- vi. The **stability** of the **bulk power system** shall be maintained during and following the most severe **contingencies**, with due regard to successful and unsuccessful automatic **reclosing**.
- vii. For each of the **contingencies** that involve a **normal fault clearing**, **stability** shall be maintained when the simulation is based on **fault clearing** initiated by the “**system A**” **protection group**, and also shall be maintained when the simulation is based on **fault clearing** initiated by the “**system B**” **protection group**. When applying this requirement to **contingency** Event *no 6*, the failure of a **protection group** shall apply only to one circuit at a time.
- viii. Regarding **contingency no 6**, if multiple circuit towers are used only for station entrance and exit purposes, and if they do not exceed five towers at each station, then this condition is an acceptable risk and therefore can be excluded. Other similar situations can be excluded on the basis of acceptable risk, provided that the Reliability Coordinating Committee specifically accepts each request for exclusion. (See Appendix E.)
- ix. Individual Reliability Coordinator Areas shall be operated in a manner such that **Contingencies** and conditions applied can be withstood without causing **significant adverse impact** on other Reliability Coordinator Areas.
- x. Appropriate adjustments shall be made to Reliability Coordinator Area operation to accommodate the impact of **protection group outages**, including the **outage** of a **protection group** which is a part of a **Type I special protection system**. For typical periods of forced outage or maintenance of a **protection group**, it can be assumed, unless there are indications to the contrary, that the remaining **protection** will function as designed. If the **protection group** will be out of service for an extended period of time, additional adjustments to operations may be appropriate considering other system conditions and the consequences of possible failure of the remaining **protection group**.
- xi. Normal transfer levels shall not require system adjustments before manually reclosing faulted elements unless specific instructions describing alternate actions are in effect to maintain stability of the BPS.
- xii. Emergency transfer levels may require system adjustments before manually reclosing faulted elements to maintain stability of the bulk power system.

Operating to the contingencies listed above in Table 3 is considered to provide an acceptable level of bulk power system security. However, under high risk conditions, such as severe weather, the expectation of the occurrence of contingencies not listed in Table 3 and/or the associated consequences may be judged to be significantly greater. When these conditions exist, consideration should be given to operating in a more conservative manner.

Appendix B - Guidelines and Procedures for NPCC Transmission Reviews

1.0 Introduction

NPCC has established a Reliability Assessment Program to bring together work done by NPCC, Transmission Planners and Planning Coordinators relevant to the assessment of **BPS reliability**. As part of the Reliability Assessment Program, the Task Force on System Studies (TFSS) is charged on an ongoing basis with conducting periodic reviews of the **reliability** of the planned bulk power transmission system of each Planning Coordinator Area of NPCC and the transmission interconnections to other Planning Coordinator Areas. The purpose of these reviews is to determine whether each Planning Coordinator Area's planned bulk power transmission system is in conformance with the NPCC Directory #1 *Design and Operation of the Bulk Power System*. The annual Area Transmission Review required in R12 is presented for this purpose. It is expected that this Review will cover Directory #1 requirements as they apply to the **bulk power system**.

2.0 Purpose of Review Presentation

The purpose of the presentation associated with an Area Transmission Review is to demonstrate that the Planning Coordinator's planned **bulk power system** based on its projection of available **demand**, transmission, and **resources**, is in conformance with the Directory #1 criteria. By such a presentation, the Task Force will satisfy itself that the criteria have been met and, in general, that the **reliability** of the NPCC Interconnected Systems will be maintained.

3.0 Study Year To Be Considered

It is suggested that a study year of 4 to 6 years from the reporting date is a realistic one, both from the viewpoint of minimum lead times required for construction, and the ability to alter plans or facilities. The reviews may be conducted for a longer term beyond 6 years to address identified marginal conditions that may have longer lead-time solutions.

4.0 Types and Frequency of Reviews

As described in requirement **R12**, each Planning Coordinator is required to present an annual transmission review to TFSS. However, the review presented by the Planning Coordinator may be one of three types: a Comprehensive (or Full) Review, an Intermediate (or Partial) Review, or an Interim Review.

A Comprehensive Review is a thorough assessment of the Planning Coordinator's entire bulk power transmission system, and includes sufficient analyses to fully address all aspects of an Area Transmission Review as described in **R12**.

In the years between Comprehensive Reviews, Planning Coordinators may conduct either an Interim Review, or an Intermediate Review, depending on the extent of the Planning

Coordinator's system changes since its last Comprehensive Review. If the system changes are relatively minor, the Planning Coordinator may conduct an Interim Review. In an Interim Review, the Planning Coordinator provides a summary of the changes in planned facilities and forecasted system conditions since its last Comprehensive Review and a brief discussion and assessment of the impact of those changes on the bulk power transmission system. No new analyses are required for an Interim Review.

If the Planning Coordinator's system changes since its last Comprehensive Review are moderate or concentrated in a portion of the Planning Coordinator's system, the Planning Coordinator may conduct an Intermediate Review. An Intermediate Review covers all the elements of a Comprehensive Review, but the analyses may be limited to addressing only those issues considered to be of significance, considering the extent of the system changes.

In March of each year, after a Planning coordinator presents a proposal for the type of review to be conducted during the current year, TFSS will consider each Planning Coordinator's proposal. TFSS will either indicate their concurrence, or require the Planning Coordinator to conduct a more extensive review if the Task Force feels that such is warranted based on the Planning Coordinator's system changes since its last Comprehensive Review.

5.0 Format of Presentation – Comprehensive and Intermediate Review

a) Introduction

- Reference the most recent Area Comprehensive Review and any subsequent Intermediate or Interim reviews as appropriate.
- Describe the type and scope of this review.
- For a Comprehensive Review, describe the existing and planned **bulk power system** facilities included in this review.
- Describe changes in system facilities, **bulk power system elements** and **loads** since the most recent Comprehensive Review.
- Include maps and one-line diagrams of the system showing proposed changes as necessary.
- Describe the demand levels to be studied, according to the range of forecast system demands.
- Identify projected firm transfers and interchange schedules.

b) Present the scope of the analyses. The analyses conducted for a Comprehensive Review should be thorough, but an Intermediate Review may focus on specific areas of the system, specific system conditions, or a more limited set of “critical” **contingencies**.

c) Steady State Assessment

- Present the **load** model, power factor, demand side management, and other modeling assumptions used in the analysis. Discuss the methodology used in voltage assessments. (An Intermediate Review may refer to the discussion from the last Comprehensive Review.)
- Provide supporting information on the **contingencies** selected for evaluation and an explanation of why **contingencies** not simulated would produce less severe results.
- Provide information on the generation dispatch conditions assumed in the analysis.
- Include plots of "base case" **load** flows with all lines in service for the various conditions studied, e.g., peak, off-peak, and heavy transfers.
- Present the effects of major planned changes on the system.
- Identify applicable transfer limits within and between Planning Coordinator Areas.
- Show the adequacy of voltage performance and voltage control capability for the planned bulk power transmission system.

d) Stability Assessment

Present and/or refer to significant studies showing the effect of **contingencies** on the system and report on the most severe **contingencies** in the following manner:

- Provide supporting information on the **contingencies** selected for evaluation and an explanation of why **contingencies** not simulated would produce less severe results.
- The nature of the **fault** applied, **elements** switched, and **fault clearing** times.
- Plots of angles versus time for significant machines, HVdc and SVC response, voltages at significant buses and significant interface flows.

For a Comprehensive or Intermediate Review, present the **load** model and other modeling assumptions used in the analysis. (An Intermediate Review may refer to the discussion from the last Comprehensive Review.)

e) **Fault** Current Assessment

- Present the methodology and assumptions used in the **fault** current assessment. (An Intermediate Review may refer to the discussion from the last Comprehensive Review.)
- Present instances where **fault** levels exceed equipment capabilities and measures to mitigate such occurrences.
- Present changes to **fault** levels at stations adjacent to other Planning Coordinator Areas.

f) Extreme **Contingency** Assessment

- Present the scope of the analyses including a description of the system conditions assessed. The analyses conducted for a Comprehensive Review should be thorough, but an Intermediate Review may focus on specific areas of the system, specific system conditions, or a more limited set of “critical” **contingencies**.
- Provide supporting information on the extreme **contingencies** selected for evaluation and an explanation of why the remaining **contingencies** not simulated would produce less severe results.
- Review the results for widespread cascading due to overloads, instability or voltage collapse caused by extreme **contingencies**
- In the case where **contingency** assessment reveals serious consequences, conduct an evaluation of implementing a change to address such **contingencies**.

g) Extreme System Condition Assessment

- Present the scope of the analyses including a description of the system conditions assessed. The analyses conducted for a Comprehensive Review should be thorough, but an Intermediate Review may focus on specific areas of the system, specific system conditions, or a more limited set of “critical” **contingencies**.

- Provide the rationale for the loss of fuel supply conditions selected for evaluation and an explanation of why other loss of fuel supply conditions not simulated would produce less severe results.
- Provide supporting information on the **contingencies** selected for evaluation and an explanation of why the remaining **contingencies** not simulated would produce less severe results.
- In the case where extreme condition assessment reveals serious consequences, conduct an evaluation of implementing measures to mitigate such consequences.

h) Review of **Special Protection Systems (SPSs)**

- Present the scope of review. A Comprehensive Review should review all the existing, new, and modified **SPSs** included in its transmission plan. An Intermediate Review may focus on the new and modified **SPSs**, and just those existing **SPSs** that may have been impacted by system changes since they were last reviewed.
- Present the need and utilization for Type I and Type II **SPSs**. For instances where a **SPS** utilization is anticipated to increase, the TFSS should inform the Task Force on Coordination of Planning (TFCP) of this finding.
- Review the validity of the classification of Type III **SPSs**. For instances where a **SPS** which was formerly considered to have only local consequences is identified as having the potential for inter- Planning Coordinator Area effects, for the time period being reviewed, the TFSS should notify the Task Force on Coordination of Planning, System Protection and Coordination of Operation. In such instances a complete review of the **SPS** should be made, as per the *Procedure for NPCC Review of New or Modified Bulk Power System Special Protection Systems (SPS)* in Directory #7.

i) Review of Dynamic Control Systems (DCSs)

Review of potential consequences of failure or misoperation of Dynamic Control Systems (DCS), as defined in NPCC Document C-33 *Procedure for Analysis and Classification of Dynamic Control Systems*. For Type I and Type II DCSs, present and/or refer to appropriate **stability** studies analyzing the consequences of failure or misoperation in accordance with the Joint Working Group (JWG)-1 report, "Technical Considerations and Suggested Methodology for the Performance

Evaluation of Dynamic Control Systems". A Comprehensive Review should address all potentially impactful existing and new DCSs, but an Intermediate Review may focus on new DCSs and only those existing DCSs that may have been impacted by system changes since they were last reviewed.

j) Review of Exclusions to the Directory#1 *Criteria*

Review any exclusions granted under NPCC *Guidelines for Requesting Exclusions to Simultaneous Loss of Two Adjacent Transmission Circuits on a Multiple Circuit Tower* (Appendix E). A Comprehensive Review should address all exclusions, but an Intermediate Review may focus on just those exclusions that may have been impacted by system changes since they were last reviewed.

k) Overview Summary of System Performance for Year Studied

6.0 Format of Presentation - Interim Review

- a) Introduction of Interim Review
- b) Reference the most recent Comprehensive Review and any subsequent Intermediate or Interim Reviews as appropriate.
- c) Changes in Facilities (Existing and Planned) and Forecasted System Conditions Since the Last Comprehensive Review.
 - **Load Forecast**
 - **Generation Resources**
 - **Bulk Power System elements**
 - **Transmission Facilities**
 - **Special Protection Systems**
 - **Dynamic Control Systems**
 - **Exclusions**
- d) Brief Impact Assessment and Overview Summary

The Planning Coordinator will provide a brief assessment of the impact of these changes on the **reliability** of the interconnected **bulk power system**, based on engineering judgment and internal and joint system studies as appropriate.

7.0 Documentation

The documentation required for a Comprehensive or Intermediate Review should be in the form of a report addressing each of the items of the above presentation format. The report should be accompanied by the Planning Coordinator's **bulk power system** map and one-line diagram, summary tables, figures, and appendices, as appropriate. The report may include references to other studies performed by the Planning Coordinator or by utilities within the Planning Coordinator Area that are relevant to the Area Transmission Review, with appropriate excerpts from those studies.

The documentation required for an Interim Review should be in the form of a short summary report (normally not exceeding 5 pages), containing a description of system changes and a brief assessment on their impact on the **reliability** of the interconnected **bulk power system**

8.0 Task Force Follow-Up Procedures

- 8.1 Once a Planning Coordinator has presented its Transmission Review report to the TFSS, TFSS will review the Planning Coordinator's report and any supporting documentation and consider whether to accept the report as complete and in full conformance with these Guidelines :
- a. If the report is found to be unacceptable, TFSS will indicate to the Planning Coordinator the specific areas of deficiency, and request the Planning Coordinator to address those deficiencies.
 - b. If there is no concurrence about the results and conclusion(s) of the Planning Coordinator's Review, TFSS will indicate to the Planning Coordinator the specific areas of disagreement, and work with the Planning Coordinator to try to achieve concurrence. If agreement has not been reached within a reasonable period of time, TFSS will prepare a summary of the results of its review, and present the summary to the TFCP.
 - c. If the report is considered as complete and in full conformance with these Guidelines, TFSS will accept the report.
- 8.2 If the Area Transmission Review indicates an overall **bulk power system** reliability concern (not specific to the Planning Coordinator's planned bulk power transmission system), TFSS will consider what additional studies may be necessary to address the concern, and prepare a summary discussion and recommendation to the Task Force on Coordination of Planning

8.3 Upon completion of an Area Review, TFSS will report the results of the review to the Task Force on Coordination of Planning. The TFCP will then review and vote on the completeness and acceptability of the Area Transmission Review and report its finding to the Reliability Coordinating Committee for a final review and approval.

Appendix C - Procedure for Testing and Analysis of Extreme Contingencies

1.0 Introduction

Extreme **Contingencies** (ECs) are tested "as a measure of system strength" in order to identify potential patterns of weakness in the bulk power transmission system. This procedure for the testing and analysis of ECs should be used when testing ECs for NPCC studies or studies submitted for NPCC review.

This procedure applies to transmission planning studies that consider the overall performance of the interconnected systems of the NPCC Planning Coordinator Areas. It principally applies to NPCC - wide studies of the **bulk power system** and generally does not apply to studies normally conducted by NPCC Transmission Planner and Planning Coordinators that concentrate on individual or a limited number of facilities. This procedure also applies to Area Transmission Reviews, and may be applicable to other studies conducted by the Transmission Planner and Planning Coordinators, and even to individual facility investigations, where such studies and investigations consider the overall performance of the interconnected systems of the NPCC Planning Coordinator Areas. Certain Transmission Planners or Planning Coordinators may elect to completely mitigate the effects of specific ECs.

Finally, this procedure should be followed in multi-regional studies in which NPCC is an active participant, to the extent that this is within the scope of such multi-regional efforts.

2.0 Choosing Contingencies for Testing

The ECs are defined as per **Requirement R9**. Testing should focus on those ECs expected to have the greatest potential effect on the interconnected system. Particular attention should be paid to **contingencies** which would result in major angular power shifts, e.g., interruption of shorter transmission paths carrying heavy power flows, leaving longer transmission paths as the only remaining paths. Additionally, **contingencies** which would result in reversal of major power transfers, e.g. loss of major ties in a neighboring region or Area when said region or Area was transferring power away from the area of interest, should be considered for their impact in subjecting the system to severe power swings. In considering specific **contingencies** to be investigated in an NPCC study, all relevant testing done at the Transmission Planner and Planning Coordinator level should first be reviewed.

In general, a **contingency** in a particular Planning Coordinator Area should be studied, if requested by any other Transmission Planner or Planning Coordinator, based on a reasonable surmise that the requesting Entity may be adversely affected.

3.0 Modeling Assumptions

As referenced in Table 2, performance assessment “i” for **R9**, the assumed generation dispatch, transfers levels, load levels and **load** representation are major considerations in EC tests. It is not the intent to test the worst imaginable extreme, but EC tests should be severe.

The specification of appropriate **load** representation applies to long term stability tests or post-transient power flows as well as **transient stability** tests.

4.0 Evaluating Individual Test Results

A question in evaluating the results of a particular test run is - “Does the system “pass” or “fail” for this **contingency**?” While in the final analysis this is a matter of informed engineering judgment, factors which should be considered include:

1. Lines or transformers loaded above **short time emergency ratings**,
2. Buses with voltage levels in violation of **applicable emergency limits**, (which vary depending on the location within the system),
3. Magnitude and geographic distribution of such overloads and voltage violations across the system,
4. Transient generator angles, frequencies, voltages and power,
5. Operation of Dynamic Control Systems and **Special Protection Systems (SPS)**,
6. Oscillations that could cause generators to lose synchronism or lead to dynamic instability,
7. Net loss of source resulting from any combination of loss of synchronism of one or more units, generation rejection or runback initiated by SPS, or any other defined system separation,
8. Identification of the extent of the Planning Coordinator Area (s) involved for any indicated instability or islanding (the involvement of more than one Planning Coordinator Area, should be a major consideration),
9. **Relay** operations or the proximity of apparent impedance trajectories to **relay** trip characteristics,
10. The angle across opened breakers,
11. Adequacy of computer simulation models and data.

Finally, a judgment should be attempted as to whether a "failure" is symptomatic of a basic system weakness, or just sensitivity to a particular EC. For example, should failures turn up for several EC tests in a particular part of the system, it is likely that a basic system weakness has been identified.

The loss of portions of the system should not necessarily be considered a failed result, provided that these losses do not jeopardize the integrity of the overall BPS.

NPCC study groups should avoid characterizations like "successful" and "unsuccessful" when commenting on individual runs. Rather, the specific initial conditions directly causing or related to the failure, the complete description of the nature of the failure (e.g., voltage collapse, instability, system separation, as well as the facilities involved), and the extent of potential impact on other Planning Coordinator Areas should be reported.

5.0 Evaluating the Results of EC Tests

EC test reports should focus on those portions of the system in which basic system weaknesses may be developing, rather than on the results of one specific **contingency**.

Any patterns of weaknesses should be identified, which may include reference to earlier NPCC studies and/or Transmission Planner, Planning Coordinator or member system investigations. There is also a need to distinguish between a "failed" test which indicates sensitivity only to a particular **contingency** run and a "failed" test which indicates a more general system weakness (always keeping in mind the severity of possible consequences of the **contingency**). Actions taken by member systems, Transmission Planners or Planning Coordinators to reduce the probability of occurrence or mitigate the consequences of the **contingency** should also be cited.

NPCC follow-up, after publication of a final report, is appropriate only for instances of possible general system weakness. In these instances, the results should be specifically referred to the affected Transmission Planner(s) or Planning Coordinator(s) for further and more detailed investigation with subsequent reporting to NPCC.

Appendix D - Guidelines for Area Review of Resource Adequacy

1.0 Introduction

NPCC has established a Reliability Assessment Program to bring together work done by the NPCC and Planning Coordinators relevant to the assessment of **bulk power system reliability**. As part of the Reliability Assessment Program, each Planning Coordinator submits to the Task Force on Coordination of Planning its Area Review of Resource Adequacy, which is an annual assessment to demonstrate that the proposed resources of each NPCC Planning Coordinator will meet NPCC resource adequacy planning requirements, consistent with these guidelines. The Task Force is charged, on an ongoing basis, with reviewing and recommending NPCC Reliability Coordinating Committee approval of these reviews of **resource** adequacy of each Planning Coordinator Area of NPCC.

The NPCC role in monitoring conformance with the NPCC Directory #1 - *Design and Operation of Bulk Power System* is essential because under this criterion, each Planning Coordinator determines its resource requirements by considering interconnection assistance from other Planning Coordinators, on the basis that adequate **resources** will be available in those Planning Coordinator Areas. Because of this reliance on interconnection assistance, inadequate **resources** in one Planning Coordinator Area could result in adverse consequences in another Planning Coordinator Area.

It is recognized that all Planning Coordinators may not necessarily express their own **resource** adequacy criterion as stated in Requirements R4, R5, and R6 of the Directory #1 criteria. However, the Directory #1 criteria provide a reference point against which a Planning Coordinator's **resource** adequacy criterion can be compared.

2.0 Purpose of Presentation

The purpose of the presentation associated with a resource adequacy review is to show that each Planning Coordinator's proposed resources are in accordance with the NPCC Directory #1 - Design and Operation of the Bulk Power System. By such a presentation, the Task Force will satisfy itself that the proposed resources of each NPCC Planning Coordinator will meet the NPCC Resource Adequacy Requirements, as defined NPCC Directory #1, over the time period under consideration.

3.0 Format of Presentation and Report – Comprehensive Review

Each Planning Coordinator should include in its presentations and in the accompanying report documentation, as a minimum, the information listed below. At its own discretion,

the Planning Coordinator may discuss other related issues not covered specifically by these guidelines.

3.1 Executive Summary

3.1.1 Briefly illustrate the major findings of the review.

3.1.2 Provide a table format summary of major assumptions and results.

3.2 Table of Contents

3.2.1 Include listing of all tables and figures.

3.3 Introduction

3.3.1 Reference the previous NPCC Area Review.

3.3.2 Compare the proposed resources and load forecast covered in this NPCC review with that covered in the previous review

3.4 Resource Adequacy Criterion

3.4.1 State the Planning Coordinator's resource adequacy criterion.

3.4.2 State how the Planning Coordinator criterion is applied; e.g., load relief steps.

3.4.3 Summarize resource requirements to meet the criteria for the time period under consideration. If interconnections to other Planning Coordinators and regions are considered in determining this requirement, indicate the value of the interconnections in terms of megawatts.

3.4.4 Provide either an estimate of the resources required to meet the NPCC criteria or a statement as to the comparison of the two criteria, if the Planning Coordinator criterion is different from the NPCC criterion.

3.5 Resource Adequacy Assessment

3.5.1 Evaluate proposed resources versus the requirement to reliably meet projected electricity demand assuming the Planning Coordinator's most likely load forecast.

3.5.2 Evaluate proposed resources versus the requirement to reliably meet projected electricity demand assuming the Planning Coordinator's high load growth scenario.

- 3.5.3 Describe load and resource uncertainties on projected Planning Coordinator Area reliability and describe mechanisms to mitigate anticipated material adverse effects on reliability.
- 3.5.4 Describe anticipated effects from proposed major changes to market rules on Planning Coordinator Area reliability.
- 3.5.5 Summarize resource adequacy studies conducted since the previous Area Review, as appropriate
- 3.6 Proposed Resource Capacity Mix
 - 3.6.1 Discuss anticipated material adverse effects on reliability resulting from the proposed resources fuel supply and transportation or environmental considerations.
 - 3.6.2 Describe available mechanisms to mitigate anticipated reliability impacts of resource fuel supply, demand resource response, transportation issues and/or environmental considerations.
 - 3.6.3 Discuss anticipated reliability impacts related to an Area's compliance with State, Federal or Provincial requirements (such as environmental, renewable energy, or greenhouse gas reductions).

4.0 Format of Presentation and Report – Annual Interim Review

The Annual Interim Review should include a reference to the most recent Comprehensive Review; a listing of major changes in: facilities and system conditions, load forecast, generation resources availability; related fuel supply and transportation information, environmental considerations, demand response programs, transfer capability and emergency operating procedures. In addition, the assessment should also include a comparison of major changes in market rules, implementation of new rules, locational requirements, and installed capacity requirements. Finally, the report should include a brief impact assessment and an overall summary.

The Planning Coordinator will provide a brief assessment of the impact of these changes on the reliability of the interconnected bulk power system. This assessment should be based on engineering judgment, internal system studies and appropriate joint interconnected studies. To the extent that engineering judgment or existing studies can be used to clearly demonstrate that a Planning Coordinator Area is expected to meet the NPCC resource adequacy criterion, detailed system LOLE studies are not required.

The documentation for the Annual Interim Review should be in the form of a summary report (normally not exceeding three to five pages.)

Sections A and B should describe the reliability model and program used for the resource adequacy studies discussed in Section 3.5. Section C should describe the Task Force follow-up procedures.

A. Description of Resource Reliability Model

1.1 Load Model

1.1.1 Description of the **load** model and basis of period **load** shapes.

1.1.2 How **load** forecast uncertainty is handled in model.

1.1.3 How the electricity demand and energy projections of interconnected entities within the Planning Coordinator Area that are not members of the Planning Coordinator Area are addressed.

1.1.4 How the effects (demand and energy) of demand-side management programs (e.g., conversion, interruptible demand, direct control **load** management, demand (**load**) response programs) are addressed.

1.2 Supply Side Resource Representation

1.2.1 Resource Ratings

1.2.1.1 Definitions.

1.2.1.2 Criteria for verifying **ratings**. Reference NPCC Directory#9 Verification of Gross and Net Real Power Capability and Directory#10 Verification of Gross and Net Reactive Power Capability.

1.2.2 Unavailability Factors Represented

1.2.2.1 Type of unavailability factors represented; e.g., forced outages, planned outages, partial derating, etc.

1.2.2.2 Source of each type of factor represented and whether generic or individual unit history provides basis for existing and new units

1.2.2.3 Maturity considerations, including any possible allowance for in-service date uncertainty.

1.2.2.4 Tabulation of typical unavailability factors.

1.2.3 Purchase and Sale Representation

- 1.2.3.1 Describe characteristics and level of dependability of transactions.
- 1.2.4 Retirements.
 - 1.2.4.1 Summarize proposed retirements.
- 1.3 Representation of Interconnected System in Multi-Area Reliability Analysis, including which Planning Coordinator Areas and regions are considered, interconnection capacities assumed, and how expansion plans of other Planning Coordinators and regions are considered.
- 1.4 Modeling of Variable and Limited Energy Sources.
- 1.5 Modeling of Demand Side Resources and Demand (Load) Response Programs.
 - 1.5.1 Description should include how such factors as in-service date uncertainty, **rating**, availability, performance and duration are addressed.
- 1.6 Modeling of all Resources.
 - 1.6.1 Description should include how such factors as in-service date uncertainty; capacity value, availability, **emergency** assistance, scheduling and deliverability are addressed.
- 1.7 Other assumptions i.e., internal transmission limitations, maintenance over-runs, fuel supply and transportation and environmental constraints.
- 1.8 Incorporate the reliability impacts of market rules.

B. Other Factors, If Any, Considered in Establishing Reserve Requirement Documentation

The documentation required to meet the requirements of the above format should be in the form of summaries of studies performed within a Planning Coordinator Area, including references to applicable reports, summaries of reports or submissions made to regulatory agencies.

C. Task Force Follow-Up Procedures

Once a specific Planning Coordinator has made a presentation or a series of presentations to the Task Force on Coordination of Planning, the latter shall:

- 1.1 Prepare a brief summary of key issues discussed during the presentation.

- 1.2 Note where further information was requested and the results of such further interrogations.
- 1.3 Note the specific items that require additional study and indicate the responsibilities for undertaking these studies.
- 1.4 Recommend to the Reliability Coordinating Committee whether the Resource Adequacy Review is suitable for approval.

Appendix E - Guidelines for Requesting Exclusions to Simultaneous Loss of Two Adjacent Transmission Circuits on a Multiple Circuit Tower.

1.0 Introduction

Directory #1 allows for requests for exclusion from the simultaneous loss of two adjacent transmission circuits on multiple circuit towers on the basis of acceptable risk. All exclusions must be reviewed by the applicable Task Forces and approved by the Reliability Coordinating Committee (RCC). An acceptance of a request for exclusion is dependent on the successful demonstration that such exclusion is an acceptable risk. These guidelines describe the procedure to be followed and the supporting documentation required when requesting exclusion, and establishes a procedure for periodic review of exclusions of record.

2.0 Documentation

The documentation supporting a request for exclusion to the Criteria includes the following:

- 2.1 A description of the facilities involved, including geographic location, length and type of construction, and electrical connections to the rest of the interconnected power system;
- 2.2 Relevant design information pertinent to the assessment of acceptable risk, which might include: details of the construction of the facilities, geographic or atmospheric conditions, or any other factors that influence the risk of sustaining the loss of adjacent transmission circuits on a multiple circuit tower;
- 2.3 An assessment of the consequences of the loss of adjacent transmission circuits on a multiple circuit tower, including, but not limited to, a discussion of levels of exposure and probability of occurrence of **significant adverse impact** on the **bulk power system** ;
- 2.4 For existing facilities, the historical outage performance, including cause, for such **contingencies** on the specific facility (facilities) involved as compared to that of other multiple circuit tower facilities;
- 2.5 For planned facilities, the estimated frequency of adjacent transmission circuit multiple circuit tower **contingencies** based on the historical performance of facilities of similar construction located in an area with similar geographic climate and topography.

3.0 Procedure for obtaining an Exclusion

The following procedure is used to obtain an exclusion:

- 3.1 The entity requesting the exclusion (the Requestor) submits the request and supporting documentation to the Task Force on System Studies (TFSS) after acceptance has been granted by the Requestor's own Planning Coordinator, if such process is applicable.
- 3.2 TFSS reviews the request, verifies that the documentation requirements have been met, and determines the acceptability of the request.
- 3.3 If TFSS deems the request acceptable, TFSS requests the Task Force on Coordination of Planning (TFCP), the Task Force on Coordination of Operation (TFCO), and the Task Force on System Protection (TFSP) to review the request. The Requestor provides copies of the request and supporting documentation to the other Task Forces as directed by TFSS. If additional information is requested by the other Task Forces as part of their assessment, the Requestor provides this information directly to the interested Task Force, with a copy to the TFSS. The other Task Forces review the request and indicate their acceptance or non-acceptance to TFSS.

Appendix F – Procedure for Operational Planning Coordination

1.0 Introduction

The Reliability Coordinators (RC) of the Northeast Power Coordinating Council, Inc. (NPCC) require access to the security data specified in this procedure in order to adequately assess the reliability of the NPCC **bulk power system**. All users of the electric systems, including market participants, should supply such data to the NPCC Reliability Coordinators. Coordination among and within the Reliability Coordinator Areas (RC Area) of NPCC is essential to the reliability of interconnected operations. Timely information concerning system conditions should be transmitted by the NPCC RC Areas to other RC Areas as needed to assure reliable operation of the **bulk power system**. One aspect of this coordination is to ensure that adjacent RC Areas and neighboring systems are advised on a regular basis of expected operating conditions, including generator, transmission and system **protection**, including Type I **special protection system**, outages that may materially reduce the ability of an RC Area to contribute to the reliable operation of the interconnected system, or to receive and/or render assistance to another RC Area. To the extent practical, the coordination of outage schedules is desirable in order to limit the severity of such impacts.

To ensure that there is effective coordination for system **reliability** concerns, this document establishes procedures for the exchange of information regarding load/capacity forecasts, including firm sales and firm purchases, generator outage schedules, and transmission outage schedules for those **elements** that may have an adverse impact on other RC Area(s). It also details general action that may be taken to improve the communication of problems as well as specific topics that may be discussed in regularly scheduled conference calls or ad-hoc conference calls arranged in anticipation of problems such as capacity deficiency or inadequate light load margin in one or more RC Areas.

NPCC participants and other recipients of the information provided by processes in this guideline should adhere to the NPCC Critical Energy Infrastructure Information Non – Disclosure agreement.

2.0 Load/Capacity Forecasts

2.1 Twice yearly by May 15th and November 15th respectively, the Operations Planning Working Group (CO 12) will perform a summer and winter assessment for the next season.

The results will be reviewed by the NPCC TFCO and the NPCC Reliability Coordinating Committee (RCC) in advance of the spring and autumn meetings of both groups

2.2 Each week, each RC Area will review its weekly net resource capacity margin, as

defined in Attachment A, for the twelve weeks to follow and forward the information to the NPCC Staff for distribution to all NPCC RC Areas. If an NPCC RC Area identifies a deficiency or light load condition, the RC Area should identify the cause(s) and mitigation measures that have been implemented, or will be implemented, to manage the issue.

3.0 Generator Outage Coordination

- 3.1 Each RC Area should exchange current and expected generator outages that may have a significant impact on an adjacent RC Area or neighboring systems or a significant impact on the transfer capability between RC Areas.

4.0 Transmission Outage Coordination

4.1 Advance Planning of Transmission Facility Outages

Each RC should exchange critical transmission **element** outages as identified in the coordination agreements with their interconnected neighbors, **elements** identified on the Facilities Notification List and multiple transmission **element** outages that may have an adverse impact on external energy transfers. Each Reliability Coordinator shall minimize the duration of outages to facilities that impact inter-Reliability Coordinator Areas.

4.2 Facilities Notification List

The NPCC Facilities Notification List, Attachment D, has two components:

- 1) the NPCC Transmission Facilities Notification List; and
- 2) the list of NPCC Type I **special protection systems**.

The Facilities Notification List is developed by each RC Area and specifies all facilities that, if removed from service, may have a significant, direct or indirect impact on another RC Area's transfer capability. The cause of such impact might include stability, voltage, and/or thermal considerations.

Prior to October 1st of each year, each RC Area will review and update its Facilities Notification List and coordinate necessary changes with other appropriate NPCC RC Areas. Prior to January 1st, and after review by the TFCO, the jointly developed, updated and approved Facilities Notification List will be posted on the NPCC secure website.

It should be noted that revisions to the Facilities Notification List will not follow the NPCC Process for Open Review due to the secure nature of the information contained, and Attachment D is not openly published with this Procedure.

A temporary reconfiguration of the network may result in an outage to one or more facilities not listed in Attachment D having an impact on other NPCC RC Areas. It is the responsibility of the RC experiencing the condition to notify impacted RCs in a timely manner and provide updated status reports during the condition.

4.3 Notifications of Transmission **Element** Outages:

4.3.1 Notification requirements for Transmission **Element** Outages should be defined in interconnection coordination agreements. The time frames identified below are the minimum notification requirements.

4.3.2 Reliability Coordinators will advise affected RCs of all planned and unplanned outages of **elements** on the Facilities Notification List and those multiple transmission **element** outages that may have an adverse impact on external energy transfers.

All outages to equipment listed in the Facilities Notification List and those multiple transmission **element** outages that may have an adverse impact on external energy transfers should be planned with as much advance notice as practical.

Normally, notification for outages on **elements** covered by this instruction will be submitted to the appropriate RC Areas at least two (2) working days prior to the time the **element** is to be taken out of service.

When an RC Area receives an outage notification from another RC Area, prompt attention will be given to the notification and appropriate comments rendered.

4.3.3 An RC Area will not normally remove from service any transmission **elements**, which might have a **reliability** impact on an RC Area without prior notification to and appropriate review by that RC Area. In the event of an **emergency** condition, each RC Area may take action as deemed appropriate. Other RC Areas should be notified immediately.

An RC Area will make every effort to reschedule routine (non-emergency) transmission outages that severely degrade the reliability of an adjacent RC Area or neighboring system.

4.3.4 Each RC Area will advise the other affected RC Areas of any **protection** outage associated with RC Area tie line facilities Coordination agreements may identify additional reporting requirements associated with **protection** outages.

5.0 Specific Communications

Conditions in an RC Area that may have an impact on another RC Area should be communicated in a clear and timely manner. Specific communications are conducted as follows:

5.1 Weekly

Each Thursday a conference call will be initiated by the NPCC Staff to discuss operations expected during the seven-day period starting with the following Sunday. Operations personnel from the NPCC RC Areas will participate. In advance of the conference call, each RC Area will prepare the data specified in Attachments A and B, and forward it to the NPCC Staff a minimum of one hour in advance of the scheduled call. The completed “NPCC Weekly Conference Call Generating Capacity Worksheet,” Attachment B, together with the list of “Twelve Weeks Projections of Net Margins,” will be forwarded to the conference call participants by the NPCC Staff.

Each RC will review its weekly capacity margins for the next twelve week period. If a deficiency or light load condition is identified, the RC will identify the cause of the deficiency or light load condition and discuss proposed mitigation measures.

The NPCC Staff will prepare Conference Call Notes that will be forwarded to the conference call participants and members of the TFCO by the following Friday afternoon.

Items of particular concern that should be discussed during the weekly conference call are described in Attachment C.

5.2 Emergency Preparedness Conference Call

Whenever adverse system operating or weather conditions are expected, any RC Area may request the NPCC Staff to arrange an Emergency Preparedness Conference Call (NPCC Document C-01) to discuss operating details with appropriate operations management personnel from the NPCC RC Areas and neighboring systems.

5.3 Daily Conference Calls

Each of the NPCC Reliability Coordinator Area control rooms participate in a regularly scheduled daily conference call. The goal of this call is to alert NPCC

Reliability Coordinators of any potential emerging problems. Subjects for discussion are limited to credible events which could impact the ability of a Reliability Coordinator to serve its load and meet its operating reserve obligations, or which would impose a burden to the Interconnection.

Procedure for Operational Planning Coordination – Attachment A

**Load and Capacity Table Instructions
and
Generating Capacity Worksheet Instructions**

Week Beginning	The seven day period for which data is to be reported is defined as starting with the Sunday following the conference call through the following Saturday.
Installed Generating Capacity (Line Item 1)	Include all available generation at its maximum demonstrated capability for the appropriate seasonal capability period.
Firm Purchases (Line Item 2)	Include only those transactions where capacity is delivered. Exclude “energy only” transactions.
Firm Sales (Line Item 3)	Include only those transactions where capacity is delivered. Exclude “energy only” transactions.
Net Capacity (Line Item 4)	Add Installed Generating Capacity and Firm Purchases. Subtract Firm Sales. (Line 1+Line 2-Line3)
Peak Load Forecast (Line Item 5)	The peak load forecast should be the best estimate of the RC Area’s maximum peak load exposure anticipated for the week reported.
Available Reserve (Line Item 6)	Subtract Peak Load Forecast from Net Capacity. (Line 4-Line5.)
Demand Side Management (Line Item 7)	Include only maximum capability which can be obtained by operator initialization within four (4) hours.

Attachment A (continued)	
Known Unavailable Capability (Line Item 8)	Include all known outages, as well as those deratings or unit outages presently forced out, unavailable, on extended cold standby or which are anticipated to remain out of service. This would also include capacity unavailable due to transmission constraints.
Net Reserve (Line Item 9)	Available Reserve plus Demand Side Management minus Known Unavailable Capacity. (Line 6+Line 7-Line 8)
Required Operating Reserve (Line Item 10)	The methodology used by each RC Area in calculating operating reserves should, at a minimum, meet the requirements of NPCC Directory # 5, "Reserve." Methodologies differing from the Directory #5 requirements should be clarified in Attachment B, "NPCC Weekly Conference Call Generating Capacity Worksheet," under the tab for "Operating Reserve."
Gross Margin (Line Item 11)	Subtract Required Operating Reserve from Net Reserve. (Line 9-Line 10)
Unplanned Outages (Line Item 12)	Estimate the amount of generating capacity which will be unavailable. This quantity should be based on historical averages for forced outages and deratings.
Net Resource Capacity Margin (Line Item 13)	Subtract Unplanned Outages from Gross Margin. A positive value reflects surplus reserve. A negative value reflects a deficiency. (Line 11-Line 12)
Forecast High / Low Temperatures and Days (Line Item 14)	Include the expected high and low temperatures for the RC Area for the week, and indicate the day on which they are expected to occur.

Attachment A (continued)	
Seasonal High / Low Temperatures (Line Item 15)	Include the expected high and low forecast seasonal temperatures for the RC Area.
Minimum Load Forecast (Line Item 16)	The minimum load forecast should be the best estimate of the RC Area's minimum load exposure anticipated for the week reported.
Minimum Resources (Line Item 17)	The Minimum Resources are the Reliability Coordinator Area's total expected on-line generator minimum output capability and must-take purchases.
Light Load Margin (Line Item 18)	Subtract Minimum Resources from Minimum Load Forecast. A negative number indicates a light load condition. (Line 16-Line 17)

Procedure for Operational Planning Coordination – Attachment B

NPCC Weekly Conference Call Generating Capacity Worksheet

The “NPCC Weekly Conference Call Generating Capacity Worksheet” is an active spreadsheet used each week to assist in the calculation of the data discussed during the weekly conference call. A blank template is available from the NPCC office.

Procedure for Operational Planning Coordination - Attachment C

CONDITIONS FOR DISCUSSION

Items of particular concern that should be discussed during a conference call can include, but are not limited to, the following:

- anticipated weather;
- largest first and second contingencies;
- operating reserve requirements and expected available operating reserve;
- capacity deficiencies;
- potential fuel shortages or potential supply disruptions which could lead to energy shortfalls;
- light load margins;
- general and specific voltage conditions throughout each system or RC Area;
- status of short term contracts and other scheduled arrangements, including those that impact on operating reserves;
- additional capability available within twelve hours and four hours;
- generator outages that may have a significant impact on an adjacent RC Area or neighboring system;
- transmission outages that may have an adverse impact on external energy transfers;
- potential need for emergency transfers;
- expected transfer limits and limiting elements;
- a change or anticipated change in the normal operating configuration of the system, such as the temporary modification of relay **protection** schemes so that the usual and customary levels of **protection** will not be provided, or the arming of **special protection systems** not normally armed, or the application of abnormal operating procedures; and
- update of the abnormal status of NPCC Type I **special protection systems** forced out of service

Attachment D
NPCC Facilities Notification List

Attachment D is not publicly available due to the confidential nature of the information presented.

Appendix G - Procedures for Inter Reliability Coordinator Area Voltage Control

1.0 Introduction

This Procedure provides general principles and guidance to Reliability Coordinators and Transmission Operators for effective inter- Transmission Operator Area voltage control, consistent with the NPCC, Directory #1, “Design and Operation of the Bulk Power System”. Specific methods to implement this Procedure may vary among Reliability Coordinators and Transmission Operators, depending on local requirements. Coordinated inter- Transmission Operator Area voltage control is necessary to regulate voltages to protect equipment from damage and prevent voltage collapse. Coordinated voltage regulation reduces electrical losses on the network and lessens equipment degradation. Local control actions are generally most effective for voltage regulation. Occasions arise when adjacent Reliability Coordinators and Transmission Operators can assist each other to compensate for deficiencies or excesses of **reactive power** and improve voltage profiles and system security.

2.0 Principles

Each Reliability Coordinator and Transmission Operator operates, in accordance with NPCC, Directory #1, “Design and Operation of the Bulk Power System” criteria, their own individual or joint operating policies, procedures and applicable interconnection agreements. Adjacent Reliability Coordinators and Transmission Operator should be familiar with the respective criteria and procedures of their neighboring Reliability Coordinators and Transmission Operator Areas, and should mutually agree upon procedures for inter- Transmission Reliability Coordinator and Operator Area voltage control.

In the event the system state changes to a condition that requires a voltage or reactive corrective action, the Reliability Coordinator and Transmission Operator for the Area in which the condition is originating from should immediately take corrective action. If the corrective control actions are ineffective, or the Reliability Coordinator and Transmission Operator for the Area have insufficient reactive resources to control the problem, assistance may be requested from other Reliability Coordinators and Transmission Operator Areas.

Whether inter- Reliability Coordinator and Transmission Operator Area voltage control is carried out through specific or general procedures, the following should be considered and implemented if applicable:

- 2.1 To effectively coordinate voltage control, location and placement of metering for **reactive power** resources and voltage controller status should be the same between adjacent Reliability Coordinators and Transmission Operator Areas;
- 2.2 the availability of **voltage regulating transformers** in the proximity of **tie lines**;

- 2.3 voltage levels, limits, and regulation requirements for stations on either side of an inter- Reliability Coordinator and Transmission Operator Area interface;
 - 2.4 the circulation of **reactive power** (export at one tie point in exchange for import at another);
 - 2.5 **tie line** reactive losses as a function of active **power** transfer;
 - 2.6 the sharing of the reactive requirements of **tie lines** and series regulating equipment (either equally or in proportion to line lengths, etc.);
 - 2.7 the transfer of **reactive power** from one Reliability Coordinator and Transmission Operator Area to another
 - 2.8 reactive **reserve** of on-line generators;
 - 2.9 shunt reactive device availability and switching strategy;
 - 2.10 **static VAR compensator** availability, reactive **reserve**, and control strategy;
 - 2.11 each Reliability Coordinator and Transmission Operator Area should anticipate voltage trends and initiate corrective action in advance of critical periods of heavy and light **loads**.
 - 2.12 Each Reliability Coordinator and Transmission Operator Area should maintain a mix of static and dynamic resources, including reactive **reserves**
- 3.0 **Procedure for Triennial Monitoring and Reporting of Inter-Area Voltage Control**
- 3.1 On, or shortly before, the first of July, the Task Force Coordination of Operations (TFCO) Secretary will write to each TFCO member, requesting a written response by the end of July in the form of:
 - a) A copy of any new or revised procedures, principles, or understandings (such as minutes of an operating committee meeting between Reliability Coordinators and Transmission Operator Areas) between the reporting Reliability Coordinator and adjacent Reliability Coordinators. , or,
 - b) a response indicating no change to existing procedures, principles, or understandings currently on file at NPCC.
 - 3.2 The TFCO Secretary will summarize the responses and will forward it to TFCO members at least two weeks prior to the October TFCO meeting.

- 3.3 Following TFCO review and acceptance of the responses, the TFCO Chairman will forward the summary to the Chairman of the Reliability Coordinating Committee (RCC) for informational purposes. This will normally be forwarded three weeks prior to the next regularly scheduled RCC meeting.