

Con Edison Quality Assurance Findings for 2015-16 IRM Preliminary Base Case

INT-TRLM

BHE-ME, ME-S-ME, and SME-NH had different ratings than the topology shown in Assumption Matrix V9a (pg. 18)

Why are HQ-CMA negative direction 0 on Jan and Nov, but 1200 only in May? Winter contract to HQ?

BOS-IMP 4900? Shouldn't it be 4850?

CT-IMPEX 2500? Should be 2600?

MOD-PRIO

What are AUPU_A, AUPU_B, etc. modifiers?

UNT-MXCP

ID-502 MYSTIC 7 should be around 575.5 MW (according to CELT), but we have them in the model as 560 MW.

EOP-DATA

Vol. Curtail should be 122 MW, 116 MW is currently in the model.

5% manual voltage reduction is off by 1.5 MW (62 vs 63.488), but should not have an impact on the model. (using 2007 shape as the basis for P.U. of load)