


Probabilistic Methods in Resource Adequacy Planning at PJM

IEEE PES General Meeting
July 2015, Denver CO

PJM RTO

Members	900+
Millions - people served	61
Peak Load (MW)	165,492
Generating Capacity (MW)	183,604
DR and EE (MW)	11,100+
Transmission Lines (Miles)	62,500+
Energy (GW - 2013)	791,089
Generation Sources	1,376
Area Served (Sq Miles)	243,417
States served	13 + DC
21% of U.S. GDP	



Motivation


- Sources of uncertainty in resource adequacy planning
 - Load
 - Resource Performance
 - Generation
 - Demand Response
 - Transmission
- Main concern for adequacy planners
 - If $X = \text{Sum of Available Resources at time } t$
 - $Y = \text{Load at time } t$
 - then a **Loss of Load Event** (LOLE) takes place when $X < Y$
- Ensure availability of adequate capacity resources
 - Capacity market (PJM's Reliability Pricing Model)

Probabilistic Adequacy Studies at PJM

- Reserve Requirement (aka Installed Reserve Margin Study)
- Capacity Emergency Transfer Objective (CETO)
- Demand Response (DR) Caps

Reserve Requirement Study (RRS)

- Objective
 - Compute Installed Reserve Margin (IRM)
 - IRM then is used to construct a downward sloping demand curve in Reliability Pricing Model (RPM)
- Approach






Reserve Requirement Study (RRS)

- Inputs (for PJM and World)
 - Generation
 - Expected Generation fleet (capturing expected additions, retirements)
 - Forced Outage Rates (EFORd)
 - Rate assumed to provide the probability that a unit is unavailable on a forced outage at the time of demand
 - Planned Outage Requirement
 - Deterministic amount of weeks
 - Load
 - Profile throughout the year (e.g. monthly/weekly/weekday peaks)
 - From the PJM load forecast (which assumes 50/50 weather)
 - Statistical distribution for weekday peaks
 - Normally distributed (captures uncertainty in weather/economics)
 - Parameters of distribution obtained from historical loads

Reserve Requirement Study (RRS)

LOLE Risk for 3 Summer Weeks



The same comparison is made for the remaining 49 weeks of the target year.

Study criteria: total annual LOLE = 0.1 events/yr.

In other words, $LOLE = \sum_{year} E(X < Y) = 0.1$

Reserve Requirement Study (RRS)


- Output
 - Installed Reserve Margin (IRM) = Total Installed Generation / Solved Annual Peak Load
 - Forecast Pool Requirement (FPR) = IRM * (1 - Average Forced Outage Rate)

Capacity Emergency Transfer Objective (CETO)

- Similar to the RRS
 - But applied to Locational Deliverability Area (LDA)
- Objective
 - Compute CETO for each LDA (i.e., amount of imports needed) which then is compared to the Capacity Emergency Transfer Limit (CETL)
 - Also, total amount or resources (including CETO) is then used to construct demand curve in RPM for the LDA

Capacity Emergency Transfer Objective (CETO)

- Approach




LDA

Other LDAs (inside PJM)
and/or neighboring World
regions

Capacity Emergency Transfer Objective (CETO)

- Inputs
 - LDA's Generation and Load (similar to RRS)
- Criterion

Total annual LOLE =
0.04 events/yr.



Capacity Emergency Transfer Objective (CETO)

- Output
 - CETO
 - Reliability Requirement = CETO + Total Internal Generation * (1-Average Forced Outage Rate)
 - Used in RPM
- CETL is also used in RPM

Total LOLE Risk due to Transmission and Capacity Adequacy

Zone	CETL (MW)	Capacity Adequacy	LOLE Risk (events/year)	Transmission LOLE Risk (events/year)	Total LOLE Risk (events/year)
LDA X	CETO		0.1	0.04	0.14
LDA Y	> CETO		0.1	< 0.04	< 0.14


RRS and CETO in RPM

- So far we have set the reliability requirements for PJM and the LDAs based on these probabilistic studies
- Those requirements are in Unforced Capacity (UCAP) terms
 - Recall the multiplication by (1-Average Forced Outage Rate) in the FPR and RR computations
- In RPM, each resource (generation, DR, EE) has a UCAP valuation
 - And they compete to meet the UCAP requirement
- Some resources, however, are not available during the entire year
 - E.g. Limited DR, Extended Summer DR
 - PJM does not reduce their UCAP valuation due to these limitations
 - PJM sets caps for these resources instead


Limited DR and Extended Summer DR RPM Requirements

Requirement	Limited DR	Extended Summer DR
Availability	Any weekday, other than NERC holidays, during Jun. - Sep. period of delivery	Any day during Jun. - Oct. period and following May of delivery
Maximum Number of Interruptions	10 interruptions	Unlimited
Hours of Day Required to Respond (Hours in EPT)	12 – 8:00 p.m.	10 a.m. – 10:00 p.m.
Maximum Duration of Interruption	6 Hours	10 Hours

Reserves in PJM resulting from RRS



(Potential) Reserves in PJM after an RPM auction



Demand Response (DR) Caps

- Objective
 - Compute caps for DR products D with limited availability so that their clearing in RPM (displacing annual availability products) does not pose reliability concerns
- Approach
 - Caps are computed at the RTO and at the LDA levels

$$\begin{aligned} & \max D \\ \text{s.t.:} & \\ & \sum_{\text{year}} E(G + D < Y) = 0.1 + \alpha \quad \text{With } X = G + D \end{aligned}$$

$$G + D = \text{IRM}$$

Demand Response (DR) Caps

- Inputs
 - Load distribution from IRM/CETO case
 - Capacity distribution from IRM/CETO case
- Procedure: we solve the optimization problem by inspection
 - Capacity distribution gets shifted to the left during periods (weeks) where DR is not available
 - Implicit assumption: DR displaces average performing generation
 - We make some corrections for reduction of maintenance requirements due to DR displacing generation

Demand Response (DR) Caps

- Additional Tests
 - Limited DR product has two additional limitations
 - Can be called up a maximum of 10 times
 - Can be called up for a maximum of 6 hours in each call
 - Additional caps are computed based on:
 - Probability of needing DR more than 10 times
 - Probability of needing DR more than 6 hours
- For Limited DR in some LDAs, the cap based on the probability of needing DR more than 6 hours is the most limiting cap.

Demand Response (DR) Caps

- Output
 - DR Cap expressed as a percentage of the Reliability Requirement for RTO and the LDAs

Actual Inputs to RPM 2017/2018 Delivery Year

- RTO


- IRM = 15.7%
- FPR = 1.0916
- Reliability Requirement (RR) = 179,545 MW
- Limited DR Cap = 4.1%
- Limited DR + Extended Summer DR Cap = 9.3%

- LDA (MAAC)

- CETO = 4,420 MW
- Reliability Requirement (RR) = 71,534 MW
- Limited DR Cap = 6.1%
- Limited DR + Extended Summer DR Cap = 11.5%
- CETL = 7,393 MW

Usage of Probabilistic Studies' Outputs in RPM

For the RTO and each LDA modeled in RPM:



Demand Curve for RPM
(Target Level of Reserve = RR)

If,
 G_i = Internal Annual Resources
 G_e = Resources Imported
 D = Limited Availability Resources

Then, RPM's clearing mechanism considers the following constraints

$$G_e \leq CETL$$

$$D \leq Cap_D$$

Other Probabilistic Studies for Resource Adequacy at PJM

- NERC Probabilistic Assessment
 - Designed to assess the reliability of a system on a future year by calculating Expected Unserved Energy (EUE) and Loss of Load Hours (LOLH)
- Winter Weekly Reserve Target
 - Designed to schedule maintenance during the winter season

Probabilistic Methods in Resource Adequacy Planning at PJM

IEEE PES General Meeting
July 2015, Denver CO