

New York State Reliability Council - Installed Capacity Subcommittee
Action Items List 80+Conference Call 35
[Fade out items denotes Action Item has been completed]

No	Action Item	Responsible Individual(s)	Sched./ Actual Comp. Dates
66-1	Collapse all EOPs and use only summer months and find out if LOLE is the same around 0.1 days/year. Partially completed.	Greg Drake/Greg Campoli	9-30-07
66-2	Con Edison and NYISO to automate the IRM/LCR curve calculation and perform the benchmarking.	Drake/Villalba	10-10-07
74-1	Draft a procedure to determine the treatment of external capacity.	NYISO	10/31/07
75-2	Provide a summary version of the IRM Study Schedule and Project Timeline at the next meeting, currently scheduled for May 30.	Steve Jeremko	10/03/07
<i>75-3</i>	<i>Discuss MARS switch settings at Meeting #78. NYISO and Glenn.</i>	<i>NYISO</i>	<i>6/27/07</i>
76-4	Delivery of the transmission model. Add nomograms to the interface between New York and Long Island to account for the loss of the Barrett and Glenwood units. Share with the group the resultant nomograms.	Bill Lamanna	10/03/07
77-2	Verify how far apart the year to year forecast shown in the Gold Book has been during the last 5 years.	Maniaci	11/1/07
78-1	Refine PJM East area model and interconnections with NYISO through IPSAC.	Bill Lamanna	11/1/07
78-3	Write up on the cable interface (I to J) limits changes	Bill Lamanna	10/03/07
<i>78-5</i>	<i>Review Zone J simultaneous import capability from PJM and Zone K.</i>	<i>Bill Lamanna</i>	<i>9/1/2007</i>
<i>78-6</i>	<i>Modify modeling technique of Astoria West units to reflect that any one of the Astoria GTs 10-13 can be connected at any time and to increase the capacity states of NYPA CC unit from 2 to 7.</i>	<i>Greg Drake</i>	<i>8/1/2007</i>
<i>78-7</i>	<i>Verify if 79.9 MW Plattsburg wind farm is in service. Greg will report back to the group on this item</i>	<i>Greg Drake</i>	<i>8/1/2007</i>
79-1	Simple Cycle derate analysis for downstate units. Investigate emergency ratings of the units. Investigate whether the difference between emergency rating and normal rating is used for operating reserve. Review CT generation DMNC test data.	Cenk Yildirim	10/3/2007
**80-1	Review Loads and generation on all four neighboring pools.	Arthur Maniaci	10/3/2007
**	It may drop-off from the list.		