

September 1st, 2021 ICS Meeting #251

Prepared for: September 10th, 2021 EC Meeting
Prepared by: Brian Shanahan, ICS Chairperson

1. Review of 2022 Preliminary Base Case Tan45 Results & Tan45 Curve Points - for EC Review

ICS reviewed and accepted the 2022 Tan45 results, which are an IRM of 18.6% with Zone J LCR of 80.6% and Zone K LCR of 96.1%. These results are a net -2.1% change from the prior year and are provided for Executive Committee review.

2. Review of PBC table 6-1 – for EC Review

ICS reviewed and approved the 2022 PBC Table 6-1, which is an IRM Impact Assessment comparing 2022 to 2021 PBC results. The largest contributor to year-on-year changes is Summer LFU improvements (-1.3%) due to the narrowing of high load bins. Capacity additions resulted in a (+0.4%) increase from the prior year due to the addition of 180 MW of wind and solar generation. This was countered by a -0.4% impact from updated Gold Book DMNC values that saw an upstate to downstate decrease in total available MWs.

Executive Committee Action Requested:

Review and Approval of the 2022 IRM Table 6-1.