

## **NYISO Major Emergency Report**

At 1310 on 10/08/2017 a Major Emergency was declared by the NYISO Shift Supervisor when the power flow on Central East VC exceeded its Transient Stability Limit by more than 105%

This was caused by: Loss of 7040/MSU-1 loaded at 650MW

To correct this the NYISO Shift Supervisor: Curtailed transactions, Started 2 Gilboa units, moved Phase Angle Regulators (PAR), and redispatched generation.

Load relief was not required.

The Major Emergency was terminated at 1321 on 10/08/2017

# NYISO Major Emergency Report

At 00:18 on 03/08/2018 a Major Emergency was declared by the NYISO Shift Supervisor when the power flow on Central East exceeded its Voltage Transfer Limit by more than 105%

This was caused by: An event in ISO-NE that resulted in the loss of 1600MW of generation, including Phase 2 and Kendall 4.

To correct this the NYISO Shift Supervisor: Curtailed transactions, moved Phase Angle Regulators (PAR) to reduce flow, and redispached generation.

Load relief was not required.

The Major Emergency was terminated at 00:26 on 03/08/2018

## NYISO Major Emergency Report

At 08:40 on 03/14/2018 a Major Emergency was declared by the NYISO Shift Supervisor when the power flow on Central East VC exceeded its Transient Stability Limit by more than 105%

This was caused by: An event in ISO-NE that resulted in the loss of 2000MW, including Phase 2 and Mystic 9.

To correct this the NYISO Shift Supervisor:

Placed a capacitor in service, moved Phase Angle Regulators (PAR) to reduce flow, started and redispached generation.

Load relief was not required.

The Major Emergency was terminated at 08:49 on 03/14/2018