

NYISO OPERATIONS REPORT FOR the Month of February 2021

Peak Load

The peak load for the month was 21,746 MW, which occurred on Monday, February 8, 2021, for hour beginning 18:00. At that time the Operating Reserve requirement was 1,965 MW. This resulted in a minimum total Operating Capacity requirement of 23,711 MW for that hour.

Reserve Requirements:

Reserve Requirement	10 sync	Non sync	30 min
For Hour	655	1,310	1,965
DSASP Cont.	1,000	2,432	5,068
	55	0	55

The NYCA all time winter peak load of 25,738 MW, which occurred on Tuesday, January 7, 2014 for hour beginning 18:00.

Major Emergencies

At 01:19 on 02/10/2021 a Major Emergency was declared by the NYISO Shift Supervisor when the power flow on Central East VC exceeded its 105% Voltage Transfer Limit. The Major Emergency was terminated at 01:29.

The Major Emergency state was declared 0 times during February of 2020

Alert States

ON 5 OCCASIONS AN ALERT STATE WAS DECLARED:

- 0 SYSTEM FREQUENCY 0 LOW 0 HIGH
- 1 ACE GREATER THAN (+OR-) 500MW
- 0 SHORTAGE OF 10 MIN SYNCHRONIZED RESERVE
- 0 SHORTAGE OF 10 MIN TOTAL RESERVE
- 0 ACTUAL FLOW EXCEEDING LTE FOR LESS THAN 5 MIN
- 0 ACTUAL VOLTAGE BELOW PRE-CONTINGENCY LOW LIMIT
- 3 EXCEEDING CENTRAL EAST VOLTAGE CONTINGENCY LIMIT
- 0 EXCEEDING TRANSIENT STABILITY LIMIT
- 0 NYISO COMPUTER PROBLEM
- 0 NEIGHBORING SYSTEM 5% VOLTAGE REDUCTION
- 1 EMERGENCY TRANSFER DECLARED
- 0 GIC (SMD) ACTIVITY
- 0 SEVERE WEATHER
- 0 OTHER

The Alert state was declared 2 times during February of 2020

Thunder Storm Alerts

0 Thunder Storm Alerts were declared for the month of February for a total of 0 hours.

Reserve Activations

ON 9 OCCASIONS RESERVES WERE ACTIVATED DURING THE MONTH:

- 4 LOSS OF NEW YORK CONTROL AREA GENERATORS
- 0 MAINTENANCE OF SYNCHRONIZED RESERVES
- 0 SIMULTANEOUS ACTIVATION OF RESERVES
 - 0 FOR ISO-NE
 - 0 FOR IESO
 - 0 FOR PJM
 - 0 FOR NYISO
 - 0 FOR NB
- 5 LARGE CONTROL ERRORS (ABOVE 200MW)
 - 0 LOAD PICKUP
 - 0 SCHEDULE CHANGE & LOAD PICKUP
 - 3 SCHEDULE CHANGE
 - 0 SCHEDULE CHANGE DUE TO TLR
 - 2 OTHER (FIXED GEN CHANGES / COMPUTER PROBLEMS)

- 0 OF THESE RESERVE ACTIVATION'S DID NOT RESULT IN THE ACE-CROSSING ZERO
- 0 OF THE NON-ZERO CROSSINGS REQUIRED ANOTHER RESERVE PICKUP TO BE INITIATED
- 0 NON-ZERO CROSSINGS WERE ASSOCIATED WITH A UNIT LOSS

ON 5 OCCASIONS RESERVES WERE ACTIVATED DURING THE MONTH OF February 2020
3 OF THESE PICKUPS WERE FOR ACE.

Emergency Actions

Special Case Resources:	SCR Test	Zones	J/K	2/25/2020	16:00-17:00
	SCR Test	Zones	A/B	2/25/2020	17:00-18:00
	SCR Test	Zones	C/D/E/F/G/H/I	2/25/2020	18:00-19:00
Emergency Demand Response Program:	None				
Purchases:	None				
Sales:	None				

TLR 3 Declared

0 TLR Level 3's were declared for the month of February for a total of 0 hours

Inadvertent Accumulations for January-2021

	Monthly Accumulation	End of Month Balance	
On-Peak:	-4,582 MWh	-7,233	MWh
Off-Peak:	-579 MWh	-13,369	MWh

NERC Control Performance

CPS1: 158.14 %
BAAL Violations: 0

NERC/NPCC Reportable DCS Events

None.