

## NYISO OPERATIONS REPORT FOR the Month of June 2021

### Peak Load

The peak load for the month was 30,919 MW, which occurred on Tuesday, June 29, 2021, for hour beginning 17:00. At that time the Operating Reserve requirement was 1,965 MW. This resulted in a minimum total Operating Capacity requirement of 32,884 MW for that hour.

Reserve Requirements:

Reserve	10 sync	Non sync	30 min
Requirement	655	1,310	1,965
For Hour	1,396	2,028	3,017
DSASP Cont.	57	0	57

The NYCA all time summer peak load of 33,956 MW, which occurred on Friday, July 19, 2013 for hour beginning 16:00.

### Major Emergencies

None

The Major Emergency state was declared 0 times during June of 2020

### Alert States

ON 5 OCCASIONS AN ALERT STATE WAS DECLARED:

- 0 SYSTEM FREQUENCY 0 LOW 0 HIGH
- 3 ACE GREATER THAN (+OR-) 500MW
- 1 SHORTAGE OF 10 MIN SYNCHRONIZED RESERVE
- 0 SHORTAGE OF 10 MIN TOTAL RESERVE
- 0 ACTUAL FLOW EXCEEDING LTE FOR LESS THAN 5 MIN
- 0 ACTUAL VOLTAGE BELOW PRE-CONTINGENCY LOW LIMIT
- 1 EXCEEDING CENTRAL EAST VOLTAGE CONTINGENCY LIMIT
- 0 EXCEEDING TRANSIENT STABILITY LIMIT
- 0 NYISO COMPUTER PROBLEM
- 0 NEIGHBORING SYSTEM 5% VOLTAGE REDUCTION
- 0 EMERGENCY TRANSFER DECLARED
- 0 GIC (SMD) ACTIVITY
- 0 SEVERE WEATHER
- 0 OTHER

The Alert state was declared 7 times during June of 2020

### Thunder Storm Alerts

5 Thunder Storm Alerts were declared for the month of June for a total of 19 hours

**Reserve Activations**

ON 9 OCCASIONS RESERVES WERE ACTIVATED DURING THE MONTH:

- 6 LOSS OF NEW YORK CONTROL AREA GENERATORS
- 0 MAINTENANCE OF SYNCHRONIZED RESERVES
- 0 SIMULTANEOUS ACTIVATION OF RESERVES
  - 0 FOR ISO-NE
  - 0 FOR IESO
  - 0 FOR PJM
  - 0 FOR NYISO
  - 0 FOR NB
- 3 LARGE CONTROL ERRORS (ABOVE 200MW)
  - 0 LOAD PICKUP
  - 0 SCHEDULE CHANGE & LOAD PICKUP
  - 1 SCHEDULE CHANGE
  - 0 SCHEDULE CHANGE DUE TO TLR
  - 2 OTHER (FIXED GEN CHANGES / COMPUTER PROBLEMS)

- 1 OF THESE RESERVE ACTIVATION'S DID NOT RESULT IN THE ACE-CROSSING ZERO
- 0 OF THE NON-ZERO CROSSINGS REQUIRED ANOTHER RESERVE PICKUP TO BE INITIATED
- 0 NON-ZERO CROSSINGS WERE ASSOCIATED WITH A UNIT LOSS

ON 19 OCCASIONS RESERVES WERE ACTIVATED DURING THE MONTH OF June 2020  
14 OF THESE PICKUPS WERE FOR ACE.

**Emergency Actions**

Special Case Resources: None  
Emergency Demand Response Program: None  
Purchases: None  
Sales: None

**TLR 3 Declared**

0 TLR Level 3's were declared for the month of June for a total of 0 hours

**Inadvertent Accumulations for May-2021**

	Monthly <u>Accumulation</u>		End of Month <u>Balance</u>	
On-Peak:	6,384	MWh	-285	MWh
Off-Peak:	2,218	MWh	-24,441	MWh

**NERC Control Performance**

CPS1: 155.06 %  
Baal Violations: 0

**NERC/NPCC Reportable DCS Events**

On 06/16/2021 a RPU was initiated at 18:36 for the loss of Astoria Energy 2 CC3 and CC4 loaded at 575 MW.

ACE crossed zero and the RPU was terminated at 18:44.