

NYISO Certification

Description:

NYSRC Reliability Rule Reference (No. and Name)

C.5: Fault Current Assessment

NYSRC Requirement(s) for which compliance is being self-certified

- R2.** After evaluating and considering the *NYISO* assessment in R1 concerning a location for which *fault* duty levels may exceed appropriate equipment *ratings*, the applicable equipment owner shall assess the condition and report its findings to the *NYISO* in accordance with *NYISO* requirements.

Compliance Monitoring Process

Compliance Monitoring Responsibility:

- M2: *NYISO*/RCMS

Compliance Documentation Reporting Frequency:

- M2: Annually

Compliance Reporting Requirements:

- M2: In accordance with Annual Compliance Monitoring Program requirements

Measure No.

<input checked="" type="checkbox"/> Full Compliance	M2. The <i>NYISO</i> certified that all applicable equipment owners evaluated <i>NYISO</i> assessments concerning locations for which <i>fault</i> duty levels may exceed equipment <i>ratings</i> and reported their findings to the <i>NYISO</i> in accordance with <i>NYISO</i> requirements and R2.
---	---

Levels of Non-Compliance

<input type="checkbox"/> Level 1	M2. Not applicable.
<input type="checkbox"/> Level 2	M2. The <i>NYISO</i> certified that one or two applicable equipment owners did not evaluate <i>NYISO</i> fault duty assessments as required and report their findings to the <i>NYISO</i> .
<input type="checkbox"/> Level 3	M2. The <i>NYISO</i> certified that three or more applicable equipment owners did not evaluate <i>NYISO</i> fault duty assessments as required and report their findings to the <i>NYISO</i> .
<input type="checkbox"/> Level 4	M2. Not applicable.

Notes: 2016 NYISO Fault Current Assessment performed according to the NYISO Guideline for Fault Current Assessment were reviewed and approved by the NYISO Operating Committee on May 19, 2016. As a mitigation measure for certain fault current conditions identified in sensitivity analysis, and following due consultation and approval by the equipment owner, the Interim Operating Protocol for Astoria East and West Stations Fault Current Mitigation, approved by the Operating Committee on May 6, 2010, will continue to be implemented. Of the stations evaluated, there are no over-dutied breakers.

Certified by: K. Burrell

Title: Supervisor, System Modeling

Date: May 26, 2016