

NYISO Major Emergency Report

At 00:18 on 03/08/2018 a Major Emergency was declared by the NYISO Shift Supervisor when the power flow on Central East exceeded its Voltage Transfer Limit by more than 105%

This was caused by: An event in ISO-NE that resulted in the loss of 1600MW of generation, including Phase 2 and Kendall 4.

To correct this the NYISO Shift Supervisor: Curtailed transactions, moved Phase Angle Regulators (PAR) to reduce flow, and redispached generation.

Load relief was not required.

The Major Emergency was terminated at 00:26 on 03/08/2018