

NYISO Major Emergency Report

At 08:40 on 03/14/2018 a Major Emergency was declared by the NYISO Shift Supervisor when the power flow on Central East VC exceeded its Transient Stability Limit by more than 105%

This was caused by: An event in ISO-NE that resulted in the loss of 2000MW, including Phase 2 and Mystic 9.

To correct this the NYISO Shift Supervisor:

Placed a capacitor in service, moved Phase Angle Regulators (PAR) to reduce flow, started and redispached generation.

Load relief was not required.

The Major Emergency was terminated at 08:49 on 03/14/2018