

NYISO OPERATIONS REPORT

FOR the Month of

March 2018

Peak Load

The peak load for the month was 20,756 MW, which occurred on Wednesday, March 7, 2018, for hour beginning 18:00. At that time the Operating Reserve requirement was 1,965 MW. This resulted in a minimum total Operating Capacity requirement of 22,721 MW for that hour.

Reserve Requirements:

Reserve	10 sync	Non sync	30 min
Requirement	655	1,310	1,965
For Hour	1,394	3,074	6,164
DSASP Cont.	104	0	104

The NYCA all time winter peak load of 25,738 MW, which occurred on Tuesday, January 07, 2014 for hour beginning 18:00.

Major Emergencies

*On March 8, 2018 a Major Emergency was declared at 00:18 when generation was lost in ISONE causing Central East VC to exceed 105%. The Major Emergency was terminated at 00:26.

*On March 14, 2018 a Major Emergency was declared at 08:40 when generation was lost in ISONE causing Central East VC to exceed 105%. The Major Emergency was terminated at 08:49.

The Major Emergency state was declared 0 times during March of 2017

Alert States

ON 16 OCCASIONS AN ALERT STATE WAS DECLARED:

1 SYSTEM FREQUENCY 1 LOW 0 HIGH
0 ACE GREATER THAN (+OR-) 500MW
2 SHORTAGE OF 10 MIN SYNCHRONIZED RESERVE
0 SHORTAGE OF 10 MIN TOTAL RESERVE
0 ACTUAL FLOW EXCEEDING LTE FOR LESS THAN 5 MIN
0 ACTUAL VOLTAGE BELOW PRE-CONTINGENCY LOW LIMIT
5 EXCEEDING CENTRAL EAST VOLTAGE CONTINGENCY LIMIT
0 EXCEEDING TRANSIENT STABILITY LIMIT
0 NYISO COMPUTER PROBLEM
0 NEIGHBORING SYSTEM 5% VOLTAGE REDUCTION
8 EMERGENCY TRANSFER DECLARED
0 GIC (SMD) ACTIVITY
0 SEVERE WEATHER
0 OTHER

The Alert state was declared 27 times during March of 2017

Thunder Storm Alerts

1 Thunder Storm Alerts were declared for the month of March for a total of 6:00 hours.

Reserve Activations

ON 5 OCCASIONS RESERVES WERE ACTIVATED DURING THE MONTH:

- 0 LOSS OF NEW YORK CONTROL AREA GENERATORS
- 1 MAINTENANCE OF SYNCHRONIZED RESERVES
- 3 SIMULTANEOUS ACTIVATION OF RESERVES
 - 3 FOR ISO-NE
 - 0 FOR IESO
 - 0 FOR PJM
 - 0 FOR NYISO
 - 0 FOR NB
- 1 LARGE CONTROL ERRORS (ABOVE 200MW)
 - 0 LOAD PICKUP
 - 0 SCHEDULE CHANGE & LOAD PICKUP
 - 0 SCHEDULE CHANGE
 - 0 SCHEDULE CHANGE DUE TO TLR
 - 1 OTHER (FIXED GEN CHANGES / COMPUTER PROBLEMS)

- 1 OF THESE RESERVE ACTIVATION'S DID NOT RESULT IN THE ACE-CROSSING ZERO
- 0 OF THE NON-ZERO CROSSINGS REQUIRED ANOTHER RESERVE PICKUP TO BE INITIATED
- 0 NON-ZERO CROSSINGS WERE ASSOCIATED WITH A UNIT LOSS

ON 7 OCCASIONS RESERVES WERE ACTIVATED DURING THE MONTH OF March 2017
1 OF THESE PICKUPS WERE FOR ACE.

Emergency Actions

Special Case Resources: None
 Emergency Demand Response Program: None
 Purchases: None
 Sales: None

TLR 3 Declared

0 TLR Level 3's were declared for the month of March for a total of 0:00 hours

Inadvertent Accumulations for February-2018

	<u>Monthly Accumulation</u>		<u>End of Month Balance</u>	
On-Peak:	-17,087	MWh	19,889	MWh
Off-Peak:	-12,016	MWh	14,054	MWh

NERC Control Performance

CPS1: 202.15 %
 BAAL Violations 0

NERC/NPCC Reportable DCS Events

None