

NYISO OPERATIONS REPORT

FOR the Month of

May 2020

Peak Load

The peak load for the month was 20,124 MW, which occurred on Wednesday, May 29, 2020, for hour beginning 17:00. At that time the Operating Reserve requirement was 1,965 MW. This resulted in a minimum total Operating Capacity requirement of 22,089 MW for that hour.

Reserve Requirements:

Reserve	10 sync	Non sync	30 min
Requirement	655	1,310	1,965
For Hour	1,547	3,371	6,335
DSASP Cont.	63	0	63

The NYCA all time summer peak load of 33,956 MW, which occurred on Friday, July 19, 2013 for hour beginning 16:00.

Major Emergencies

None

The Major Emergency state was declared 0 times during May of 2019

Alert States

ON 7 OCCASIONS AN ALERT STATE WAS DECLARED:

- 1 SYSTEM FREQUENCY 1 LOW 0 HIGH
- 2 ACE GREATER THAN (+OR-) 500MW
- 1 SHORTAGE OF 10 MIN SYNCHRONIZED RESERVE
- 0 SHORTAGE OF 10 MIN TOTAL RESERVE
- 0 ACTUAL FLOW EXCEEDING LTE FOR LESS THAN 5 MIN
- 0 ACTUAL VOLTAGE BELOW PRE-CONTINGENCY LOW LIMIT
- 1 EXCEEDING CENTRAL EAST VOLTAGE CONTINGENCY LIMIT
- 0 EXCEEDING TRANSIENT STABILITY LIMIT
- 0 NYISO COMPUTER PROBLEM
- 0 NEIGHBORING SYSTEM 5% VOLTAGE REDUCTION
- 2 EMERGENCY TRANSFER DECLARED
- 0 GIC (SMD) ACTIVITY
- 0 SEVERE WEATHER
- 0 OTHER

The Alert state was declared 14 times during May of 2019

Thunder Storm Alerts

0 Thunder Storm Alerts were declared for the month of May for a total of 0 hours

Reserve Activations

ON 9 OCCASIONS RESERVES WERE ACTIVATED DURING THE MONTH:

- 1 LOSS OF NEW YORK CONTROL AREA GENERATORS
- 0 MAINTENANCE OF SYNCHRONIZED RESERVES
- 6 SIMULTANEOUS ACTIVATION OF RESERVES
 - 4 FOR ISO-NE
 - 1 FOR IESO
 - 0 FOR PJM
 - 1 FOR NYISO
 - 0 FOR NB
- 3 LARGE CONTROL ERRORS (ABOVE 200MW)
 - 0 LOAD PICKUP
 - 0 SCHEDULE CHANGE & LOAD PICKUP
 - 2 SCHEDULE CHANGE
 - 0 SCHEDULE CHANGE DUE TO TLR
 - 1 OTHER (FIXED GEN CHANGES / COMPUTER PROBLEMS)

- 0 OF THESE RESERVE ACTIVATION'S DID NOT RESULT IN THE ACE-CROSSING ZERO
- 0 OF THE NON-ZERO CROSSINGS REQUIRED ANOTHER RESERVE PICKUP TO BE INITIATED
- 0 NON-ZERO CROSSINGS WERE ASSOCIATED WITH A UNIT LOSS

ON 7 OCCASIONS RESERVES WERE ACTIVATED DURING THE MONTH OF May 2019
3 OF THESE PICKUPS WERE FOR ACE.

Emergency Actions

Special Case Resources: None
Emergency Demand Response Program: None
Purchases: None
Sales: None

TLR 3 Declared

0 TLR Level 3's were declared for the month of May for a total of 0 hours

Inadvertent Accumulations for April-2020

	Monthly <u>Accumulation</u>		End of Month <u>Balance</u>	
On-Peak:	4,229	MWh	14,900	MWh
Off-Peak:	3,028	MWh	-10,998	MWh

NERC Control Performance

CPS1: 161.28 %
BAAL Violation: 0

NERC/NPCC Reportable DCS Events

On 05/03/2020 a RPU and SAR was initiated at 17:27 for the loss of CPV units 1 & 2 loaded at 580 MW. ACE

crossed zero and the RPU was terminated at 17:31. SAR was terminated at 17:45