Submit request to raymond40@aol.com via the NYSRC site www.nysrc.org Item Information		
1. PRR No. & Title of Reliability Rule or Requirement change	PRR 132 I.4 Transmission Data	
2. Rule Change Requester Information		
Name	Reliability Rules Subcommittee	
Organization		
3. New rule or revision to existing rule?	Revision	
4. Need for rule change, including advantages and disadvantages	The New York State Reliability Council (NYSRC) Executive Committee adopted NYSRC's Reliability Compliance Monitoring Subcommittee (RCMS) recommendation for the NYSRC's Reliability Rules Subcommittee (RRS) <i>"to review and modify Reliability Rule 1.4 and the related Requirements and to propose modifications, to the extent necessary, to clearly and objectively identify non-compliant data error submissions, and to consider any other modifications the RRS deems necessary;" This recommendation came from RCMS review of Market Participant compliance violation of Transmission Data requirement (1.4). RCMS members noted the difficulty in interpretation of Requirement 1.4 as follows: • The impossibility of perfect data accuracy [is unachievable] based upon the thousands of data items and repetitive updating of data sets. [Therefore,] it would be imprudent and impracticable to find every instance of an erroneous data submission to be noncompliant. • While all data errors require correction, <u>not all have the potential to have a</u> <u>material</u>most do not adversely impact_affect on the reliability of the NYS Bulk Power <u>System. The NYISO is expected to exercise its</u>-ud judgment <u>in assessing the is</u> required to assess-materiality <u>of the data error</u>. It is noted that 1.4, as currently written, does not require that the potential impact on reliability of the data errors</i>	
5. Related NYSRC rules	None	
6. Section A – Reliability Rule Elements		
1. Reliability Rule	Accurate load flow, short circuit, and stability data bases required for planning and operating studies of the NYS Bulk Power System shall be developed and maintained The data shall include appropriate detail from adjacent control areas.	
2. Associated NERC & NPCC Standards and Criteria	NPCC: Directory 1 NERC: MOD-010, 012, 031; IRO-010	
3. Applicability	NYISO, Market Participants and Developers	

Request to Develop or Modify Reliability Rules and Requirements (NYSRC Policy No. 1-7) Submit request to raymond40@aol.com via the NYSRC site www.nysrc.org

1

I

7. Section B – Requirements		
	R1. The NYISO shall establish and maintain procedures for the development and	
	maintenance of load flow, short circuit, and stability data bases. These procedures	
	shall:	
	R.1.1 Require Market Participants and Developers to provide complete.	Formatted: Font: Not Bold
	consistent and accurate required accurate and comprehensive equipment data	Formatted: Font: Not Bold
	consistent and accurate required accurate and comprehensive equipment data for the data bases used to support technical analyses for the purpose of	
	preserving the reliability of the NYS Bulk Power System. –This data reporting	
	procedure shall be conducted at least annually and shall include data	
	submission schedules. report to the NYISO accurate equipment data, including	
	submission schedules, report to the WhSO accurate equipment data, including changes, which affect these data bases. The procedure shall address	
	changes, which affect these data bases. The procedure shall address appropriate time requirements for reporting such data.	
	appropriate time requirements for reporting such data.	
	R.1.2 Require Market Participants and Developers to report accurate and	
	comprehensive equipment data for facilities that are installed or modified	
	outside of the normal reporting process. This procedure shall address	
	appropriate time requirements for reporting such data.	
	R.1.3 Include guidelines for checking the reasonableness of equipment data	
	(<i>load</i> flow, short circuit and <i>stability</i> data) to identify <i>Suspect Data</i> . The	
	guidelines shall specify reasonable data parameters.	
	R.1.4 Require Market Participants and Developers-to report to the NYISO -data	
	errors and corrections or Suspect Data that they may have identified. This	
	procedure shall address appropriate time requirements for reporting such data.	
	R.1.2 Include guidelines for checking the reasonableness of equipment data	Formatted: Font: Not Bold
	(load flow, short circuit and stability data) to identify Suspect Data. The	Formatted: Funt. Nut Bolu
	guidelines shall specify reasonable data parameters.	
	R.1.5_3-Require the NYISO to apply the guidelines in R1.2-34 to data provided to the NYISO.	Formatted: Font: Not Bold
	tie wise.	
	R.1. <u>6</u> _4-Require the <i>NYISO</i> to request verification or corrections of any <i>Suspect</i>	Formatted: Font: Not Bold
	Data from the Market Participant or Developer-that provided the data.	
	R.1.7 Require the NYISO to assess the potential for an adverse material impact	
	of a Market Participant's data error on the reliability of the NYS Bulk Power	
	System if the data error was used in planning or operating studies.	
	For this requirement, adverse material impact is defined as:	
	The NYISO assessment identifies a reliability violation on the NYS Bulk	
	Power System, or the conclusions of a NYISO planning or operating study	
	change as a result of the data error. - after the misreported data was used in planning or operating studies	
	<u>Material Impact is defined as:</u> The NYISO assessment identifies a current system reliability	Formatted: Underline
		Formatted: Underline

I

	The NYISO assessment identified that, within the past year, the system had been operated in an in-secured state.	
	R2 . Load flow, short-circuit, and <i>stability</i> data bases shall be updated by the <i>NYISO</i> on an annual basis or whenever system changes warrant an update, as specified by <i>NYISO</i> procedures required under R1. These data bases shall be made available per <i>NYISO</i> procedures.	
	R3. Market Participants and Developers shall:	
	R.3.1 <u>Review and update load flow, short circuit, and stability data bases as</u> specified by NYISO procedures required by R.1.1.	Formatted: Font: Not Bold
	R.3.2 Report to the NYISO equipment data for equipment additions or modifications in accordance with NYISO procedures required by R.1.2.	Formatted: Indent: Left: 0.24", First line: 0"
	<u>R3.3</u> <u>Report to the NYISO data errors or Suspect Data that are identified in</u>	Formatted: Font: 10 pt
	accordance with NYISO procedures required by R.1.3.	Formatted: Indent: Left: 0.24", First line: 0"
	Provide to the NY/SO accurate <i>load</i> flow, short circuit and stability data in the time frame and format as specified by NY/SO procedures required R1. This data	Formatted: Font: 10 pt
	will be used to maintain up-to-date data bases required under R2.	Formatted: Font: 10 pt
	R.3. <u>4</u> 2 Respond to <i>NYISO</i> requests for data verification or correction of <i>Suspect</i> Data <u>r-equired by R.1.6.</u>	Formatted: Font: Not Bold
	<u>R.3.5</u> <u>Respond to NYISO requests for supplemental data or other information</u> required for its assessment of the material impact of a data error on the reliability of the NYS Bulk Power System after the misreported data was used in planning or operating studies, in accordance with NYISO procedures required by R.1.7.	
	R.3.3 Review and check their equipment data (<i>load</i> flow, short circuit and stability)	Formatted: Indent: Left: -0.01"
	R.3.3 Review and check their equipment data (<i>load</i> flow, short circuit and <i>stability</i> data) within data bases provided by the <i>NYISO</i> to ensure accuracy.	Formatted: Indent: Left: -0.01", First line: 0"
8. Section C – Compliance Elements		
1. Measures	M1: Replace the present M1 with the following: The NYISO provided evidence that it has established and maintained procedures for	Formatted: Font: Not Bold
	the development and maintenance of load flow, short circuit, and stability data in	Formatted: Font: Not Bold
	accordance with R1, including the procedures and actions specified in R1.1 through R1.7.	Formatted: Fullt. Nut Bolu
	M2: Load flow, short-circuit, and stability data bases were updated as specified by NYISO procedures and schedules, in accordance with R2.	Formatted: Left
	M3: Replace the present M3 with the following: The NYISO certified that every Market Participant, as appropriate, provided evidence that it reviewed, updated, and reported load flow, short circuit, and stability data bases in accordance with R3.1; reported equipment data to the NYISO	

	in accordance with R3.2; and reported data errors, Suspect Data, and information	
2 Lougla of Non-Compliance	requested by the NYISO, in accordance with R3.3, R.3.4, and R3.5.	
2. Levels of Non-Compliance	For Measure 1	
	Level 1: Not applicable.	
	Level 2: NYISO procedures for development and maintenance of load flow, sho circuit, and <i>stability</i> data bases have been prepared, but we incomplete in one or more areas <u>identified in R1.1 through R1.7.</u>	
	Level 3: It was determined that the NYISO did not adequately apply guidelines for identifying Suspect Data in accordance with R1.5 certain data provided by Market Participants and Developers after review of equipment data used in a planning or operating stuindicated that the data fell outside the range of reasonable data parameters.	for r a udy
	Level 4: NYISO procedures for development and maintenance of load flow, sho circuit, and stability data bases have not been prepared in accordar with R1.1 through R1.7, or the NYISO didhas not prepared guidelines identifying Suspect Data.	nce
	For Measure 2	
	Level 1: Not applicable.	
	Level 2: <u>NYISO El</u> oad flow, short-circuit, or <i>stability</i> data bases were not updat as specified by <i>NYISO</i> procedures and schedules <u>and in accordance w</u> <u>R2</u> .	/ith
	Level 3: Not applicable.	Formatted: Justified, Indent: Left: 0"
	Level 4: <u>NYISONone of the</u> load flow, short-circuit, and <i>stability</i> data bases we not updated as specified by <i>NYISO</i> procedures and schedules and R2.	ere
	For Measure 3	
	Level 1: The NYISO certified that the required data, in accordance with R3.1 a R3.2, that was provided was complete, but was not submitted to the NYISO by the specified time by one or more—designated Mark Participants and Developers.	the
	Level 2: The NYISO certified that the required data, <u>in accordance with R3.1 a</u> <u>R3.2</u> was submitted_to the NYISO on time, but was incomplete in one more areas for one or more— <u>designated</u> Market Participants—a Developers.	e or
	Level 3: The NYISO certified that one or more Market Participants and Developers did not check the accuracy of its data, did not report data errors or Suspect Data to the NYISO, or did not respond to the NYISO fr	Formatted: Left
	requests for data verification or correction of <u>data errors or Suspect</u>	
	Data, In accordance with R3.3 through R3.5.	Formatted: Font: Not Italic
	- <u>OR -</u>	Formatted: Indent: Left: 1.13"
	The NYISO certified that an error, found in data submitted by one or	Formatted: Indent: Left: 0", Hanging: 0.61"

	 Compliance Monitoring Process (See Policy 4): 3.1 Compliance 	more Market Participants, had the potential of having an adverse material impact on the reliability of the NYS Bulk Power System if the data had been used in a planning or operating study. Level 4: The NYISO certified that the required data, in accordance with R3.1 and R3.2, from one or more-designated Market Participants, and Developers was not submitted to the NYISO. M1: BCMS	
	Monitoring Responsibility	M2: RCMS M3: NYISO/RCMS	
	3.2 Reporting Frequency	M1: In accordance with NYSRC Compliance Monitoring Program schedule. M2: In accordance with NYSRC Compliance Monitoring Program schedule. M3: Annually	
	3.3 Compliance Reporting Requirements	_M1: NYISO Self-Certification. M2: NYISO Self-Certification. M3: NYISO Certification of Market Participant compliance.	Formatted: Don't add space between paragraphs of
I	9. Implementation Plan	1. Three months following Executive Committee adoption of PRR 132, the NYISO	the same style, Line spacing: Multiple 1.15 li, No widow/orphan control
		 shall provide evidence to RCMS that it modified its procedures in accordance with revised Reliability Rule I.4 requirements. Four months following Executive Committee adoption of PRR 132, NYISO staff shall make a presentation to RCMS describing the methodology it proposes to use for assessing whether a data error would have the potential for causing an adverse material impact on the reliability of the NYS BPS, as required by R1.7. 	
	10. Comments		
	11. Date Rule Adopted	4	Formatted Table
	12. PRR Revision Dates	2/23/16, 2/24/16, 3/24/16, 4/18/16, 5/15/16	