

Request to Develop or Modify Reliability Rules and Requirements (NYSRC Policy No. 1)

Submit request to herb@policyadvisorsllc.com via the NYSRC site www.nysrc.org

Item	Information
1. PRR No. & Title of Reliability Rule or Requirement change	PRR-144### C.3: Outage Coordination - Requirement 4 and Requirement 6
2. Rule Change Requester Information	
Name	James Grant
Organization	NYISO
3. New rule or revision to existing rule?	Existing
4. Need for rule change, including advantages and disadvantages	The intent of existing R4 is for scheduled maintenance outage of facilities to be completed expeditiously in the event of an emergency. However, the NYISO cannot attest as to whether or not a facility owner has acted expeditiously in restoring an outage. The intent of existing R4 will be incorporated into the procedures stipulated in existing R6 of this Rule, so that facility owners are aware of their obligation to restore maintenance outages expeditiously in the case of an emergency. Existing R4 will be retired, and subsequent Requirements will be renumbered.
5. Related NYSRC rules	C.3 Requirements R2, R3, and R5.
6. Section A – Reliability Rule Elements	
1. Reliability Rule	C.3: Outage Coordination
2. Associated NERC & NPCC Standards and Criteria	NERC: IRO-014, IRO-017 NPCC: Directory 1
3. Applicability	NYISO
7. Section B – Requirements	

Formatted Table

Requirements	<p>R4. Maintenance of facilities which impact the reliability of the NYS Bulk Power System shall be expedited.</p> <p>R5R4. Appropriate adjustments shall be made to NYCA operations to accommodate the impact of <i>protection group</i> outages.</p> <p>R5R4.1. For typical periods of forced or maintenance outage of a <i>protection group</i>, it can be assumed, unless there are indications to the contrary, that the remaining <i>protection</i> will function as designed.</p> <p>R5R4.2 If the <i>protection group</i> will be out of service for an extended period of time (as defined in NPCC criteria), additional adjustments to operations may be appropriate considering other system conditions and the consequences of possible failure of a remaining <i>protection group</i>.</p> <p>R6R5. The NYISO shall maintain procedures and systems which ensure that outages of transmission facilities are coordinated in such a manner to ensure <i>reliability</i>. <u>The procedures shall include a requirement that Transmission Owners expedite, to the extent practicable, maintenance of facilities which impact the reliability of the power system.</u> The NYISO must notify the NYSRC of any changes to these procedures and systems.</p>
8. Section C – Compliance Elements	
1. Measures	M1
2. Levels of Non-Compliance	No change from existing
3. Compliance Monitoring Process (See Policy 4):	No change from existing
3.1 Compliance Monitoring Responsibility	No change from existing
3.2 Reporting Frequency	No change from existing
3.3 Compliance Reporting Requirements	No change from existing
9. Implementation Plan	The NYISO shall revise the Outage Scheduling Manual to explicitly include the intent in the new Requirement 6 that obligates facility owners to expedite maintenance outage restoration in the event of an emergency.
10. Comments	
11. Date Rule Adopted	
12. PRR Revision Dates	

DRAFT

