

NEW YORK STATE RELIABILITY COUNCIL
RCMS Status Report for EC #203 - Friday, March 11, 2016
RCMS #193 Status Report - Thursday, March 3, 2016

- 2015 Reliability Compliance Program Highlights
 - RCMS approved for EC review
- 2016 Reliability Compliance Program
 - A.1 (R1, R2) IRM study & report
 - RCMS determined NYISO in full compliance
 - C.8 (R1) Real time operations of NYS BPS
 - RCMS determined NYISO in full compliance for January, 2016
 - G.4 (R2) ConEd identification of eligible BS resources
 - RCMS compliance review delayed pending completion of physical installation of BS equipment
- Reliability Rule H.1 - Control Center Communications
 - NYISO/MP loss of communications incident 1/28/16 (R1)
 - NYISO provided written report within 30 days of incident (R.4)
 - RCMS determined NYISO in full compliance & no further action was recommended
- Reliability Rule D.1 - Mitigation of Major Emergencies
 - High voltage incidents on CE interface 2/3/16 & 2/15/16
 - NYISO provided preliminary reports (R.9)
 - RCMS determined NYISO in full compliance & no further action was recommended