

Request to Develop Reliability Rules for Implementation of Rules Enhancement Plan (REP)

Item	Response
1. Rules Enhancement Plan (REP) Description	On April 11, 2013, the NYSRC Executive Committee adopted a Rules Enhancement Plan (REP) which: (1) restructures the present NYSRC Reliability Rules and supporting elements, and (2) proposes new rules and revises others to ensure they are consistent with current and pending NERC and NPCC standards and criteria, while continuing to maintain NYSRC's more stringent and specific requirements. Proposed new and revised rules are highlighted below in red-line. The REP is described in the report, <i>Rules Enhancement Plan</i> , www.nysrc.org/ , which describes the restructured rule format (PRR Lines 3-7) and the tasks for implementing the REP.
2. Reliability Rule Requester	NYSRC Reliability Rules Subcommittee (RRS)
3. REP Proposed Reliability Rule (PRR) No.	REP-14
4. Title & No. of Proposed Reliability Rule	A-R3: Review of Resource Adequacy
5. Section A – Reliability Rule Elements	
1. Reliability Rule	<u>The adequacy of planned NYCA resources shall be assessed to demonstrate conformance with NYSRC resource adequacy requirements.</u>
2. Associated NERC & NPCC Standards and Criteria	NPCC: Directory 1 NERC: None
3. Applicability	NYISO
6. Section B – Requirements	
Requirements	<p>K-M2b: A NYCA resource adequacy assessment for the next summer period and two years beyond, for demonstrating next capability period compliance with the NYSRC IRM requirement and NYISO locational ICAP requirements, and prospective future compliance. The assessment shall include statewide and New York City and Long Island resource adequacy.</p> <p><u>R1. An NYCA resource adequacy assessment shall be conducted annually for the next summer period and two years beyond, for demonstrating that proposed NYCA resources meet NYCA statewide IRM and New York City and Long Island locational capacity requirements as determined by NYSRC and NYISO studies conducted in accordance with A-R1 and A-R2. The assessment shall be documented in a resource adequacy report, covering at a minimum, the evaluations and information below:</u></p> <p style="padding-left: 40px;"><u>R1.1 The assessment shall evaluate a base case assuming proposed resources and the most likely load forecast, as well as alternate scenarios approved by RCMS.</u></p> <p style="padding-left: 40px;"><u>R1.2 Any potential base case resource adequacy needs shall be addressed by NYISO procedures. The NYISO shall report to the NYSRC on identified needs and possible corrective actions consistent with NYISO procedures.</u></p> <p style="padding-left: 40px;"><u>R1.3 The resource adequacy report shall include key assumptions and other factors considered in the assessment.</u></p>
7. Section C – Compliance Elements	

Formatted: Space After: 10 pt

Formatted Table

Formatted: Font: Not Bold

Formatted: Font: 10 pt, Not Bold

Formatted Table

Formatted: Font: 10 pt, Not Bold

Formatted: Font: 10 pt, Not Bold

Formatted: Font: 10 pt

Formatted: Font: 10 pt

Formatted: No bullets or numbering

Formatted: Font: 10 pt

Formatted: Font: 10 pt

Formatted: Font: 10 pt

Formatted: Font: 10 pt

Formatted: Font: 10 pt

Formatted: Indent: Left: 0"

Formatted: Indent: Left: 0.5"

1. Measures	<p>M1:</p> <p>The NYISO submitted the annual NYCA resource adequacy assessment report to the NYSRC in accordance with R1 requirements, Measurement K-M2.b. During a year when the NYISO was required by NPCC to submit a New York Area Resource Adequacy Study, submission of that report to the NYSRC for compliance review would meet this requirement.</p>
2. Levels of Non-Compliance	<p>For M1:</p> <p><u>Level 1:</u> Not applicable.</p> <p><u>Level 2:</u> A NYCA resource adequacy assessment was submitted to the NYSRC, but the report was deficient in one or more areas.</p> <p><u>Level 3:</u> Not applicable. The NYISO failed to report to the NYSRC in a reasonable time on possible corrective actions after potential base case resource adequacy needs were identified.</p> <p><u>Level 4:</u> A NYCA resource adequacy assessment was not submitted to the NYSRC.</p>
3. Compliance Monitoring Process (See Policy 4):	
3.1 Compliance Monitoring Responsibility	RCMS
3.2 Reporting Frequency	Annually
3.3 Compliance Reporting Requirements	Complete documentation
8. Comments	This rule has been relocated from Rule Group K – Reliability Assessment (K-M2b) to Rule Group A – Resource Adequacy.
9. Date Reliability Rule Adopted	
10. REP PRR Revision Dates	5/22/14, 7/16/14

Formatted: Font color: Red