

NEW YORK STATE RELIABILITY COUNCIL
RRS #207 Status Report for EC #211 - Thursday, November 10, 2016

- **PRRs under development**
 - PRR 128 - Definition of Bulk Power System
 - NPCC A-10 with ConEd radial exclusion proposal in review
 - Tabled pending NPCC A-10 review by TFCP/TFSS
- **PRRs for Posting**
 - PRR 135 - G.4 (R1, R2) System restoration from eligible black start resources
 - RRS developing clarification of relevant system conditions
 - RRS recommends EC approval to post for comments
- **PRRs for Final Approval**
 - PRR 131C - G.2 Loss of Gas - New York City
 - NYC dual fuel generator capability year testing requirements
 - RRS agreed to limit scope of testing to Zone J combined-cycle LOG/MOB units
 - PRR 131C posted for comment. NYPA & IPPNY submitted comments.
 - With due regard to posted comments, RRS recommends EC final approval of PRR 131C as posted (NYPA voted against)
 - PRR 133 - F System Restoration
 - Conformance with NERC's SRP Training and Black Start testing requirements
 - PRR 133 posted for comment. NYISO submitted comments.
 - With due regard to posted comments, RRS recommends EC final approval of PRR 133 as posted
 - PRR 134 - I.5 Disturbance Recording
 - RRS developing new rule to retire I.5
 - PRR 134 posted for comment. No comments received.
 - RRS recommends EC final approval of PRR 134 as posted