

NEW YORK STATE RELIABILITY COUNCIL
RRS #225 Status Report for EC #229 - Friday May 11, 2018

- **PRRs under development**
 - PRR 128 - Definition of Bulk Power System
 - Discussed treatment of radial elements
 - **Action:** Tabled pending NPCC A-10 revision
- **PRRs Posted for Comment**
 - None
- **PRRs for Final Approval**
 - PRR 140 – A.1 (R1) Establishing NYCA IRM Requirements
 - Clarification for consistency with NPCC Directory 1
 - No comments received from posting
 - **Action:** RRS recommends final EC approval
 - PRR 141 – A.2 (R1, R2) Establishing LSE ICAP Requirements
 - Clarification
 - No comments received from posting
 - **Action:** RRS recommends final EC approval
- **PRRs for Discussion**
 - No further action by RRS on ConEd proposal to require GSU LTCs to optimize dynamic reactive resources. ConEd has adopted a GSU LTC requirement in its own Transmission Planning Criteria for new interconnections.
 - Continuing discussion NPCC’s response to NYSRC’s request for clarification on open breaker N-1/-1 criterion. NPCC comments due by 5/4/18:
 - IESO – No comments
 - VELCO – Agrees with NPCC responseRRS reviewing need for more stringent NYSRC rule.
 - Discussion on need to clarify NYSRC RR E.1 (R3.1) – “Establishing the Minimum Level of Operating Reserve” to conform with NYISO’s “Proposed Tariff Revisions Addressing Provision of Synchronized Reserves by Inverter-Based Energy Storage Resources; Docket No. ER18-__-000”, 3/29/18. RRS requested NYISO provide technical information on the equivalency of inverter based resources as *synchronized resource capacity* and status of FERC approval.

- **Other RRS Matters**

- Discussion of NYISO written report on 3/8/18 & 3/14/18 declarations of Major Emergency for Central-East interface limit exceedance. RRS approved report.
- Continuing discussion of proposed workshop on DER impact on NYCA reliability