

**NEW YORK STATE RELIABILITY COUNCIL**  
**RRS #226 Status Report for EC #230 - Friday June 8, 2018**

- **PRRs under development**
  - PRR 128 - Definition of Bulk Power System
    - Discussed treatment of radial elements
    - **Action:** Tabled pending NPCC A-10 revision
- **PRRs Posted for Comment**
  - None
- **PRRs for Final Approval**
  - None
- **PRRs for Discussion**
  - EC approved PRRs 140 & 141 to be included in upcoming revision to RR&C Manual.
  - On 5/30/18 NPCC RCC approved NPCC's response to NYSRC's request for clarification on open breaker N-1-1 criterion. RRS did not see need for more stringent NYSRC rule. No further action.
  - Tabled discussion until RRS 227 on need to clarify NYSRC RR E.1 (R3.1) – “Establishing the Minimum Level of Operating Reserve” to conform with NYISO's “Proposed Tariff Revisions Addressing Provision of Synchronized Reserves by Inverter-Based Energy Storage Resources; Docket No. ER18-\_\_-000”, 3/29/18. RRS requested NYISO provide technical information on the equivalency of inverter based resources as *synchronized resource capacity* and status of FERC approval.
- **Other RRS Matters**
  - Continuing discussion of proposed workshop on DER impact on NYCA reliability
    - DER Workshop Scope\_Rev3
    - DPS SIR PV inventory list
    - NPCC RCC May 30 2018 Agenda Item 6-5-3 "DER Planning Practices"
    - A regional first: New Englanders used less grid electricity midday than while they were sleeping on April 21
  - Posting of Revised NPCC Directory Development and Revision Manual