

2020 NYSRC Long-Term Resource Adequacy Assessments

Laura Popa


Manager, Resource Planning

NYSRC RCMS

February 4, 2021

Goal

- **This presentation summarizes the 2020 NYSRC Long-Term Resource Adequacy Assessments (LTRAAs) Report in support of the NYSRC certification**
- **LTRAA report information is based on NYISO's:**
 - 2020 RNA Base Case and scenarios results
 - 2020 Q3 STAR results



2020 LTRAA Background

- **The New York State Reliability Council's (NYSRC) Reliability Rule A.3. B. R2 requires the NYISO to prepare a biennial NYCA Long-Term Resource Adequacy Assessment (LTRAA) covering a ten-year look-ahead period**
 - New requirement in the NYSRC Reliability Rules, starting with the July 17, 2020 version #45: <http://www.nysrc.org/NYSRCReliabilityRulesComplianceMonitoring.html>
- **This assessment is designed to include findings from the latest NYISO Reliability Needs Assessment (RNA) or other comparable NYISO-approved resource adequacy reviews, such as the newly-defined Short-Term Reliability Process (STRP) and its quarterly Short-Term Assessment of Reliability (STAR)**
- **The 2020 LTRAA review report uses the information from the 2020 RNA for Study Years 2024 through 2030 (year 4 through year 10), and from the 2020 Q3 STAR for the 2021 through 2025 (with a focus on years 1 through year 3)**
- **The NYISO provides the 2020 LTRAA report summarizing these assessments to the NYSRC to fulfill the requirement**

2020 RNA Base Case Major Assumptions

2020 RNA: Summer Peak Load and Energy Forecast Assumptions

Baseline and Adjusted Baseline Energy Forecasts

| Annual GWh | 2020 | 2021 | 2022 | 2023 | 2024 | 2025 | 2026 | 2027 | 2028 | 2029 | 2030 |
|--|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|
| 2020 End-Use Energy Forecast | 154,380 | 158,431 | 161,852 | 162,477 | 163,897 | 165,132 | 166,331 | 167,305 | 168,188 | 168,789 | 169,249 |
| – Energy Efficiency and Codes & Standards | 1,885 | 3,959 | 6,200 | 8,599 | 11,081 | 13,582 | 15,937 | 18,057 | 19,921 | 21,563 | 23,016 |
| – BtM Solar PV | 2,631 | 3,274 | 3,899 | 4,563 | 5,193 | 5,738 | 6,205 | 6,591 | 6,893 | 7,130 | 7,289 |
| – BtM Non-Solar Distributed Generation | 1,252 | 1,416 | 1,059 | 940 | 818 | 852 | 877 | 900 | 931 | 956 | 973 |
| + Storage Net Energy Consumption | 19 | 43 | 67 | 99 | 130 | 160 | 189 | 221 | 254 | 281 | 309 |
| + Electric Vehicle Energy | 199 | 345 | 538 | 781 | 1,085 | 1,456 | 1,889 | 2,407 | 3,031 | 3,765 | 4,506 |
| + Non-EV Electrification | 190 | 457 | 815 | 1,289 | 1,884 | 2,591 | 3,337 | 4,163 | 5,055 | 5,997 | 6,988 |
| 2020 Gold Book Baseline Forecast | 149,020 | 150,627 | 152,114 | 150,544 | 149,904 | 149,167 | 148,727 | 148,548 | 148,783 | 149,183 | 149,774 |
| + BtM Solar PV | 2,631 | 3,274 | 3,899 | 4,563 | 5,193 | 5,738 | 6,205 | 6,591 | 6,893 | 7,130 | 7,289 |
| 2020 RNA Base Case Forecast¹ | 151,651 | 153,901 | 156,013 | 155,107 | 155,097 | 154,905 | 154,932 | 155,139 | 155,676 | 156,313 | 157,063 |

Baseline and Adjusted Baseline Summer Peak Forecasts

| Annual MW | 2020 | 2021 | 2022 | 2023 | 2024 | 2025 | 2026 | 2027 | 2028 | 2029 | 2030 |
|---|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| 2020 End-Use Peak Demand Forecast | 33,319 | 33,599 | 33,978 | 34,220 | 34,555 | 34,861 | 35,208 | 35,524 | 35,848 | 36,108 | 36,324 |
| – Energy Efficiency and Codes & Standards | 296 | 591 | 943 | 1,322 | 1,709 | 2,108 | 2,488 | 2,825 | 3,116 | 3,360 | 3,579 |
| – BtM Solar PV | 555 | 707 | 841 | 986 | 1,102 | 1,204 | 1,287 | 1,351 | 1,392 | 1,411 | 1,411 |
| – BtM Non-Solar Distributed Generation | 218 | 251 | 189 | 169 | 148 | 154 | 158 | 164 | 170 | 174 | 177 |
| – BtM Storage Peak Reductions | 5 | 14 | 26 | 44 | 63 | 91 | 125 | 159 | 206 | 250 | 292 |
| + Electric Vehicle Peak Demand | 40 | 68 | 103 | 147 | 201 | 261 | 333 | 418 | 513 | 625 | 748 |
| + Non-EV Electrification | 11 | 25 | 46 | 72 | 104 | 146 | 187 | 230 | 279 | 327 | 379 |
| 2020 Gold Book Baseline Forecast² | 32,296 | 32,129 | 32,128 | 31,918 | 31,838 | 31,711 | 31,670 | 31,673 | 31,756 | 31,865 | 31,992 |
| + BtM Solar PV | 555 | 707 | 841 | 986 | 1,102 | 1,204 | 1,287 | 1,351 | 1,392 | 1,411 | 1,411 |
| 2020 RNA Base Case Forecast¹ | 32,851 | 32,836 | 32,969 | 32,904 | 32,940 | 32,915 | 32,957 | 33,024 | 33,148 | 33,276 | 33,403 |

¹ For the resource adequacy study, the Gold Book baseline load forecast was modified by removing the behind-the-meter solar PV impacts in order to model the solar PV explicitly as a generation resource to account for the intermittent nature of its availability.

² The transmission security power flow RNA base cases use this Gold Book baseline forecast.

2020 RNA: Inclusion Rules Application

- **Proposed generation and transmission to be included:**
 - Next slide contains a list of added projects
- **Generation deactivations: all plant deactivations listed in the 2020 Gold Book Section IV are modeled out of service in the RNA Base Case**
 - Certain peaker units listed in Table IV-6 are assumed out-of-service during summer ozone season only (additional details in this presentation)
- **Proposed Local Transmission Owner Plans (LTP) to be included:**
 - All BPTF LTPs listed in the 2020 GB Section VII as firm, with consideration for the in-service date
 - All non-BPTF LTPs listed by the Transmission Owner as firm
- **Existing transmission facilities modeled out-of-service include:**
 - Con Edison's B3402 and C3403 345 kV cables for the entire study period

Proposed Generation and Transmission Projects

Proposed Projects Included in the 2020 RNA Base Case

| Queue # | Project Name | Zone | Point of Interconnection | Summer Peak (MW) | 2020 RNA Commercial Operation Date |
|---|--|------|-----------------------------------|------------------|------------------------------------|
| Proposed Transmission Additions, other than Local Transmission Owner Plans | | | | | |
| Q545A* | Empire State Line | A | Dysinger - Stolle 345kV | n/a | 6/2022 |
| 556 | Segment A Double Circuit | E,F | Edic - New Scotland 345kV | n/a | 12/2023 |
| 543 | Segment B Knickerbocker-Pleasant Valley 345 kV | F,G | Greenbush - Pleasant Valley 345kV | n/a | 12/2023 |
| 430 | Cedar Rapids Transmission Upgrade | D | Dennison - Alcoa 115kV | 80 | 10/2021 |
| System Deliverability Upgrades* | Leeds-Hurley SDU | F,G | Leeds- Hurley SDU 345kV | n/a | summer 2021 |
| Proposed Generations Additions | | | | | |
| 387* | Cassadaga Wind | A | Dunkirk - Moon Station 115 kV | 126.5 | 12/2021 |
| 396 | Baron Winds | C | Hillside - Meyer 230kV | 238.4 | 12/2021 |
| 422 | Eight Point Wind Energy Center | B | Bennett 115kV | 101.8 | 12/2021 |
| 505 | Ball Hill Wind | A | Dunkirk - Gardenville 230kV | 100.0 | 12/2022 |
| 546 | Roaring Brook Wind | E | Chases Lake Substation 230kV | 79.7 | 12/2021 |
| 678 | Calverton Solar Energy Center | K | Edwards Substation 138kV | 22.9 | 12/2021 |
| MW Additions from 2019-2028 CRP | | | | 543 | |
| Total MW generation additions | | | | 669 | |
| *also included in the 2019-2028 CRP Base Cases | | | | | |

DEC Peaker Rule Impacts on the 2020 RNA Base Case

DEC Peaker Rule Background

- New York State Department of Environmental Conservation (DEC) adopted a regulation to limit nitrogen oxides (NO_x) emissions from simple-cycle combustion turbines (“Peaking Units”) (referred to as the “Peaker Rule”)
- The Peaker Rule required all impacted plant owners to file compliance plans by March 2, 2020
- NYISO considered generators’ compliance plans in the development of the 2020 Reliability Needs Assessment Base Case
- The following slides show zonal breakdown of the same related information from slide 16 (*i.e.* 2020 GB Table iV-6)

Status Change due to DEC Peaker Rule, Zone G

| Units | Nameplate MW | CRIS (MW) | | Capability (MW) | | 2023 Ozone Season | 2023 non-Ozone Season | 2024 Ozone Season | 2024 non-Ozone Season | 2025 Ozone Season | 2025 non-Ozone Season |
|-------------------------------------|--------------|-----------|--------|-----------------|--------|---------------------------|---------------------------|---------------------------|---------------------------|---------------------------|---------------------------|
| | | Summer | Winter | Summer | Winter | May 2023 - September 2023 | October 2023 - April 2024 | May 2024 - September 2024 | October 2024 - April 2025 | May 2025 - September 2025 | October 2025 - April 2026 |
| Coxsackie GT | 22 | 20 | 26 | 20 | 24 | O/S | O/S | O/S | O/S | O/S | O/S |
| South Cairo | 22 | 20 | 26 | 18 | 23 | O/S | O/S | O/S | O/S | O/S | O/S |
| <i>Unavailable MW = Impacted MW</i> | 43 | 40 | 52 | 38 | 46 | | | | | | |
| O/S - Out-of-service | | | | | | | | | | | |

- Notes:
1. The service pattern in the last two columns repeats in subsequent years of the RNA Study Period
 2. Other compliance plans were submitted in addition to what is shown on this table. The table lists the plants with compliance plans that resulted in a change of status (*i.e.*, as also listed in the 2020 Gold Book Table iV-6)

Status Change due to DEC Peaker Rule, Zone J

| Units | Nameplate MW | CRIS (MW) | | Capability (MW) | | 2023 Ozone Season | 2023 non-Ozone Season | 2024 Ozone Season | 2024 non-Ozone Season | 2025 Ozone Season | 2025 non-Ozone Season |
|---|--------------|-----------|--------|-----------------|--------|---------------------------|---------------------------|---------------------------|---------------------------|---------------------------|---------------------------|
| | | Summer | Winter | Summer | Winter | May 2023 - September 2023 | October 2023 - April 2024 | May 2024 - September 2024 | October 2024 - April 2025 | May 2025 - September 2025 | October 2025 - April 2026 |
| | | | | | | | | | | | |
| Astoria GT1 | 16 | 16 | 21 | 14 | 19 | I/S | I/S | I/S | I/S | O/S | I/S |
| Gowanus 1&4 (1-1 through 1-8, and 4-1 through 4-4) | 320 | 279 | 364 | 274 | 365 | O/S | I/S | O/S | I/S | O/S | I/S |
| Gowanus 2&3 (2-1 through 2-8 and 3-1 through 3-8) | 320 | 300 | 391 | 278 | 373 | I/S | I/S | I/S | I/S | O/S | I/S |
| Narrows 1&2 (1-1 through 1-8, and 2-1 through 2-8) | 352 | 309 | 404 | 287 | 380 | I/S | I/S | I/S | I/S | O/S | I/S |
| Ravenswood GTs (01, 10, 11) | 69 | 50 | 64 | 41 | 57 | O/S | O/S | O/S | O/S | O/S | O/S |
| Arthur Kill GT1 | 20 | 17 | 22 | 12 | 15 | I/S | I/S | I/S | I/S | O/S | O/S |
| Astoria GTs (2-1 through 2-4, 3-1 through 3-4, 4-1 through 4-4) | 558 | 504 | 621 | 415 | 543 | O/S | O/S | O/S | O/S | O/S | O/S |
| Con Ed 59th St | 17 | 15 | 20 | 16 | 20 | I/S | I/S | I/S | I/S | O/S | O/S |
| Con Ed 74th St | 37 | 39 | 49 | 35 | 41 | O/S | O/S | O/S | O/S | O/S | O/S |
| Con Ed Hudson Ave 5 | 16 | 15 | 20 | 14 | 20 | O/S | O/S | O/S | O/S | O/S | O/S |
| Unavailable MW (Summer Capability) | | | | | | 779 | 506 | 779 | 506 | 1,385 | 533 |
| Available MW (Summer Capability) | | | | | | 606 | 880 | 606 | 880 | 0 | 852 |
| Impacted MW | 1,725 | 1,544 | 1,975 | 1,385 | 1,834 | | | | | | |

O/S - Out-of-service

I/S - In-service

Notes:

1. The service pattern in the last two columns repeats in subsequent years of the RNA Study Period
2. Other compliance plans were submitted in addition to what is shown on this table. The table lists the plants with compliance plans that resulted in a change of status (*i.e.*, as also listed in the 2020 Gold Book Table iv-6)

Status Change due to DEC Peaker Rule, Zone K

| Units | Nameplate MW | CRIS (MW) | | Capability (MW) | | 2023 Ozone Season | 2023 non-Ozone Season | 2024 Ozone Season | 2024 non-Ozone Season | 2025 Ozone Season | 2025 non-Ozone Season |
|-------------------------------------|--------------|-----------|--------|-----------------|--------|---------------------------|---------------------------|---------------------------|---------------------------|---------------------------|---------------------------|
| | | Summer | Winter | Summer | Winter | May 2023 - September 2023 | October 2023 - April 2024 | May 2024 - September 2024 | October 2024 - April 2025 | May 2025 - September 2025 | October 2025 - April 2026 |
| Glenwood GT1 | 16 | 14.6 | 19.1 | 11.4 | 14.5 | O/S | O/S | O/S | O/S | O/S | O/S |
| Northport GT | 16 | 13.8 | 18.0 | 11.7 | 15.1 | O/S | O/S | O/S | O/S | O/S | O/S |
| Port Jefferson GT1 | 16 | 14.1 | 18.4 | 12.9 | 16.6 | O/S | O/S | O/S | O/S | O/S | O/S |
| <i>Unavailable MW = Impacted MW</i> | 48 | 42.5 | 55.5 | 36.0 | 46.2 | | | | | | |
| O/S - Out-of-service | | | | | | | | | | | |
| I/S - In-service | | | | | | | | | | | |

Notes:

1. The service pattern in the last two columns repeats in subsequent years of the RNA Study Period
2. Other compliance plans were submitted in addition to what is shown on this table. The table lists the plants with compliance plans that resulted in a change of status (*i.e.*, as also listed in the 2020 Gold Book Table iV-6)

Resource Adequacy RNA Results

2020 RNA: LOLE Results

| Study Year | NYCA Baseline Summer Peak Load (MW) | Area J Peak Load (MW) (Non-coincident) | RNA Base Case NYCA LOLE (days/year) |
|------------|-------------------------------------|--|-------------------------------------|
| 2024 | 31,838 | 11,557 | 0.04 |
| 2025 | 31,711 | 11,552 | 0.08 |
| 2026 | 31,670 | 11,609 | 0.10 |
| 2027 | 31,673 | 11,667 | 0.12 |
| 2028 | 31,756 | 11,747 | 0.13 |
| 2029 | 31,865 | 11,836 | 0.17 |
| 2030 | 31,992 | 11,924 | 0.19 |

- 2026: LOLE at 0.10 (0.097) d/y is at criterion
- 2027: Criterion violation (*i.e.*, LOLE>0.1 days/year) observed through 2030
- Removal of Area J peakers drives the increase in LOLE
 - removed approximately 1,400 MW by 2025
- The LOLE increase from 2026 to 2030 is due to load growth

Note: The first Short-Term Assessment of Reliability (STAR) started on July 15, 2020. Its Study Period encompasses year 1 through year 5 following the STAR starting date. The study assumptions and results related with the STAR Study Period will be updated, as applicable at the time.

Compensatory MW Concept for Resource Adequacy

- **Resource adequacy compensatory megawatt amounts are determined by adding generic “perfect capacity” resources to zones (or combination of zones) to address the shortfall**
 - “Perfect capacity” is capacity that is not derated (e.g., due to ambient temperature or unit unavailability caused by factors such as equipment failures or lack of “fuel”), not subject to energy duration limitations, and not tested for transmission security or interface impacts. Actual resources would need to be larger in order to achieve the same impact as perfect-capacity resources.
- **The compensatory MW additions are not intended to represent specific solutions, as the impact of specific solutions can depend on the type of the solution and its location on the grid**
- **Resource needs could potentially be met by combinations of solutions including generation, transmission, energy efficiency, and demand response measures**
- **No transmission constraints within Zones J or K are modeled in MARS**

Individual Zonal Compensatory MW

| Study Year | NYCA LOLE (dy/yr) | Zones for Additions | | | |
|------------|-------------------|---------------------|--------------|-----------|--------------|
| | | Only in A-F | Only in G-I | Only in J | Only in K |
| 2024 | 0.04 | - | - | - | - |
| 2025 | 0.09 | - | - | - | - |
| 2026 | 0.10 | - | - | - | - |
| 2027 | 0.12 | 700 | 700 | 100 | not feasible |
| 2028 | 0.14 | 1,600 | 1,650 | 150 | not feasible |
| 2029 | 0.17 | not feasible | not feasible | 300 | not feasible |
| 2030 | 0.19 | not feasible | not feasible | 350 | not feasible |

Notes:

(+) positive values are for those study years with NYCA LOLE above the criterion, and the values represent the MW that can be added to each zone to restore the NYCA LOLE to 0.1 days/year

“Not feasible” - Either a large, or no amount of capacity added in the zone can bring NYCA LOLE below 0.1

RNA Resource Adequacy Observations

- Adequate compensatory MW must be located within, or injected into, Zone J because of transmission constraints into Zone J observed starting in 2029. This result is exemplified by the fact that no compensatory MW in any of the other NYCA zones will help bring the LOLE back below 0.1 days/year.
- Potential solutions to address the 350 compensatory MW resource adequacy deficiency in Zone J by 2030 (100 MW in 2027) could include a combination of additional transfer capability into Zone J and/or resources located within Zone J, and/or demand-side solutions. However, solutions would also need to address the Zone J local transmission load area deficiencies identified in the transmission security evaluations.
- Note: No local transmission load area limits are modeled for the resource adequacy assessment – deficiencies at this local level are identified in the transmission security assessments.

2020 RNA Scenarios Based on the RNA Base Cases

RNA Scenarios based on Base Cases

- RNA scenarios are provided for information only, and do not lead to Reliability Needs identification or mitigation
- The NYISO evaluated the following scenarios as part of the RNA:
 - High Load Forecast Scenario – Resource Adequacy
 - The 2020 Gold Book High Load forecast were used for the resource adequacy analysis.
 - Zonal Resource Adequacy Margins (ZRAM) - Resource Adequacy
 - Identification of the maximum level of zonal MW capacity that can be removed without either causing NYCA LOLE violations, or exceeding the zonal capacity.
 - “Status-quo” Scenario - Transmission Security and Resource Adequacy
 - Removal of proposed major transmission and generation projects assumed in the RNA Base Case.

High Load Scenario

2020 Gold Book NYCA High Load vs. Baseline Summer Peak Forecast

| Year | High Load | Baseline Load | Delta (High Load - Baseline Load) |
|------|-----------|---------------|---|
| 2024 | 32,623 | 31,838 | 785 |
| 2025 | 32,641 | 31,711 | 930 |
| 2026 | 32,863 | 31,670 | 1,193 |
| 2027 | 33,163 | 31,673 | 1,490 |
| 2028 | 33,562 | 31,756 | 1,806 |
| 2029 | 33,976 | 31,865 | 2,111 |
| 2030 | 34,380 | 31,992 | 2,388 |

2020 Gold Book Zone J High Load vs. Non-coincident Summer Peak Forecast

| Year | High Load | Baseline Load | Delta (High Load - Baseline Load) |
|------|-----------|---------------|---|
| 2024 | 11,751 | 11,557 | 194 |
| 2025 | 11,775 | 11,552 | 223 |
| 2026 | 11,884 | 11,609 | 275 |
| 2027 | 12,009 | 11,667 | 342 |
| 2028 | 12,158 | 11,747 | 411 |
| 2029 | 12,315 | 11,836 | 479 |
| 2030 | 12,467 | 11,924 | 543 |

2020 RNA Resource Adequacy High Load Scenario NYCA LOLE Results

| Study Year | 2024 | 2025 | 2026 | 2027 | 2028 | 2029 | 2030 |
|--------------------|------|------|------|------|------|------|------|
| 2020 RNA Base Case | 0.04 | 0.08 | 0.10 | 0.12 | 0.14 | 0.17 | 0.19 |
| High Load Scenario | 0.07 | 0.15 | 0.19 | 0.26 | 0.35 | 0.49 | 0.63 |

Zonal Resource Adequacy Margin (ZRAM)

| Study Year | 2024 | 2025 | 2026 | 2027 | 2028 | 2029 | 2030 |
|------------------|--------|------|-------|------|------|------|------|
| LOLE | 0.04 | 0.09 | 0.10* | 0.12 | 0.14 | 0.17 | 0.19 |
| Zone A | -850 | -400 | -50 | - | - | - | - |
| Zone B | -850 | -400 | -50 | - | - | - | - |
| Zone C | -1,500 | -400 | -50 | - | - | - | - |
| Zone D | -1,500 | -400 | -50 | - | - | - | - |
| Zone E | EZR | -400 | -50 | - | - | - | - |
| Zone F | -1,500 | -400 | -50 | - | - | - | - |
| Zone G | -1,500 | -400 | -50 | - | - | - | - |
| Zone H | EZR | EZR | -50 | - | - | - | - |
| Zone I | EZR | EZR | -50 | - | - | - | - |
| Zone J | -450 | -50 | 0 | - | - | - | - |
| Zone K | -1,400 | -550 | -150 | - | - | - | - |
| Zones A-F | -1,500 | -400 | -50 | - | - | - | - |
| Zones G-I | -1,500 | -400 | -50 | - | - | - | - |

Notes:

EZR - exceeds zonal resources (*i.e.*, all generation can be removed without causing a violation)

*LOLE for year 2026 is 0.097 days/year

- Determines the amount of “perfect capacity” in each zone that could be removed before the NYCA LOLE reaches 0.10 days/year, and offer another relative measure of how close the system is from violating reliability criteria
- This simulation is applicable to any RNA Study Years that have LOLE levels that are below criterion, *i.e.*, from 2024 through 2026.
- Note: the impacts of removing capacity on the reliability of the transmission system and on transfer capability are highly location dependent. Thus, in reality, lower amounts of capacity removal are likely to result in reliability issues at specific transmission locations.

Status-quo Scenario

2020 RNA Resource Adequacy Status-quo Scenario NYCA LOLE Results

| Study Year | 2024 | 2025 | 2026 | 2027 | 2028 | 2029 | 2030 |
|---------------------|------|------|------|------|------|------|------|
| Base Case | 0.04 | 0.08 | 0.10 | 0.12 | 0.14 | 0.17 | 0.19 |
| Status-quo Scenario | 0.07 | 0.13 | 0.14 | 0.17 | 0.19 | 0.23 | 0.25 |

- This scenario evaluates the reliability of the system under the assumption that no major transmission or generation projects come to fruition within the RNA Study Period
- This includes the removal of all proposed transmission and generation projects that have met 2020 RNA Base Case inclusion rules and removal of generators that require modifications to comply with the DEC's Peaker Rule
- From a resource adequacy perspective, this scenario indicates that if expected generation and transmission projects are not built, the criterion violation advances by two years to 2025

RNA Scenarios Based on the 2019 70x30 CARIS Scenarios

RNA 70x30 Scenario Background

- The CLCPA mandates that 70% of New York’s end-use energy consumption be served by renewable energy by 2030 (“70x30”), including specific technology-based targets for distributed solar (6,000 MW by 2025), storage (3,000 MW by 2030), and offshore wind (9,000 MW by 2035)
- The RNA 70x30 scenario models are based on the 2019 CARIS 70x30 scenario assumptions and output information
 - The 2019 CARIS Report is available on the NYISO website [\[link\]](#)
- The CARIS 70x30 scenario analyzed the system congestion and constrained generation pockets that arise from implementing 70% renewable energy on the New York system by 2030
- The purpose of this analysis is to augment the effort with reliability perspectives on potential system changes undertaken to meet state policy goals
 - Additional assumptions details are in Appendix C of the August 20 ESPWG [presentation](#)

Resource Adequacy Analysis Steps

- 1. Model the CARIS 70x30 “Base Load” and “Scenario Load” along with their corresponding renewable resources mix and calculate NYCA LOLE**
 - Identify Zonal Resource Adequacy Margin (ZRAM)
- 2. For each load model, if the system has surplus resources (LOLE less than 0.1) then remove fossil plants based on age until NYCA exceeds the LOLE criterion (“model at criterion”)**
 - This age-based approach is a simple analytical approach as a proxy to represent unit retirements that may occur as surplus resources increase. In reality many factors will affect specific generator status decisions
 - Quantify (MW) fossil plant removals that may be possible while maintaining resource adequacy
 - Additional Details in the August 20, 2020 ESPWG presentation:
https://www.nyiso.com/documents/20142/14682221/04%20RNA_70x30ScenariosResults.pdf

Fossil Removal on “Base Load”

| Cases (Age >=) | Total Thermal Capacity (MW) | | | | Cumulative Capacity Removed (MW) | | | | NYCA LOLE |
|-------------------|-----------------------------|--------|----------------|--------|----------------------------------|--------|----------------|-------|--------------|
| | Zone J | Zone K | Other Zones | Total | Zone J | Zone K | Other Zones | Total | |
| Total | 8,190 | 3,962 | 15,012 | 27,165 | 0 | 0 | 0 | 0 | 0.00 |
| 70 | 6,978 | 3,564 | 14,616 | 25,160 | 1,212 | 398 | 396 | 2,005 | 0.02 |
| 68 | 6,601 | 3,371 | 14,616 | 24,590 | 1,589 | 591 | 396 | 2,575 | 0.05 |
| 67* | 6,386 | 3,360 | 14,616 | 24,364 | 1,804 | 602 | 396 | 2,801 | 0.11 |
| 67 | 6,236 | 3,360 | 14,616 | 24,214 | 1,954 | 602 | 396 | 2,951 | 0.15 |

Observations

- NYCA meets the LOLE criterion with 2,575 MW removed
- NYCA exceeds the LOLE criterion when 2,801 MW are removed (67*)
 - The increase in LOLE is primarily driven by Zone J capacity removals

Notes:

- Case 67: most, but not all units age 67 years and older were retired in this case
- Case 67*: a special evaluation of Case 67 where the marginal unit was derated instead of fully removed to obtain an LOLE closer to 0.1 days/year

Resource Adequacy Key Takeaways

- **The NYCA system is reliable when adding new resources, but:**
 - Becomes unreliable as existing fossil generators are removed from service
 - This analysis does not consider potential reliability impacts due to:
 - Intra-zonal constraints on the transmission system
 - Changes on the transmission system as a result of the resource additions or subtractions
 - Unit Commitment, ramp rate constraints, and other production cost modeling techniques
- **Retirement of nuclear units may require additional (or removal of less) fossil fuel generation in order to have a reliable system**
- **Modeling ESRs provides a benefit to the system by:**
 - Allowing for additional units to be retired, subject to the limitations identified above
- **Alleviating the local transmission constraints that cause renewable curtailments, while beneficial from an annual energy production perspective as shown in CARIS, does not offset the need for dispatchable generation to meet reliability requirements at peak load**
- **Additional details in the 2020 RNA Report and Appendices:**
<https://www.nyiso.com/documents/20142/2248793/2020-RNAReport-Nov2020.pdf>

Questions?

Our mission, in collaboration with our stakeholders, is to serve the public interest and provide benefit to consumers by:

- Maintaining and enhancing regional reliability
- Operating open, fair and competitive wholesale electricity markets
- Planning the power system for the future
- Providing factual information to policymakers, stakeholders and investors in the power system

