



# High Intermittent Renewable Resources Analysis – Phase 3 Part 2

---

Kevin Osse

Capacity Market Operations – Resource Adequacy

**Installed Capacity Subcommittee Meeting #261**

June 1, 2022

# Objective

- Review the High Renewable Phase 3 part 2 study methodology and results
- Observations from the study results
- Conclusions and recommendations

# Notes about Study

- Each part of the phase 3 study was developed without capturing the impacts of transmission constraints
- By removing transmission constraints on the system, there are no longer trade-offs between Zone J/K and the rest of the system
- All the results in Phase 3 study are based on parametric comparisons

# ESR Modeling Methodology

- The energy storage resources (“ESR”) are modeled using predetermined charge and discharge shapes as discussed in the NYSRC’s Energy Storage Resource Modeling Whitepaper (<https://www.nysrc.org/PDF/Reports/IRM%20White%20Papers/Energy%20Storage%20Whitepaper.pdf>)
- For Part 2 of the study, the 6,000 MW of ESRs are added after Part 1 in which 27,000 MW of renewable resources were added to the system
  - The duration for the discharging period for the ESRs is 4 hours
- To maximize the benefits of the ESRs, the discharging period is designed to be situated at the 4 hours with the highest probability for Loss of Load (LOL) events, from HB16 to HB19
  - The NYISO reviewed the hourly distribution of LOLE from the Part 1 study and identified that HB16-HB19 had the highest 4-hr LOLE distribution
- To minimize the impact from the charging of the ESRs, the pre-determined shape included hourly charging at 50% capability for eight hours between HB00 and HB08

# Reserve Margin Results

| Case and Scenarios                                       | 2022 FBC      | 2022 FBC*                   | Phase 3 Part 1                | Phase 3 Part 2 | DELTA (Phase 3 Part 2 – Part 1) |
|--|---------------|-----------------------------|-------------------------------|----------------|---------------------------------|
| Resource Changes   | n/a           | No transmission constraints | 27,000 MW renewable resources | 6,000 MW ESR   |                                 |
| Transmission Constraints                                 | Included      | Removed                     | Removed                       | Removed        |                                 |
| <b>Installed Capacity Reserve Margin Comparison</b>      |               |                             |                               |                |                                 |
| <b>NYCA</b>  | <b>119.7%</b> | <b>117.2%</b>               | <b>180.5%</b>                 | <b>198.8%</b>  | <b>+18.3%</b>                   |
| <b>Unforced Capacity Reserve Margin (URM) Comparison</b> |               |                             |                               |                |                                 |
| <b>NYCA</b>  | <b>105.0%</b> | <b>102.7%</b>               | <b>112.5%</b>                 | <b>125.5%</b>  | <b>+13.0%</b>                   |

# ICAP and UCAP Changes

| NYCA                   | Part 1 | Part 2 | Delta        |
|------------------------|--------|--------|--------------|
| NYCA Peak Load         | 32,139 | 32,139 | <b>0</b>     |
| <b>ICAP Changes</b>    |        |        |              |
| As Found ICAP (MW)     | 68,037 | 74,037 | <b>6,000</b> |
| ICAP @ LOLE = 0.1 (MW) | 58,000 | 63,891 | <b>5,857</b> |
| ICAP Removed (MW)      | 10,036 | 10,146 | <b>143</b>   |
| ICAP Reserve Margin    | 180.5% | 198.8% | <b>18.3%</b> |
| <b>UCAP Changes</b>    |        |        |              |
| As Found UCAP (MW)     | 42,938 | 47,256 | <b>4,318</b> |
| UCAP @ LOLE = 0.1 (MW) | 36,147 | 40,330 | <b>4,183</b> |
| UCAP Removed (MW)      | 6,791  | 6,926  | <b>135</b>   |
| UCAP Reserve Margin    | 112.5% | 125.5% | <b>13.0%</b> |

# Observations

- When adding significant amount of ESRs to the system, the ICAP and UCAP required to maintain the system LOLE at the 0.1 criterion increases
- The sizeable increases in the IRM and URM suggest that a portion of the added ESRs is still needed for system at criterion, indicating that the modeled ESRs have lower-than-expected effectiveness in addressing system LOLE
  - Discharging of ESRs is scheduled during high risk of LOL events from HB16 to HB19.
  - After adding the ESRs, the LOLEs during H16-HB19 are largely removed; however not all events are completely addressed this four hour window
  - The addition of ESRs improves the reliability of the at-criteria system
    - The Expected Unserved Energy (EUE) as an output from the MARS simulation is reduced from 239 MWh (Part 1 study) to 133 MWh (Part 2 study)

| Before Adding the ESRs (Part 1 Study) |      |      |      |      |      |      |       |       |       |       |       |       |       |       |      |      |        |
|---------------------------------------|------|------|------|------|------|------|-------|-------|-------|-------|-------|-------|-------|-------|------|------|--------|
| HB                                    | 0-8  | 9    | 10   | 11   | 12   | 13   | 14    | 15    | 16    | 17    | 18    | 19    | 20    | 21    | 22   | 23   | Total  |
| Percentage                            | 0.0% | 0.0% | 0.1% | 1.4% | 3.7% | 4.0% | 7.9%  | 9.9%  | 13.3% | 14.8% | 10.0% | 12.9% | 10.0% | 9.5%  | 2.5% | 0.0% | 100.0% |
| After Adding the ESRs (Part 2 Study)  |      |      |      |      |      |      |       |       |       |       |       |       |       |       |      |      |        |
| HB                                    | 0-8  | 9    | 10   | 11   | 12   | 13   | 14    | 15    | 16    | 17    | 18    | 19    | 20    | 21    | 22   | 23   | Total  |
| Percentage                            | 0.0% | 0.1% | 0.1% | 2.7% | 6.7% | 7.5% | 15.0% | 18.8% | 0.2%  | 0.3%  | 0.2%  | 0.2%  | 20.3% | 22.8% | 5.1% | 0.0% | 100.0% |

# Observations (cont'd)

- Upon further review, a few drivers may contribute to the results:
  - The single four hour output window for all 6,000 MW does not provide full support to the system as reliability events are longer than four hours.
    - Peaker retirements will be included in Part 3 of the study. ESRs are expected to be more beneficial when the penetration of thermal resources is reduced
  - There is likely a saturation effect with the large quantity of ESRs modeled in the study
  - Benefits from additional resources appear to leak to external areas. LOLEs from the external areas are lowered for both the Part 1 and Part 2 studies

| NYCA                 | FBC    | FBC*   | +27,00 MW Renewables | +6,000 MW ESR |
|----------------------|--------|--------|----------------------|---------------|
| IRM                  | 119.7% | 117.1% | 180.5%               | 198.8%        |
| <b>External LOLE</b> |        |        |                      |               |
| PJM                  | 0.169  | 0.178  | 0.135                | 0.119         |
| ISONE                | 0.109  | 0.122  | 0.082                | 0.070         |
| IESO                 | 0.111  | 0.103  | 0.076                | 0.067         |
| HQ                   | 0.109  | 0.093  | 0.092                | 0.092         |



# Conclusions

- **Predetermined output profiles do not have capabilities to model significant amount of ESRs**
  - Assuming the same operating behavior of all the ESRs is not reasonable, as indicated via a single output profile
  - Breaking the ESRs into multiple smaller units with different output profiles is not an ideal solution as it involves making arbitrary assumptions about different operating behaviors among the ESRs
- **Utilizing the GE ELR functionality to implement dynamic modeling of ESRs should be considered. However further refinements are needed:**
  - Currently, the GE ELR functionality is applied with the output window limitations, which will not be sufficient to model large amount of ESRs
  - The charging of the ESRs should be sufficient to provide full energy storage and not introduce new reliability issues
- **The interplay between NYCA and external systems also requires further investigation**
  - The High Renewable Phase 3 study considers high renewable and intermittent penetration for NYCA but with the current supply mix in external areas

# Recommendations

- **Continue the evolution of the GE ELR functionality to develop a modeling approach and tools for high penetration of ESRs, considering:**
  - The output characteristics of ESRs, such as staggering output of the ESR fleet to address a system shortage with a longer duration
  - The charging requirements and impacts of the ESRs
- **Investigate the impact of the additional renewable and intermittent resources on NYCA compared with external systems.**

# Questions?

# Our Mission & Vision



## Mission

Ensure power system reliability and competitive markets for New York in a clean energy future



## Vision

Working together with stakeholders to build the cleanest, most reliable electric system in the nation