

IRM 2024 Preliminary Base Case Parametric Results (as of 3/28/2023)						
Material Changes						
Number	Adjustment Type	Description	Impact on Margins			
			NYCA	NYC	LI	LHV
		IRM 2023 Final Base Case	19.9	78.2	107.4	88.5
1	A-F	Wind Shapes (2018-2022)	-0.11	0.00	0.00	0.00
2	A-K	RoR Shapes (2018-2022)	0.09	0.06	0.09	0.07
3	A-K	Thermal Outage Rate (2018-2022)	0.29	0.29	0.16	0.31
4	A-K	AC Transmission Topology	-0.36	-0.25	-0.36	-0.27
		Sum of Material Changes	-0.09	0.11	-0.11	0.10
		Non Material Changes	-0.01	0.00	-0.02	0.00
		<b>Preliminary Base Case Parametric Results **</b>	19.80	78.30	107.27	88.65

**\*\* The LCR values reported are neither Tan 45 results nor LCR Optimizer results. The actual LCRs will be determined and approved by the NYISO's Operating Committee in January 2024 based upon the EC approved IRM and database model with modifications pursuant to Market Services Tariff Section 5.11.**

Non-Material Changes (Less than 0.05% delta on IRM)						
Number	Adjustment Type	Description	Impact on Margins			
			NYCA	NYC	LI	LHV
1	A-K	Database check	0.00	0.00	0.00	0.00
2	A-F	LFG Shapes (2018-2022)	0.00	0.00	0.00	0.00
3	A-K	Solar Shapes (2018-2022)	-0.01	0.00	-0.02	0.00
		Sum of Non-Material Changes	-0.01	0.00	-0.02	0.00