

# First Draft Appendices

---

## **New York Control Area Installed Capacity Requirement**

**For the Period May 2024  
To April 2025**



December 8, 2023

---

**New York State Reliability Council, LLC  
Installed Capacity Subcommittee**



## Table of Contents

<b>A. Reliability Calculation Models and Assumptions – Appendix A</b> .....	<b>3</b>
A.1 GE MARS.....	5
A.2 Methodology .....	9
A.3 Base Case Modeling Assumptions .....	10
A.4 Data Scrub .....	41
<b>B. Details for Study Results – Appendix B</b> .....	<b>44</b>
B.1 Sensitivity Results.....	44
B.2 Frequency of Implementing Emergency Operating Procedures .....	46
B.3 LOLE Max & Mins Plus Outage Magnitudes and Durations .....	48
<b>C. Impact of Environmental Regulations- Appendix C (Being Updated by NYISO Staff)</b> .....	<b>50</b>
C.1 Combustion Turbine NOx Emission Limits.....	50
C.2 U.S. Clean Water Act: Best Technology Available for Plant Cooling Water Intake .....	51
C.3 New York City Residual Oil Elimination.....	51
C.4 Regional Greenhouse Gas Initiative (RGGI) .....	52
C.5 Distributed Generator NOx Emission Limits .....	52
C.6 Cross-State Air Pollution Rule (CSAPR).....	52
C.7 Climate Leadership and Community Protection Act (CLCPA).....	53
C.8 Offshore Wind Development .....	53
C.9 Comprehensive Energy Efficiency Initiative.....	53
C.10 Storage Deployment Target .....	54
C.11 Distributed Solar Program.....	54
C.12 Accelerated Renewable Energy Growth and Community Benefit Act .....	57
<b>D. ICAP to UCAP Translation – Appendix C (Yet to be updated)</b> .....	<b>60</b>
D.1 NYCA and NYC and LI Locational Translations.....	61
D.2 Transmission Districts ICAP to UCAP Translation .....	66
D.3 Wind Resource Impact on the NYCA IRM and UCAP Markets .....	74
<b>E. Glossary – Appendix E</b> .....	<b>76</b>

## Table of Tables & Figures

Figure A.1 NYCA ICAP Modeling.....	3
Table A.1 Modeling Details .....	4
Equation A.1 Transition Rate Definition .....	6
Equation A.2 Transition Rate Calculation Example.....	6
Table A.2 State Transition Rate Example .....	7
Table A.3 Load Model .....	10
Table A.4 2023 Final NYCA Peak Load Forecast – Coincident Peak .....	12
Table A.5 2023 Final NYCA Peak Load Forecast – Locality Peaks.....	12
Table A.6 2023 Final NYCA Peak Load Forecast – Zonal Peaks .....	12
Table A.7 2023 Summer and Winter Load Forecast Uncertainty Models .....	14
Figure A.2 Sumer LFU Distributions .....	14
Figure A.3 Bin Centers (Equidistant v. Equal Area) .....	16
Figure A.4 Per Unit Summer Load Shapes .....	17
Table A.8 Capacity Resources .....	18
Table A.9 Wind Generation.....	21
Figure A.5 Five-Year Weighted Annual Average Zonal EFORds .....	24
Figure A.6 NYCA Annual Weighted Average Availability .....	25
Figure A.7 NYCA Five-Year Weighted Average Availability.....	26
Figure A.8 NERC Weighted Annual Average Availability.....	27
Figure A.9 NERC Five-Year Weighted Average Availability .....	28
Table A.10 Transmission System Model .....	31
Figure A.10 2023 IRM Topology.....	33
Table A.11 Interface Limits Updates.....	34
Table A.14 Assumptions for Emergency Operating Procedures.....	38
Table A.15 Emergency Operating Procedures Values .....	39
Table A.16 SCR Performance .....	40
Table A.17 GE MARS Data Scrub.....	41
Table A.18 NYISO Data Scrub .....	41
Table A.19 Transmission Owner Data Scrub.....	42
Table B.1 Sensitivity Case Result.....	45
Table B.2 Implementation of EOP steps .....	47
Table B.3 SCR Calls Per Month.....	47
Table C.1 Historical NYCA Capacity Parameters .....	60
Table C.2 NYCA ICAP to UCAP Translation .....	62
Table C.3 New York City ICAP to UCAP Translation .....	63
Table C.4 Long Island ICAP to UCAP Translation.....	64
Table C.5 GHIJ ICAP to UCAP Translation.....	65
Table C.6 Central Hudson Gas & Electric ICAP to UCAP Translation.....	66
Table C.7 Con Ed ICAP to UCAP Translation.....	67

Table C.8 LIPA ICAP to UCAP Translation.....	68
Table C.9 NGRID ICAP to UCAP Translation .....	69
Table C.10 NYPA ICAP to UCAP Translation .....	70
Table C.11 NYSEG ICAP to UCAP Translation .....	71
Table C.12 O & R ICAP to UCAP Translation.....	72
Table C.13 RGE ICAP to UCAP Translation .....	73

# Appendices

# **Appendix A**

## **NYCA Installed Capacity Requirement Reliability Calculation Models and Assumptions**

**Description of the GE MARS Program: Load, Capacity,  
Transmission, Outside World Model, and Assumptions**

## A. Reliability Calculation Models and Assumptions – Appendix A

The reliability calculation process for determining the New York Control Area (NYCA) Installed Reserve Margin (IRM) requirement utilizes a probabilistic approach. This technique calculates the probabilities of outages of generating units, in conjunction with load and transmission models, to determine the number of days per year of expected capacity shortages. The General Electric Multi-Area Reliability Simulation (GE-MARS) is the primary computer program used for this probabilistic analysis. The result of the calculation for “Loss of Load Expectation” (LOLE) provides a consistent measure of system reliability. The various models used in the NYCA IRM calculation process are depicted in Figure A.1 below.

Table A.1 lists the study parameters, the source for the study assumptions, and where the assumptions are described in Appendix A. Finally, section A.3 compares the assumptions used in the [2023-24](#) and [2024-25](#) IRM reports (a.k.a. the [2024](#) IRM report).

Figure A.1 NYCA ICAP Modeling




Table A.1 Modeling Details

#	Parameter	Description	Source	Reference
<b>Internal NYCA Modeling</b>				
1	GE MARS	General Electric Multi-Area Reliability Simulation Program		Section A.1
2	11 Zones	Load Areas	Fig A.1	NYISO Accounting & Billing Manual
3	Zone Capacity Models	Generator models for each generating in Zone Generator availability Unit ratings	GADS data <a href="#">2022</a> Gold Book <sup>1</sup>	Section A.3.4
4	Emergency Operating Procedures	Reduces load during emergency conditions to maintain operating reserves	NYISO	Section A.3.5
5	Zone Load Models	Hourly loads	NYCA load shape and peak forecasts	Section A.3.1
6	Load Uncertainty Model	Account for forecast uncertainty due to weather conditions	Historical data	Section A.3.3
7	Transmission Capacity Model	Emergency transfer limits of transmission interfaces between Zones	NYISO Transmission Studies	Section A.3.5
<b>External Control Area Modeling</b>				
8	Ontario, Quebec, ISONE, PJM Control Area Parameters	See items 9-12 in this table	Supplied by External Control Area	
9	External Control Area Capacity models	Generator models in neighboring Control Areas	Supplied by External Control Area	Section A.3.6
10	External Control Area Load Models	Hourly loads	Supplied by External Control Area	Section A.3.6
11	External Control Area Load Uncertainty Models	Account for forecast uncertainty due to weather conditions	Supplied by External Control Area	Section A.3.6
12	Interconnection Capacity Models	Emergency transfer limits of transmission interfaces between control areas.	Supplied by External Control Area	Section A.3.6

<sup>1</sup> [2023](#) Load and Capacity Data Report, [http://www.nyiso.com/public/markets\\_operations/services/planning/documents/index.jsp](http://www.nyiso.com/public/markets_operations/services/planning/documents/index.jsp)

## **A.1 GE MARS**

As the primary probabilistic analysis tool used for establishing NYCA IRM requirements, the GE-MARS program includes a detailed load, generation, and transmission representation for 11 NYCA Zones, as well as the four external Control Areas (Outside World Areas) interconnected to the NYCA (see Section A.3 for a description of these Zones and Outside World Areas).

A sequential Monte Carlo simulation forms the basis for GE-MARS. The Monte Carlo method provides a fast, versatile, and easily expandable program that can be used to fully model many different types of generation, transmission, and demand-side options. GE-MARS calculates the standard reliability indices of daily and hourly LOLE (days/year and hours/year) and Loss of Energy Expectation (LOEE in MWh/year). The use of sequential Monte Carlo simulation allows for the calculation of time-correlated measures such as frequency (outages/year) and duration (hours/outage). The program also calculates the need for initiating Emergency Operating Procedures (EOPs), expressed in days/year (see Section A.3.5).

In addition to calculating the expected values for the reliability indices, GE-MARS also produces probability distributions that show the actual yearly variations in reliability that the NYCA could be expected to experience. In determining NYCA reliability, there are several types of randomly occurring events that must be taken into consideration. Among these are the forced outages of generating units and transmission capacity. Monte Carlo simulation models the effects of such random events. Deviations from the forecasted loads are captured using a load forecast uncertainty model.

Monte Carlo simulation approaches can be categorized as “non-sequential” and “sequential”. A non-sequential simulation process does not move through time chronologically or sequentially, but rather considers each hour independent of every other hour. Because of this, non-sequential simulation cannot accurately model issues that involve time correlations, such as maintenance outages, and cannot be used to calculate time-related indices such as frequency and duration.

Sequential Monte Carlo simulation (used by GE-MARS) steps through the year chronologically, recognizing the status of equipment is not independent of its status in adjacent hours. Equipment forced outages are modeled by taking the equipment out of service for contiguous hours, with the length of the outage period being determined from the equipment’s mean time to repair. Sequential simulation can model issues of concern

that involve time correlations and can be used to calculate indices such as frequency and duration. It also models transfer limitations between individual areas.

Because the GE-MARS Program is based on a sequential Monte Carlo simulation, it uses state transition rates, rather than state probabilities, to describe the random forced outages of the thermal units. State probabilities give the probability of a unit being in a given capacity state at any particular time and can be used if one assumes that the unit's capacity state for a given hour is independent of its state at any other hour. Sequential Monte Carlo simulation recognizes the fact that a unit's capacity state in any given hour is dependent on a given state in previous hours and influences its state in future hours. It thus requires additional information that is contained in the transition rate data.

For each unit, a transition rate matrix is input that shows the transition rates to go from each capacity state to each other capacity state. The transition rate from state A to state B is defined as the number of transitions from A to B per unit of time in state A (Equation A.1).

#### Equation A.1 Transition Rate Definition

$$\text{Transition (A to B)} = \frac{\text{Number of Transitions from A to B}}{\text{Total Time in State A}}$$

Table A.2 shows the calculation of the state transition rates from historic data for one year. The Time-in-State Data shows the amount of time that the unit spent in each of the available capacity states during the year; the unit was on planned outage for the remaining 760 hours of the year. The Transition Data shows the number of times that the unit transitioned from each state to each other state during the year. The State Transition Rates can be calculated from this data. For example, the transition rate from state 1 to state 2 equals the number of transitions from 1 to 2 divided by the total time spent in state 1 (Equation A.2).

#### Equation A.2 Transition Rate Calculation Example

$$\text{Transition (1 to 2)} = \frac{(10 \text{ Transitions})}{5,000 \text{ Hours}} = 0.0002$$

Table A.2 State Transition Rate Example

Time in State Data			Transition Data			
State	MW	Hours	From State	To State 1	To State 2	To State 3
1	200	5000	1	0	10	5
2	100	2000	2	6	0	12
3	0	1000	3	9	8	0
State Transition Rates						
From State	To State 1		To State 2		To State 3	
1	0.000		0.002		0.001	
2	0.003		0.000		0.006	
3	0.009		0.008		0.000	

From the state transition rates for a unit, the program calculates the two important quantities that are needed to model the random forced outages on the unit: the average time that the unit resides in each capacity state, and the probability of the unit transitioning from each state to each other state.

Whenever a unit changes capacity states, two random numbers are generated. The first is used to calculate the amount of time that the unit will spend in the current state; it is assumed that the time in a state is exponentially distributed, with a mean as computed from the transition rates. This time in state is added to the current simulation time to calculate when the next random state change will occur. The second random number is combined with the state transition probabilities to determine the state to which the unit will transition when it leaves its current state. The program thus knows for every unit on the system, its current state, when it will be leaving that state, and the state to which it will go next.

Each time a unit changes state, because of random state changes, the beginning or ending of planned outages, or mid-year installations or retirements, the total capacity available in the unit's area is updated to reflect the change in the unit's available capacity. This total capacity is then used in computing the area margins each hour.

### A.1.1 Error Analysis

An important issue in using Monte Carlo simulation programs such as GE-MARS is the number of years of artificial history (or replications) that must be created to achieve an acceptable level of statistical convergence in the expected value of the reliability index of

interest. The degree of statistical convergence is measured by the standard deviation of the estimate of the reliability index that is calculated from the simulation data.

The standard deviation has the same physical units (*e.g.*, days/year) as the index being estimated, and thus its magnitude is a function of the type of index being estimated. Because the standard deviation can assume a wide range of values, the degree of convergence is often measured by the standard error, which is the standard deviation of the estimated mean expressed as a per unit of the mean.

Convergence can also be expressed in terms of a confidence interval that defines the range in which you can state, with a given level of confidence that the actual value falls within the interval. For example, a range centered on the mean of two standard deviations in each direction (plus and minus) defines a confidence interval of 95%.

For this analysis, the Base Case required 773 replications to converge to a standard error of 0.05 and required 2,577 replications to converge to a standard error of 0.025. For our cases, the model was run to 2,750 replications at which point the daily LOLE of 0.100 Event-Days/year for NYCA was met with a standard error less than 0.025. The confidence interval at this point ranges from 19.7% to 20.1%. An IRM of 19.9% is in full compliance with the NYSRC Resource Adequacy rules and criteria (see Base Case Study Results section).

### **A.1.2 Conduct of the GE-MARS analysis**

The study was performed using Version [4.13.2129](#) of the GE-MARS software program. This version has been benchmark tested by the NYISO.

The current base case is the culmination of the individual changes made to last year's base case. Each change, however, is evaluated individually against last year's base case. The LOLE results of each of these pre-base case simulations are reviewed to confirm that the reliability impact of the change is reasonable and explainable.

General Electric was asked to review the input data for errors. They have developed a program called "Data Scrub" which processes the input files and flags data that appears to be out of the ordinary. For example, it can identify a unit with a forced outage rate significantly higher than all the others in that size and type category. If something is found, the ISO reviews the data and either confirms that it is correct as is or institutes a correction. The results of this data scrub are shown in Section A.4.

The top three summer peak loads of all Areas external to NYCA are aligned to be on the same days as that of NYCA, even though they may have historically occurred at different times. This is a conservative approach, using the assumption that peak conditions could be the result of a widespread heat wave. This would result in reducing the amount of assistance that NYCA could receive from the other Areas.

## A.2 Methodology

The [2024](#) IRM study continues to use the Unified Methodology that simultaneously provides a basis for the NYCA installed reserve requirements and the preliminary locational installed capacity requirements. The IRM/preliminary LCR characteristic consists of a curve function, “a knee of the curve” and straight-line segments at the asymptotes. The curve function is represented by a quadratic (second order) curve which is the basis for the Tan 45 inflection point calculation. Inclusion of IRM/preliminary LCR point pairs remote to the “knee of the curve” may impact the calculation of the quadratic curve function used for the Tan 45 calculation.

The procedure for determining the best fit curve function used for the calculation of the Tan 45 inflection point to define the base case requirement is based on the following methodology:

- 1) Start with all points on IRM/preliminary LCR Characteristic.
- 2) Develop regression curve equations for all different point to point segments consisting of at least four consecutive points.
- 3) Rank all the regression curve equations based on the following:
  - Sort regression equations with highest R<sup>2</sup>.
  - Remove any equations which show a negative coefficient in the first term. This is the constant labeled ‘a’ in the quadratic equation:  $ax^2+bx+c$
  - Ensure calculated IRM is within the selected point pair range, i.e., if the curve fit was developed between 14% and 18% and the calculated IRM is 13.9%, the calculation is invalid.
  - In addition, there must be at least one statewide reserve margin point to the left and right of the calculated tan 45 point.
  - Determine that the calculated IRM and corresponding preliminary LCR do not violate the 0.1 Event-Days/year LOLE criteria.
  - Check results to determine that they are consistent with visual inspection methodology used in past years’ studies.

This approach identifies the quadratic curve functions with highest R<sup>2</sup> correlations as the basis for the Tan 45 calculation. The final IRM is obtained by averaging the Tan 45 IRM

points of the NYC and LI curves. The Tan 45 points are determined by solving for the first derivatives of each of the “best fit” quadratic functions as a slope of -1. Lastly, the resulting preliminary LCR values are identified.

## A.3 Base Case Modeling Assumptions

### A.3.1 Load Model

Table A.3 Load Model

Parameter	2023 Study Assumption	2024 Study Assumption	Explanation
Peak Load	<u>October 1, 2022 NYCA:</u> <u>NYCA: 32,246.0 MW</u> <u>NYC: 11,285.0 MW</u> <u>LI: 5,133.3 MW</u> <u>G-J: 15,406.8 MW</u>	October 1, <u>2023 NYCA:</u> <u>NYCA: 32,451.5 MW</u> <u>NYC: 11,303 MY</u> <u>LI: 5090.1 MW</u> <u>G-J: 15,439 MW</u>	Forecast based on examination of <u>2023</u> weather normalized peaks, <u>2024</u> economic and expected weather projections, and Transmission Owner projections.
Load Shape Model	<u>Multiple Load Shapes Model using years: 2013 (Bins 1 &amp; 2), 2018 (Bins 3 &amp; 4), and 2017 (Bin 5-7)</u>	Multiple Load Shapes Model using years: <b>2013 (Bins 1 &amp; 2), 2018 (Bins 3 &amp; 4), and 2017 (Bin 5-7)</b>	Load shapes updated <u>for the 2023 IRM study</u> to be more reflective of current system conditions such as solar penetration
Load Uncertainty Model	Statewide and zonal models updated to reflect current data	Statewide and zonal models updated to reflect current data	Updated from <u>2023 IRM</u> . Based on TO and NYISO data and analyses.

### A.3.2 Peak Load Forecast Methodology (Updated by NYISO Staff)

The procedure for preparing the IRM forecast is very similar to that described in the NYISO Load Forecasting Manual for the ICAP forecast. The NYISO and Transmission Owners developed regression models to evaluate the relationship between regional weather and Transmission District summer weekday peak loads, using data from the summer of 2023 and other recent summers as needed. The resulting estimates of weather response (i.e., the MW increase in load per degree of increase in the weather variable) by Transmission District were used to develop 2023 Transmission District weather adjustments, which normalize the peaks to typical summer peak weather conditions. For purposes of the IRM and ICAP forecasts, the NYISO evaluates the system peak load that occurs during non-holiday weekdays in July and August. In 2023, the system peak load during this period was on July 28<sup>th</sup>, Hour Beginning 17. The system peak load of 28,722.9 MW is shown by Transmission District in Table A.4 (col. 2). The total MW adjustment (col. 3), including the

weather adjustment, and estimated demand response and municipal self-generation impacts were added to the system peak, producing the 2022 weather normalized peak load of 31,397.5 MW (col. 4). Notably, there were a number of hot weather high load days in early September of 2023. The September peak load of 30,206 MW on September 6<sup>th</sup> exceeded the IRM and ICAP peak window peak load in July. The load and weather data from the early September high load days was considered in the determination of final 2023 Transmission District weather adjustments for the 2024 IRM forecast.

Some Transmission Owners developed updated estimates of the Regional Load Growth Factor (RLGF) for their territories. The RLGF represents the ratio of forecasted 2024 summer peak load to the 2023 weather normalized peak, based on the anticipated load growth or decline in the territory (excluding large load projects). Summer peak load growth rates from the 2023 Gold Book forecast were used for those Transmission Owners that did not provide updates. The final RLGFs (col. 6) were reviewed by the NYISO and discussed with the Transmission Owners as needed. The 2024 forecast before adjustments (col. 7) is the product of the 2023 weather normalized peaks excluding large loads and the RLGFs. Summer 2024 large load projections are added in column 8. The resulting sum (col. 9) represents the 2024 IRM coincident peak forecast of 31,616.8 MW before BTM:NG adjustments. This forecast is a 2.1% decrease relative to the 2024 forecast from the 2023 Gold Book. For purposes of modeling in the IRM study, the forecast of BTM:NG (Behind-the-Meter Net Generation) resource load is added in column 10, producing a total forecast of 31,765.6 MW inclusive of BTM:NG load (col. 11).

The Locality forecasts are reported in the second table below. These forecasts are the product of the weather normalized coincident peak load in the Locality, the non-coincident to coincident peak (NCP to CP) ratio in the Locality, and the RLGF(s) of the Transmission District(s) in the Locality. The Locality NCP to CP ratios were calculated using the historical 15-year ratio (excluding outlier years). The Locality forecasts of 11,170.6 MW (Zone J), 5,080.3 MW (Zone K), and 15,273.5 MW (G-to-J Locality), inclusive of BTM:NG loads, are shown in column 10.

The third table below shows the 2024 non-coincident peak load forecast by Zone. Zonal coincident peak forecasts were generally derived using sub-zonal load shares (Transmission District to Zone), based upon peak and near-peak load hours over the most recent five summers. Zonal non-coincident peak forecasts were calculated by multiplying the coincident peak forecast by the Zonal NCP to CP ratios. The Zonal forecasts shown below include the projected impacts of BTM:NG and large load projects.

The peak load forecasts, along with the regression models, weather adjustments, RLGFs, and NCP to CP ratios used to derive them were discussed and approved by the NYISO

Load Forecasting Task Force (LFTF) and the NYSRC Installed Capacity Subcommittee (ICS). The LFTF recommended the Final 2024 Peak Load Forecast presented below to the NYSRC. The ICS approved the Final 2024 Peak Load Forecast for use in the 2024 IRM Study.

**Table A.4 2024 Final NYCA Peak Load Forecast – Coincident Peak**

2024 IRM Coincident Peak Forecast										
(1)	(2)	(3)	(4) = (2) + (3)	(5)	(6)	(7) = (5) * (6)	(8)	(9) = (7) + (8)	(10)	(11) = (9) + (10)
Transmission District	2023 Actual MW, 7/28/2023 HB 17	Total Adjustment (Demand Response + Muni Self-Gen + Wthr Adjustment) MW	2023 Weather Normalized Coincident Peak MW	2023 WN Peak MW Excluding Large Loads	Regional Load Growth Factor	2024 Forecast, Before Adjustments MW	Large Loads MW	2024 IRM Forecast, With Large Loads, Before BTM:NG Adjustments MW	BTM:NG Forecast MW	2024 IRM Forecast, With Large Load Growth and BTM:NG Adjustments MW
Con Edison	11,054.4	1,473.2	12,527.6	12,527.6	1.0029	12,563.9	0.0	12,563.9	15.2	12,579.1
Cen Hudson	986.0	62.0	1,048.0	1,048.0	0.9940	1,041.7	0.0	1,041.7	0.0	1,041.7
LIPA	4,953.4	124.4	5,077.8	5,077.8	0.9770	4,961.0	0.0	4,961.0	38.9	4,999.9
Nat. Grid	6,030.5	627.5	6,658.0	6,655.6	1.0000	6,655.6	259.0	6,914.6	5.0	6,919.6
NYPA	484.0	3.5	487.5	335.1	1.0030	336.1	169.0	505.1	0.0	505.1
NYSEG	2,887.7	158.1	3,045.8	3,045.8	0.9979	3,039.4	50.0	3,089.4	44.1	3,133.5
O&R	974.4	105.3	1,079.7	1,079.7	0.9940	1,073.2	0.0	1,073.2	0.0	1,073.2
RG&E	1,352.5	120.6	1,473.1	1,473.1	0.9965	1,467.9	0.0	1,467.9	45.6	1,513.5
<b>NYCA</b>	<b>28,722.9</b>	<b>2,674.6</b>	<b>31,397.5</b>	<b>31,242.7</b>	<b>0.9967</b>	<b>31,138.8</b>	<b>478.0</b>	<b>31,616.8</b>	<b>148.8</b>	<b>31,765.6</b>
<b>2024 Forecast from 2023 Gold Book</b>								<b>32,280.0</b>		
<b>Change from 2023 Gold Book</b>								<b>-663.2</b>		
<b>Percent Change</b>								<b>-2.1%</b>		

**Table A.5 2024 Final NYCA Peak Load Forecast – Locality Peaks**

2024 IRM Locality Peak Forecasts									
(1)	(2)	(3)	(4)	(5) = (3) * (4)	(6)	(7) = (6) - (5)	(8) = (7) / (6)	(9)	(10) = (8) + (9)
Locality	2023 Locality Peak MW	2023 Weather Normalized Locality Peak MW	Regional Load Growth Factor	2024 IRM Locality Peak Forecast Before BTM:NG Adjustments MW	2024 Forecast from 2023 Gold Book MW	Change from Gold Book Forecast MW	Percent Change from Gold Book Forecast	BTM:NG Forecast MW	Locality Peak Forecast, Including BTM:NG Adjustments MW
Zones G-to-J	13,588.6	15,235.2	1.0015	15,258.3	15,416.0	-157.7	-1.0%	15.2	15,273.5
Zone J - NYC	10,064.0	11,123.2	1.0029	11,155.4	11,280.0	-124.6	-1.1%	15.2	11,170.6
Zone K - LIPA	4,955.6	5,160.1	0.9770	5,041.4	5,049.0	-7.6	-0.2%	38.9	5,080.3

**Table A.6 2024 Final NYCA Peak Load Forecast – Zonal Peaks**

Zonal Non-Coincident Peak Forecasts With BTM:NG Adjustments										
A	B	C	D	E	F	G	H	I	J	K
2,764.0	2,095.9	2,766.8	711.5	1,360.7	2,324.8	2,177.2	638.9	1,410.0	11,170.6	5,080.3

## **Zonal Load Forecast Uncertainty**

The 2024 load forecast uncertainty (LFU) models were updated during the spring of 2023. The NYISO and pertinent Transmission Owners developed updated load-weather regression models inclusive of summer 2022 data, resulting in updated LFU multipliers for use in the 2024 IRM Study. As with the 2023 IRM Study, the equal-area approach was used to determine the reference temperatures of each of the seven LFU bins, which reflect the assumed normal distribution of the weather variable. This was done by setting the Z-value equal to the location of the midpoint of the area of each bin.

### **Review of Load-Weather Relationship**

Updated regression models were developed for all LFU modeling regions (Zones A-E, Zones F&G, Zones H&I, Zone J, and Zone K) to establish the load-weather relationship observed during the 2022 summer. The NYISO developed models for the Zones A-E and Zones F&G regions. Models for the Zones H&I and Zone J areas were developed in conjunction with Con Edison. The Zone K model was developed by LIPA and reviewed by the NYISO. The NYISO developed a system-level winter LFU model reflecting the load-weather relationship observed during the 2022-23 winter. All model results were presented to and reviewed by the LFTF and ICS. The ICS approved the updated 2023 LFU model results for use in the 2024 IRM Study.

The NYISO regional summer models established the load-weather relationship through polynomial regressions (generally 3<sup>rd</sup> order, or cubic). Pooled models using 2019, 2021, and 2022 summer data were developed. Multiple model structure combinations were investigated for each region. The optimal pooled model was selected for each LFU area based on statistical model accuracy and the resulting weather sensitivity. The weather distribution used to define the LFU bin reference temperatures was calculated using 30 years of system peak-producing weather days. This distribution was applied to the load-weather relationship established by the selected regression models to calculate the LFU multipliers for each area. The LIPA Zone K splined linear model utilized data from the 2013 through 2022 summers.

The NYCA winter model utilized a 2<sup>nd</sup> order polynomial regression fit through winter 2018-19, 2021-22, & 2022-23 load and weather data. The winter LFU model used the winter weather variable developed as part of the LFU phase 3 analyses, based on temperature and wind speed.


The 2024 IRM study LFU multipliers are presented in Table A.7. The rows list the seven bin levels and their probability of occurrence, along with the associated per-unit load multipliers by LFU area. These results are presented graphically in Figure A.2.

**Table A.7 2024 IRM Study Summer and Winter Load Forecast Uncertainty Multipliers**

Bin	Bin z	Bin Probability	Summer					Winter
			A-E	F&G	H&I	J	K	NYCA
Bin 1	2.74	0.62%	113.93%	110.69%	110.18%	108.88%	116.62%	110.37%
Bin 2	1.79	6.06%	109.54%	107.86%	107.34%	105.42%	111.14%	106.37%
Bin 3	0.89	24.17%	104.86%	104.04%	103.09%	101.61%	105.52%	102.75%
Bin 4	0.00	38.29%	100.00%	99.46%	97.81%	97.51%	100.00%	99.42%
Bin 5	-0.89	24.17%	95.00%	94.29%	91.70%	93.12%	94.48%	96.29%
Bin 6	-1.79	6.06%	89.91%	88.61%	84.93%	88.45%	88.89%	93.30%
Bin 7	-2.74	0.62%	84.79%	82.53%	77.65%	83.48%	83.27%	90.41%

**Figure A.2 Sumer LFU Distributions**

### LFU Distribution (Summer)



### Additional Discussion on the 2024 LFU Models

The Load Forecast Uncertainty (LFU) models measure the load response to weather at high peak-producing temperatures and describe the variability in peak-day load caused by the uncertainty in peak-day weather. Other sources of uncertainty such as economic growth are not captured in LFU modeling. However, economic uncertainty is relatively small compared to temperature uncertainty one year ahead. As a result, the LFTF, the NYISO, and the ICS have agreed that it is sufficient to confine the LFU one year ahead to weather alone.


LFU multipliers are largely driven by the slope of load vs. temperature, or the weather response of load. If the weather response of load increases, the slope of load vs. temperature will increase, and the upper-bin LFU multipliers (Bins 1-3) will increase. The 2023 LFU multipliers include summer 2022 data. Based upon the updated data and LFU modeling, the summer load response to weather at high temperatures was flatter in Zones F&G, Zones H&I, and Zone J, resulting in lower LFU multipliers at the upper bins relative to the prior IRM study. The summer load response to weather at high temperatures was steeper in Zones A-E and Zone K, resulting in higher Bin 1 LFU multipliers relative to the prior IRM study.

The Con Edison and Orange & Rockland peak load forecasts are based on peak weather conditions with a 1-in-3 probability of occurrence (67th percentile). All other Transmission Owners design their forecasts at a 1-in-2 probability of occurrence (50th percentile). The resulting design conditions are 50<sup>th</sup> percentile for the A-to-E and Zone K LFU areas, above 50<sup>th</sup> percentile for Zones F&G and Zones H&I, and 67<sup>th</sup> percentile for Zone J. The NYCA aggregate design condition reflected in the winter LFU multipliers is the 57<sup>th</sup> percentile.

### LFU Bin Z-Values

Beginning with the LFU models used in the 2022 IRM Study, LFU bin centers are based on Z-values which divide the area of each bin equally. In prior LFU modeling, bin centers were defined using the x-axis, equidistant from the upper and lower bounds of each bin based on the Z-value. The equal-area Z-values reflect an improved representation of the LFU multiplier's probability of occurrence. The comparison between equidistant and equal area based bin structure is shown in Figure A.3.

Figure A.3 Bin Centers (Equidistant v. Equal Area)



Review of Historical Zonal Load Shapes for Load Bins


Beginning with the 2014 IRM Study, multiple years of historical load shapes were assigned to the load forecast uncertainty bins. Three historical years were selected from those available, as discussed in the NYISO’s 2013 report, ‘Modeling Multiple Load Shapes in Resource Adequacy Studies’. The year 2007 was assigned to the lowest five bins (from cumulative probability 0% to 93.32%). The year 2002 was assigned to the second highest bin, with a probability of 6.06%. The year 2006 was assigned to the highest bin (bin 1), with a probability of 0.62%.

Following the completion of the LFU Phase 2 analyses, the NYISO recommended and the ICS approved the use of the 2013, 2017, and 2018 load shapes beginning with the 2023 IRM study.

A key finding of LFU Phase 2 was that extreme summers with hot weather and high peak loads typically have steep load duration curves, meaning that daily peak loads drop quickly relative to the summer peak load on a per-unit basis. Based on this finding, the 2013 load shape is assigned to bins 1 and 2 (upper 6.68% probability of occurrence). The 2013 load shape is reflective of a hot summer peak day and a very high peak load level. The 2018 load shape, reflective of fairly typical peak day weather, is assigned to bins 3

and 4 (62.46% probability of occurrence, including the average load level). Finally, the 2017 load shape, reflective of a mild summer, is assigned to bins 5 through 7 (lower 30.85% probability of occurrence). Figure A.4 shows a comparison of the daily load duration curve for the 2002, 2006, 2007, 2013, 2017, and 2018 summers.

**Figure A.4 Per Unit Summer Load Shapes**



An additional LFU Phase 2 recommendation was to properly scale the historical load shapes to reflect the increasing capacity of Behind-the-Meter solar in future years. BTM solar is not modeled as a resource in the 2024 IRM study. Therefore, the 2013, 2017, and 2018 historical load shapes were adjusted by scaling up the underlying BTM solar impacts from those years to reflect the projected 2024 BTM solar capacity. The 2024 IRM Study will thus reflect the average impact of increasing BTM solar penetration on load levels and daily shapes, through use of BTM solar-adjusted historical load shapes.

### A.3.3 Capacity Model

The capacity model includes all NYCA generating units, including new and planned units, as well as units that are physically outside New York State that have met specific criteria to offer capacity in the New York Control Area. The 2023 Load and Capacity Data Report

is the primary data source for these resources. Table A.8 provides a summary of the capacity resource assumptions in the [2024-25](#) IRM study.

**Table A.8 Capacity Resources**

Parameter	2023 Study Assumption	2024 Study Assumption	Explanation
Generating Unit Capacities	<a href="#">2022</a> Gold Book values. Use min (DMNC vs. CRIS) capacity value	<a href="#">2023</a> Gold Book values. Use min (DMNC vs. CRIS) capacity value	<a href="#">2023 Gold</a> Book publication
Planned Generator Units	<a href="#">0 MW of project related new thermal resources or re-ratings.</a>	0 MW of project related new thermal resources or re-ratings.	NYISO recommendation based on documented process <sup>2</sup>
Wind Resources	<a href="#">539.3 MW of Wind Capacity additions totaling 2351.1 MW of qualifying wind</a>	<a href="#">136</a> MW of <a href="#">Offshore</a> Wind Capacity additions totaling <a href="#">2502.3</a> MW of qualifying wind	Renewable units based on RPS agreements, interconnection queue, and ICS input.
Wind Shape	Actual hourly plant output over the period <a href="#">2017-2021</a> . New units will use zonal hourly averages or nearby units.	Actual hourly plant output over the period <a href="#">2018-2022</a> . New units will use zonal hourly averages or nearby units.  <a href="#">Normalized offshore wind shapes as published by NYISO over the period 2017-2021</a>	Program randomly selects a wind shape of hourly production over the years 2017-2022 for each model iteration.
Solar Resources (Grid connected)	<a href="#">0</a> MW of Solar Capacity additions totaling 214.4 MW of qualifying Solar Capacity.	<a href="#">90</a> MW of Solar Capacity additions with solar totaling <a href="#">304.4</a> MW of qualifying installed Solar Capacity.	ICAP Resources connected to Bulk Electric System

<sup>2</sup> The process includes the latest Gold Book publication, NYISO interconnection queue, and generation notifications.

Parameter	2023 Study Assumption	2024 Study Assumption	Explanation
Solar Shape	Actual hourly plant output over the period <u>2017-2021</u> . New units will use zonal hourly averages or nearby units.	Actual hourly plant output over the period <u>2018-2022</u> . New units will use zonal hourly averages or nearby units.	Program randomly selects a solar shape of hourly production over the years <u>2018-2022</u> for each model iteration.
BTM- NG Program	<u>No</u> new BTM NG resources Forecast load adjustment of <u>161.6</u> MW	<u>One new BTM NG recourse: Oxbow (Zone A) – 3.2 MW, with the total of 148.8 MW</u> Forecast load adjustment of <u>148.8</u> MW	Both the load and generation of the BTM:NG Resources are modeled.
Retirements, Mothballed units, and ICAP ineligible units	<u>1,205.2</u> MW of unit deactivations	<u>-140.1</u> MW of unit deactivations	<u>2023</u> Gold Book publication and generator notifications
Forced and Partial Outage Rates	Five-year ( <u>2017-2021</u> ) GADS data for each unit represented. Those units with less than five years – use representative data.	Five-year ( <u>2018-2022</u> ) GADS data for each unit represented. Those units with less than five years – use representative data.	Transition Rates representing the Equivalent Forced Outage Rates (EFORd) during demand periods over the most recent five-year period ( <u>2018-2022</u> )
Planned Outages	Based on schedules received by the NYISO. Removed for the <u>2023</u> IRM study.	Based on schedules received by the NYISO. Not modeled for the 2023 IRM study.	<u>Based on 2021 Final Base Case</u>
Summer Maintenance	Nominal 50 MWs – divided equally between Zones J & K	Nominal 50 MWs – divided equally between Zones J & K	Review of most recent data

Parameter	2023 Study Assumption	2024 Study Assumption	Explanation
Gas Turbine Ambient Derate	De-rate based on provided temperature correction curves.	De-rate based on provided temperature correction curves.	Operational history indicates de-rates in line with manufacturer's curves
Small Hydro Resources	Actual hourly plant output over the period <u>2017-2021</u> .	Actual hourly plant output over the period <u>2018-2022</u> .	Program randomly selects a Hydro shape of hourly production over the years <u>2017-2021</u> for each model iteration.
Large Hydro	Probabilistic Model based on 5 years of GADS data <u>2017-2021</u>	Probabilistic Model based on 5 years of GADS data <u>2018-2022</u>	Transition Rates representing the Equivalent Forced Outage Rates (EFORd) during demand periods over the most recent five-year period (2016-2020)
Energy Limited Resources (ELR)	Based upon elections made by August 1 <sup>st</sup> , <u>2022</u>	Based upon elections made by August 1 <sup>st</sup> , <u>2023</u> .	Existing elections are made by August 1st and will be incorporated into the model.

### (1) Generating Unit Capacities

The capacity rating for each thermal generating unit is based on its Dependable Maximum Net Capability (DMNC). The source of DMNC ratings are seasonal tests required by procedures in the NYISO Installed Capacity Manual. Additionally, each generating resource has an associated capacity CRIS (Capacity Resource Interconnection Service) value. When the associated CRIS value is less than the DMNC rating, the CRIS value is modeled. Wind units are rated at the lower of their CRIS value or their nameplate value in the model. The 2023 NYCA Load and Capacity Report, issued by the NYISO, is the source of those generating units and their ratings included on the capacity model.

### (2) Planned Generator Units

There are 0 MW of new thermal units and unit re-ratings (summer ratings).

### (3) Wind Modeling

Wind generators are modeled as hourly load modifiers using hourly production data over the period 2018-2022. Each calendar production year represents an hourly wind shape for each wind facility from which the GE MARS program will randomly select. New units will use the zonal hourly averages of current units within the same zone. As shown in table A.9, a total of 2486.5 MW of installed capacity is associated with wind generators.

**Table A.9 Wind Generation**

Wind				
Resource	Zone	CRIS (MW)	Summer Capability (MW)	MARS Modeled Capability**
Bliss Wind Power [WT]	A	100.5	100.5	100.5
Canandaigua Wind Power [WT]	C	125.0	125.0	125.0
High Sheldon Wind Farm [WT]	C	112.5	118.1	112.5
Howard Wind [WT]	C	57.4	55.4	55.4
Orangeville Wind Farm [WT]	C	94.4	93.9	93.9
Wethersfield Wind Power [WT]	C	126.0	126.0	126.0
Altona Wind Power [WT]	D	97.5	97.5	97.5
Chateaugay Wind Power [WT]	D	106.5	106.5	106.5
Clinton Wind Power [WT]	D	100.5	100.5	100.5
Ellenburg Wind Power [WT]	D	81.0	81.0	81.0
Jericho Rise Wind Farm [WT]	D	77.7	77.7	77.7
Marble River Wind [WT]	D	215.2	215.2	215.2
Hardscrabble Wind [WT]	E	74.0	74.0	74.0
Madison Wind Power [WT]	E	11.5	11.6	11.5
Maple Ridge Wind [WT01]	E	231.0	231.0	231.0
Maple Ridge Wind [WT02]	E	90.7	90.8	90.7
Munnsville Wind Power [WT]	E	34.5	34.5	34.5
Arkwright Summit Wind Farm [WT]	A	78.4	78.4	78.4
Eight Point Wind Energy Center [WT]	C	101.2	111.2	101.2
Bluestone Wind [WT]	E	111.8	111.8	111.8
Number 3 Wind Energy [WT]	E	103.9	103.9	103.9
Ball Hill Wind [WT]	A	100.0	100.0	100.0
Baron Winds [WT]	C	300.0	121.8	121.8
South Fork Wind Farm (Off-Shore)	K	96.0	96.0	96.0
South Fork Wind Farm II (Off-Shore)	K	40.0	40.0	40.0
<b>Total</b>		<b>2667.2</b>	<b>2502.3</b>	<b>2486.5</b>

### (4) Solar Modeling

Solar generators are modeled as hourly load modifiers using hourly production data over the period 2018-2022. Each calendar production year represents an hourly solar shape for each solar facility which the GE MARS program will randomly select from. A total of 304.4 MW of solar capacity was modeled.

#### (5) Retirements/Deactivations/ ICAP Ineligible

There are 6 units totaling -140.1 MW that were in the 2023 study that are modeled as being deactivated for the 2024 study.

#### (6) Unforced Capacity Deliverability Rights (UDRs)

The capacity model includes UDRs, which are capacity rights that allow the owner of an incremental controllable transmission project to provide locational capacity benefits. Non-locational capacity, when coupled with a UDR to deliver capacity to a Locality, can be used to satisfy locational capacity requirements. The owners of the UDRs elect whether they will utilize their capacity deliverability rights on a confidential basis by August 1<sup>st</sup> for the upcoming capability year - i.e., August 1, 2023 for the Capability Year beginning on May 1, 2024. This decision determines how this transfer capability will be represented in the MARS model. The IRM modeling accounts for both the availability of the resource that is identified for each UDR line as well as the availability of the UDR facility itself. The following facilities are represented in the 2023 IRM Study as having UDR capacity rights: LIPA's 330 MW High Voltage Direct Current (HVDC) Cross Sound Cable, LIPA's 660 MW HVDC Neptune Cable, and the 315 MW Linden Variable Frequency Transformer. The owners of these facilities have the option, on an annual basis, of selecting the MW quantity of UDRs they plan on utilizing for capacity contracts over these facilities. Any remaining capability on the cable can be used to support emergency assistance, which may reduce locational and IRM capacity requirements. The 2024 IRM Study incorporates the confidential elections that these facility owners made for the 2024-25 Capability Year. Hudson Transmission Partners 660 MW HVDC Cable has been granted UDR rights but has lost its right to import capacity and therefore is modeled as being fully available to support emergency assistance.

#### (7) Energy Limited Resources

The capacity model now includes Energy Limited resources (ELR). The NYISO filed, and FERC approved, tariff changes that enhance the ability of duration limited resources to participate in the NYISO markets. These rules allow output limited resources to participate in the markets consistent with those limitations and requires owners of those resources to inform the NYISO of their elected energy output duration limitations. Effective May 1, 2021, generation resources may participate in an Energy Limited Resource (ELR) program administered by the NYISO. Under this program, participating generators were required to submit their elected limitations to the NYISO on a confidential basis by August 1<sup>st</sup> for the upcoming capability year - i.e., August 1, 2023 for the Capability Year beginning on May 1, 2024.

## (8) Performance Data

Performance data for thermal generating units in the model includes forced and partial outages, which are modeled by inputting a multi-state outage model that is representative of the “equivalent demand forced outage rate” (EFORd) for each unit represented. Generation owners provide outage data to the NYISO using Generating Availability Data System (GADS) data in accordance with the NYISO Installed Capacity Manual. The NYSRC is continuing to use a five-year historical period for the [2024 IRM Study](#).

Figure A.5 shows a rolling 5-year average of the same data.


Figures A.6 and A.7 show the availability trends of the NYCA broken out by fuel type.

The multi-state model for each unit is derived from five years of historic events if it is available. For units with less than five years of historic events, the available years of event data for the unit is used if it appears to be reasonable. For the remaining years, the unit NERC class-average data is used.

The unit forced outage states for the most of the NYCA units were obtained from the five-year NERC GADS outage data collected by the NYISO for the years 2016 through 2020. This hourly data represents the availability of the units for all hours. From this, full and partial outage states and the frequency of occurrence were calculated and put in the required format for input to the GE-MARS program.

Figures A.8 and A.9 show the unit availabilities of the entire NERC fleet on an annual and 5-year historical basis.

Figure A.5 Five-Year Weighted Annual Average Zonal EFORds



The resources included in the calculation of these values include thermal, large hydro, wind, solar, landfill gas, and run-of-river resources with CRIS.

Figure A.6 NYCA Annual Weighted Average Availability




Figure A.7 NYCA Five-Year Weighted Average Availability




Figure A.8 NERC Weighted Annual Average Availability





Figure A.9 NERC Five-Year Weighted Average Availability



#### (9) Outages and Summer Maintenance

For the 2022 IRM Study, planned and scheduled maintenance was removed because it caused excess EOP usage. This had no impact on LOLE or IRM. ~~For Like~~ the 2023 IRM study, the 2024 IRM study the planned and scheduled maintenance was not modeled. The nominal 50 MWs of summer maintenance, however, remained constant. The amount is nominally divided equally between Zone J and Zone K.

#### (10) Gas Turbine Ambient De-rate

Operation of combustion turbine units at temperatures above DMNC test temperature results in reduction in output. These reductions in gas turbine and combined cycle capacity output are captured in the GE-MARS model using de-ratings based on ambient temperature correction curves. Based on the past reviews of historical data, no changes to the existing combined cycle temperature correction curves are proposed by the NYISO staff~~Based on its review of historical data, the NYISO staff has concluded that the existing combined cycle temperature correction curves are still valid and appropriate.~~ These temperature corrections curves, provided by the Market Monitoring Unit of the NYISO, show unit output versus ambient temperature conditions over a range starting at 60 degrees F to over 100 degrees F. Because generating units are required to report their DMNC output at peak or “design” conditions (an average of temperatures obtained at the time of the transmission district previous four like capability period load peaks), the temperature correction for the combustion turbine units is derived for and applied to temperatures above transmission district peak loads.

#### (11) Large Hydro De-rates

Hydroelectric projects are modeled consistent with the treatment of thermal units, with a probability capacity model based on five years of unit performance. Except in the case where an election such as ELR status would override the unit being modeled as a thermal unit. See Table A.8 above entitled: Capacity Resources.

### **A.3.4 Transmission System Model**

A detailed transmission system model is represented in the GE-MARS topology. The transmission system topology, which includes eleven NYCA Zones and four External Control Areas, along with transfer limits, is shown in Figure A.10. The transfer limits employed for the 2024-2025 IRM Study were developed from emergency transfer limit analyses included in various studies performed by the NYISO and based upon input from Transmission Owners and neighboring regions. The NYISO’s Transmission Planning and Advisory Subcommittee (TPAS) also reviewed and approved the topology. A list of those studies is shown in Table A.10, below. The transfer limits are further refined by other

assessments conducted by the NYISO. The assumptions for the transmission model included in the 2024-2025 IRM Study are listed in Table A.10, which reflects changes from last year's model. The changes that are captured in this year's model are: 1) Segment B of AC Transmission project expected to be in service by December 2023 which increases the transfer limits of a number of interfaces; but increases in transfer limits also reflect the delay of the construction of Dover PAR beyond June 2024<sup>3</sup>; 2) a small update to Dysinger East limit and Zone A Group limit as well as Dunwoodie and Y40/50 Group limit based on updated assumptions in the applicable planning study; 3) changes to various LIPA transfer limits based on updated transfer assumptions between LI and NYC, as well as decreases in load in the West of Newbridge area.

Forced transmission outages are included in the GE-MARS model for the underground cables that connect New York City and Long Island to surrounding Zones. The GE-MARS model uses transition rates between operating states for each interface, which were calculated based on the probability of occurrence from the most recent five years of historic failure rates and the time to repair. Transition rates into the different operating states for each interface were calculated based on the circuits comprising each interface, including failure rates and repair times for the individual cables, and for any transformer and/or phase angle regulator associated with that cable. The TOs provided updated transition rates for their associated cable interfaces.

---

<sup>3</sup> The delay of Dover PAR construction results in reduction in the transfer limits of Central East, Central East + Marcy South group, as well as UPNYSYNY, compared to the full in service of AC transmission condition. The UPNYSYNY transfer limit will be reduced by a conservative reduction of up to 750MW. The NYISO tested various scenarios of the UPNYSYNY transfer limit and concluded that the transfer limit reduction on UPNYSYNY is not expected to impact the IRM study results. Therefore, the UPNYSYNY interface limit is modeled as if the Segment B of AC Transmission project is fully in service.


**Table A.10 Transmission System Model**

<u>Parameter</u>	<u>2023 Model Assumptions</u>	<u>2024 Model Assumptions Recommended</u>	<u>Basis for Recommendation</u>
<u>UPNY-ConEd Interface Limit</u>	<u>Zone G to H transfer limit ay 6675</u>	<u>Zone G to H transfer limit increase to 7050</u>	<u>Segment B of AC Transmission in service</u>
<u>West-Central NY Limits</u>	<u>Zone A export limit – 2650 Zone A to B limit – 2200 Zone B to C limit – 1500 Zone C to B limit – 2275</u>	<u>Zone A to B limit reduced to 2100 and Zone A export limit reduced to 2500</u>	<u>Aligned with updated planning study assumptions for year 2024</u>
<u>Cedars Import Limit</u>	<u>1770 of import Capability to Zone D from Chateauguay</u>	<u>No modeling change from the 2022 assumption</u>	<u>Based on the most recent NYISO studies and processes, such as Operating Study, Operations Engineering Voltage Studies, Comprehensive System Planning Process, and additional analysis including interregional planning initiatives.</u>
<u>IESO/NYISO PARS in Zone D</u>	<u>Restore the transfer limits between IESO and NYCA to the full 300</u>	<u>No modeling change from the 2023 assumption</u>	<u>The outage impacting phase shifters L33/34P is expected to end by Summer 2023</u>
<u>Central East and Central East + Marcy Group Transfer Limit</u>	<u>Central East Dynamic limit table ranging from 22645 to 2356 MWs. Central East + Marcy Group Dynamic Limit table ranging from 4260 to 3845 MWs</u>	<u>Central East dynamic limit table ranging from 3885 to 3470 MWs Central East + Marcy Group dynamic limit table ranging from 5590 to 4945 MWs</u>	<u>Impact from the construction of Segment B Project, as well as the delay of the construction of Dover PAR (of AC Transmission Project).</u>
<u>UPNYSENY Transfer Limit</u>	<u>Upstate to downstate transfer limit at 5250 MW; dynamic limit table ranging from 5350 to 5250 MWs</u>	<u>Upstate to downstate transfer limit increase to 7150 MW; dynamic limit table removed</u>	<u>Segment B of the AC Transmission Project in service; delay of Dover PAR construction is assessed but no change to the modeled transfer limits<sup>4</sup></u>
<u>Neptune UDR Import Limit Restoration</u>	<u>Restore the import limit from the Neptune UDR to the full 660</u>	<u>No modeling change from the 2023 assumption</u>	<u>The transformer is expected to return to service during the 2023 capability year</u>

<sup>4</sup> Due to the delay of the construction of Dover PAR, the UPNYSENY transfer limit will be reduced by a conservative reduction of up to 750MW. The NYISO tested various scenarios of the UPNYSENY transfer limit and concluded that the transfer limit reduction on UPNYSENY is not expected to impact the IRM study results.

<p><u>LIPA Dynamic Ratings</u></p>	<p><u>Jamaica Ties import limit at 320 MW;</u>  <u>ConEd-LIPA import limit at 1613 MW;</u>  <u>ConEd-LIPA export limit at 135 MW;</u>  <u>Y49/Y50 Export limit at 420 MW;</u>  <u>LI-West export limit at 49 MW;</u>  <u>ConEd-LIPA Dynamic Rating table for Zone K to I and J at 130/0 MW</u></p>	<p><u>Jamaica Ties import limit reduced to 305 MW;</u>  <u>ConEd-LIPA import limit reduced to 1598 MW;</u>  <u>ConEd-LIPA export limit increased to 170 MW;</u>  <u>Y49/Y50 Export limit increased to 460 MW;</u>  <u>LI-West export limit increased to 84 MW;</u>  <u>ConEd-LIPA Dynamic Rating table for Zone K to I and J increased to 170/15 MW</u></p>	<p><u>Revised limits based on updated transfer assumptions between LI and NYC, as well as decreases in load in the West of New Bridge area which lower the thermal loading on LI internal transmission facilities.</u></p>
<p><u>Cable Forced Outage Rates</u></p>	<p><u>All existing Cable EFORs updated for NYC and LI to reflect most recent five-year history</u></p>	<p><u>All existing Cable EFORs updated for NYC and LI to reflect most recent five-year history</u></p>	<p><u>Based on TO analysis or NYISO analysis where applicable</u></p>
<p><u>UDR line Unavailability</u></p>	<p><u>Five-year history of forced outages</u></p>	<p><u>Five-year history of forced outages</u></p>	<p><u>NYISO/TO review</u></p>

Figure A.10 2024 IRM Topology



Notes

1. PJM to NY emergency assistance (EA) assumption for calculating the PJM-NY Western ties, PJM-G Group, and ABC Line Group flow distribution limit: 1500MW
2. NYCA EA simultaneous import limit: 3,500 MW
3. External areas representation based upon information received from the NPCC CP-8 WG

Legend

- ↔ Interface
  - Unidirectional Interface
  - ↔ Interface w/ Dynamic Ratings
  - Interface Group
  - Interface Group w/ Dynamic Ratings
  - - - Monitoring Interface Group
  - / - NYCA EA Interface Group Marker
  - xx "Dummy Bubble" i.e. no load
- NOTE: An interface is considered to not have a MW limitation if no number is specified

\* Due to the delay of the construction of Dover PAR, the UPNYSENY transfer limit will be reduced by a conservative reduction of up to 750MW. The NYISO tested various scenarios of the UPNYSENY transfer limit and concluded that the transfer limit reduction on UPNYSENY is not expected to impact the IRM study results.

Table A.11 shows the interface limits including dynamic limits used in the 2024 IRM study topology VS. the 2023 IRM study.

**Table A.11 Interface Limits Updates**

Interface	2023		2024		Delta	
	Forward	Reverse	Forward	Reverse	Forward	Reverse
<u>Zone A to B</u>	<u>2200</u>	<u>-</u>	<u>2100</u>	<u>-</u>	<u>-100</u>	<u>-</u>
<u>Zone A Export Limit</u>	<u>2650</u>	<u>-</u>	<u>2500</u>	<u>-</u>	<u>-150</u>	<u>-</u>
<u>Zone B to C</u>	<u>1500</u>	<u>2275</u>	<u>1500</u>	<u>2275</u>	<u>0</u>	<u>0</u>
<u>Chateaguay to Zone D</u>	<u>1770</u>	<u>1000</u>	<u>1770</u>	<u>1000</u>	<u>0</u>	<u>0</u>
<u>Central East</u>	<u>2645/2640/2585/2530/2440/2365</u>	<u>-</u>	<u>3885/3805/3725/3640/3540/3460</u>	<u>-</u>	<u>1240/1165/1140/1110/1100/1095</u>	<u>-</u>
<u>Central East + Marcy Group</u>	<u>4260/4260/4185/4100/3970/3845</u>	<u>-</u>	<u>5590/5475/5360/5235/5080/4945</u>	<u>-</u>	<u>1330/1215/1175/1135/1110/1100</u>	<u>-</u>
<u>UPNYSENY</u>	<u>5250; dynamic limits range from 5350 to 5250</u>		<u>7150; No dynamic limits</u>		<u>1900; Removal of dynamic limits</u>	
<u>Zone K to Zones I and J Group</u>	<u>1613</u>	<u>135/130 /0</u>	<u>1598</u>	<u>170/170/ 15</u>	<u>0</u>	<u>35/30/15</u>

The Topology for the 2024 IRM Study features the three major changes from the 2023 IRM Study.

1. In service of Segment B of AC Transmission Project, but with delay in the construction of the Dover PAR:
  - The Central East voltage collapse limit increases from 2654 MW to 3885 MW; dynamic limits are also increased by a similar amount. These limits are calculated by bypassing the series compensation at Knickerbocker and Dover PAR due to the delay of the construction.
  - The Central East + Marcy Group limit is increased from 4260 MW to 5590 MW due to the improvement of Central East voltage collapse limit; dynamic limits are also increased by a similar amount. These limits are calculated with the bypassing of the series compensation at Knickerbocker and Dover PAR due to the delay of the construction.
2. The UPNY-ConEd limit increases from 6675 MW to 7050 MW. The delay of the Dover PAR construction has no impact on the increase in transfer limit for UPNY-ConEd interface.
  - The UPNYSENY limit increases from 5250 MW to 7150 MW, with the removal of dynamic limits. Due to the delay of the construction of Dover PAR, the UPNYSENY

transfer limit will be impacted by a conservative reduction of up to 750MW, from the 7150 MW. Various scenarios of the UPNYSENY transfer limit reduction have been tested and it was concluded that the transfer limit reduction on UPNYSENY is not expected to impact the IRM study results.

### 3. Updates to Dysinger East and Zone A Group Limits:

The Dysinger East and Zone A Group limits were updated as follows

- Dysinger East limit is reduced from 2200 MW to 2100 MW. Zone A group limit is reduced from 2650 MW to 2500 MW. Both updates are based on the updated Year 2024 assumptions in the planning study.

### 4. Updates to Zone K Transfer Limits:

Based on study conducted by PSEG LI, the updates in the transfer assumptions between NYC and LI and the reduced load in West of New Bridge area result in the changes in various transfer limits around Zone K:

- Jamaca Ties import limit decreases from 320 MW to 305 MW
- Coned-LIPA import limit decreases from 1613 MW to 1598 MW
- ConEd-LIPA export limit increases from 135 MW to 170 MW
- Y49/Y50 export limit increases from 420 MW to 460 MW
- LI West export limit increases from 49 MW to 84 MW

Additional topology changes were made to the external area models in accordance with information received through the NPCC CP-8 working group.

#### **A.3.5 External Area Representations**

NYCA reliability depends in part on emergency assistance from its interconnected Control Area neighbors (New England, Ontario, Quebec and PJM) based on reserve sharing agreements with these external Control Areas. Load and capacity models of these Areas are therefore represented in the GE-MARS analyses with data received directly from the Areas and through NPCC sources.

The primary consideration for developing the final load and capacity models for the external Control Areas is to avoid over-dependence on the external Control Areas for emergency capacity support.

For this reason, a limit is placed on the amount of emergency capacity support that the NYISO can receive from external Control Areas in the IRM study. The 2023 IRM study the limit was 3,500 MW for all LFU bins. value of this limit for this the 2024 IRM study, is the

EA limit has been updated to vary by LFU bin or load level. Based on a study and recommendation from the NYISO<sup>5</sup> recommendation from the ICS and the NYISO that consider the amount of extra reserves that are available in the external Control Areas above an Area's required operating reserve, along with other factors by load level, the 3500 MW limit was modified as follows: LFU Bin 1: 1,470 MW; LFU Bin 2: 2,600 MW; LFU Bin 3-7: 3,500 MW. Also, Interface limits between the NYISO and neighboring Control Areas were adjusted such that the total EA from all Control Areas does not exceed the EA limit by LFU Bin.

In addition, an external Control Area's LOLE assumed in the IRM Study cannot be lower than its LOLE criteria and its Reserve Margin can be no higher than its minimum requirement. If the Area's reserve margin is lower than its requirement and its LOLE is higher than its criterion, pre-emergency Demand Response can be represented. In other words, the neighboring Areas are assumed to be equally or less reliable than NYCA.

Another consideration for developing models for the external Control Areas is to recognize internal transmission constraints within the external Control Areas that may limit emergency assistance to the NYCA. This recognition is considered implicitly for those Areas that have not supplied internal transmission constraint data. Additionally, EOPs are removed from the external Control Area models.

Finally, the top three summer peak load days of an external Control Area should be specified in the load model to be coincident with the NYCA top three peak load days. The purpose of this is to capture the higher likelihood that there will be considerably less load diversity between the NYCA and external Control Areas on the hot summer days.

For this study, both New England and PJM continue to be represented as multi-area models, based on data provided by these Control Areas. Ontario and Quebec are represented as single area models. The load forecast uncertainty model for the outside world model was supplied from the external Control Areas.

Modeling of the neighboring Control Areas in the base case in accordance with Policy 5-17 is as follows:

---

<sup>5</sup> See Installed Capacity Subcommittee Meeting No. 278 — June 28, 2023 — NYSRC Agenda Item 9 "EOP Review Whitepaper Update" and Installed Capacity Subcommittee Meeting No. 279 — August 2, 2023 Agenda Item 13 "EOP Whitepaper Preliminary Recommendations for study details".

Table.12 External Area Representations

Parameter	2023 Study Assumption	2024 Study Assumption	Explanation
Capacity Purchases	Grandfathered amounts: PJM – 1080 MW HQ – 1110 MW All contracts model as equivalent contracts	Grandfathered amounts: PJM – <u>1013</u> MW HQ – <u>1190</u> MW All contracts model as equivalent contracts	Grandfathered Rights, ETCNL, and other FERC identified rights.
Capacity Sales	Long term firm sales of 265.9 MW	Long term firm sales of <u>265.3</u> MW	These are long term federally monitored contracts.
External Area Modeling	Single Area representations for Ontario and Quebec. Five areas modeled for PJM. Thirteen zones modeled for New England	Single Area representations for Ontario and Quebec. Five areas modeled for PJM. Thirteen zones modeled for New England	The load and capacity data are provided by the neighboring Areas. This updated data may then be adjusted as described in Policy 5
Reserve Sharing	All NPCC Control Areas have indicated that they will share reserves equally	All NPCC Control Areas have indicated that they will share reserves equally	Per NPCC CP-8 working group assumption.

Table A.13 shows the final reserve margins and LOLEs for the Control Areas external to NYCA. The 2024 external area model was updated from 2023 but still-with a includes modified a 3,500-MW limit for emergency assistance (EA) imports during any given hour as described above. As per Table 7-1 of the IRM study report, the difference in between the isolated case and the final base case was 4.0% ( to be verified)in 2024 VS. 7.6% in 2023.

Table.13 Outside World Reserve Margins

Area	2023 Study Reserve Margin	2024 Study Reserve Margin	2023 Study LOLE (Event-Days/Year)	2024 Study LOLE (Event-Days/Year)
Quebec	<u>54.7%*</u>	<u>49.7%</u>	<u>0.106</u>	<u>0.120</u>
Ontario	<u>14.6%</u>	<u>5.1%</u>	<u>0.122</u>	<u>0.112</u>
PJM	<u>14.4%</u>	<u>14.7%</u>	<u>0.185</u>	<u>0.405</u>
New England	<u>9.7%</u>	<u>4.4%</u>	<u>0.109</u>	<u>0.113</u>

\*This is the summer margin.

### A.3.6 Emergency Operating Procedures (EOPs)

There are many steps that the system operator can take in an emergency to avoid disconnecting load. EOP steps 2 through 10 listed in Table A.15 were provided by the NYISO based on operator experience. Table A.14 lists the assumptions modeled.

The values in Table A.15 (top of next page) are based on a NYISO forecast that incorporates 2023 (summer) operating results. This forecast is applied against a 2024 peak load forecast of 31,765.632,246.0 MW. The table shows the most likely order that these steps will be initiated. The actual order will depend on the type of the emergency. The amount of assistance that is provided by EOPs related to load, such as voltage reduction, will vary with the load level.

**Table A.14 Assumptions for Emergency Operating Procedures**

Parameter	<u>2023 Study Assumption</u>	<u>2023 Study Assumption</u>	Explanation
Special Case Resources*	<u>July 2022–1224.8 MW based on registrations and modeled as 855.9 MW of effective capacity. Monthly variation based on historical experience.</u>	July <u>2023–1,281</u> MW based on registrations and modeled as <u>896.5</u> MW of effective capacity. Monthly variation based on historical experience.	SCRs sold for the program discounted to historic availability. Summer values calculated from July <u>2023</u> registrations. Performance calculation updated per ICS presentations on SCR performance.
Other EOPs	<u>350 MW of 10-min Operating Reserve maintained at Load Shedding 860.0 MW of non-SCR/non-EDRP resources</u>	<u>400 MW of 10-min Operation Reserve maintained at Load Shedding 929.8 MW of non-SCR/non-EDRP resources</u>	Based on white paper recommendation approved by EC Based on TO information, measured data, and NYISO forecasts
EOP Structure	10 EOP Steps Modeled	10 EOP Steps Modeled	Based on agreement with ICS

- The number of SCR calls is limited to 5 per month when calculating LOLE.

**Table A.15 Emergency Operating Procedures Values**

<u>Step</u>	<u>Procedure</u>	<u>2023 IRM MW Value</u>	<u>2024 IRM MW Value</u>
<u>1</u>	<u>Special Case Resources – Load, Gen</u>	<u>1,224 MW Enrolled/ 860 MW Modeled</u>	<u>1,281 MW Enrolled/ 896.5 MW Modeled</u>
<u>2</u>	<u>5% manual voltage Reduction</u>	<u>85.43 MW</u>	<u>113.11 MW</u>
<u>3</u>	<u>Thirty-minute reserve to zero</u>	<u>655 MW</u>	<u>655 MW</u>
<u>4</u>	<u>Voluntary industrial curtailment</u>	<u>240.05 MW</u>	<u>267.17 MW</u>
<u>5</u>	<u>General Public Appeals</u>	<u>80 MW</u>	<u>74 MW</u>
<u>6</u>	<u>5% remote voltage reduction</u>	<u>452.92 MW</u>	<u>475.56 MW</u>
<u>7</u>	<u>Emergency Purchases</u>	<u>Varies</u>	<u>Varies</u>
<u>8</u>	<u>Ten-minute reserves to zero</u>	<u>960 MW (350 MW maintained at load shedding)</u>	<u>910 MW (400 MW maintained at load shedding)</u>
<u>9</u>	<u>Customer disconnections</u>	<u>As needed</u>	<u>As needed</u>
<u>10</u>	<u>Adjustment used if IRM is lower than technical study margin</u>	<u>As needed</u>	<u>As needed</u>

### **A.3.7 Locational Capacity Requirements**

The GE-MARS model used in the IRM study provides an assessment of the adequacy of the NYCA transmission system to deliver assistance from one Zone to another for meeting load requirements. Previous studies have identified transmission constraints into certain Zones that could impact the LOLE of these Zones, as well as the statewide LOLE. To minimize these potential LOLE impacts, these Zones require a minimum portion of their NYCA ICAP requirement, *i.e.*, locational ICAP, which shall be electrically located within the Zone to ensure that enough energy and capacity are available in that Zone and that NYSRC Reliability Rules are met. For the purposes of the IRM study, Locational ICAP requirements are applicable to two transmission-constrained Zones, New York City and Long Island, and are normally expressed as a percentage of each Zone’s annual peak load.

These locational ICAP requirements, recognized by NYSRC Reliability Rule A.2 and monitored by the NYISO, supplement the statewide IRM requirement. This report using the unified methodology determines the minimum locational requirements for different levels of installed reserve. The NYSRC chooses the IRM to be used for the coming year and the NYISO chooses the final value of the locational requirements to be met by the LSEs.

### A.3.8 Special Case Resources

Special Case Resources (SCRs) are loads capable of being interrupted, and distributed generators, rated at 100 kW or higher, that are not directly telemetered. SCRs are ICAP resources that only provide energy/load curtailment when activated in accordance with the NYISO Emergency Operating Manual. Performance factors for SCRs are shown in Table A.16:

Table A.16 SCR Performance

For 2024 IRM - Final SCR Model Values							
Program	Super Zone	Superzone Performance Factor	ICS Adjustment Factors		Effective Performance Factor	SCR ICAP MW based on July 2023	Final Model Values MW
			ACL to CBL Factor	Fatigue Factor			
SCR	A-F	87.3%	92.9%	100%	81.1%	719	583
SCR	G-I	77.4%	84.2%	100%	65.1%	84	55
SCR	J	70.6%	74.5%	100%	52.6%	442	233
SCR	K	69.8%	76.2%	100%	53.2%	35	19
<b>Total</b>						<b>1281.0</b>	<b>890</b>
							<b>69.5%</b>

Table A.16 note 1: These values represent no growth from July 2023 ICAP based enrollments. Table A.16 note 2: The Performance Factor is based on the average coincident load (ACL) methodology. Table A.16 note 3: The SCR Adjustment factor (3) captures two different performance derates; 1) Calculated Translation Factor (TF) between ACL and customer baseline load (CBL) values, and the Fatigue Factor (FF=1.00)

GE-MARS model accounts for SCRs as a EOP step and will activate this step before degrading 30-minute reserve capability consistent with the rules for when the program is activated. Both GE-MARS and NYISO operations only activate EOPs in zones where they are capable of being delivered.

SCRs are modeled with monthly values. For the month of July 2023, the registered value is 1281.0 MW. The effective value of 890.0 MW is used in the model.

## A.4 Data Scrub

### A.4.1 GE Data Scrub

General Electric (GE) was asked to review the input data for errors. GE performs a “Data Scrub” which processes the input files and flags data that appears to be out of the ordinary. For example, it can identify a unit with a forced outage rate significantly higher than all the others in that size and type category. If something is found, the NYISO reviews the data and either confirms that it is the right value as is or institutes an update. The results of this data scrub are shown in the table below for the preliminary base case. The results of this data scrub are shown in Table A.17 for the preliminary base case.

Table A.17 GE MARS Data Scrub

2	11 units had changes in capacity that exceeded 10 MW	Change in capacity verified	N	N/A
3	11 units identified with large EFORD changes	These units, part of a larger annual review, were confirmed to be correct	N	N/A
4	12 Interface Limits were found inconsistent	Diagram and dynamic limits in Assumptions Matrix were corrected; data base was confirmed to be correct	N	N/A
4	Energy, even though not an explicit IRM assumption, appears higher in the model, for the base study year, than gold book forecast	A known effect of growing historical load shapes to meet future peaks. Initiative underway to study alternatives	N	N/A
5	EOP values were updated for steps 2, 3 and 5	Verified update to 2023 model	Y	N/A

### A.4.2 NYISO Data Scrub

The NYISO also performs a review of the MARS data independently from GE. The result of this review is listed below

Table A.18 NYISO Data Scrub

Item	Description	Disposition	Data Change	Post PBC Effect
1	Unit EFORD values in Master Spreadsheet were incorrect	Values were aligned with the mif and GADS transition rates	Y	See Total
2	Capacity values for BTM:NG units were using the load impact instead of resource values	Resource values were re-aligned properly	Y	See Total
3	Intermittent resources were not using the correct resource value or in the correct location	Values in the master input file are now properly aligned	Y	See Total
4	Resource value for one wind unit was misrepresented in the master spreadsheet	Values in the master spreadsheet are now properly aligned	Y	See Total
			<b>Total</b>	<b>+0.3%</b>

### A.4.3 Transmission Owner Data Scrub

In addition to the above reviews, two transmission owners scrub the data and assumptions using a masked database provided by the NYISO. Their findings are listed below.

Table A.19 Transmission Owner Data Scrub

Item	Description	Disposition	Data Change	Post PBC Effect
1	The Neptune cable rating was misaligned with real rating (650 MW vs 660 MW)	Values were aligned with expectations	Y	0.0%
2	The Cross-Sound Cable line ratings were reversed in the mif (100 MW import to LI, 330 MW export)	Values were re-aligned and Tan45 re-run	Y	-0.3%

# **Appendix B**

## **Details of Study Results**

## B. Details for Study Results – Appendix B

### B.1 Sensitivity Results

Table B.1 summarizes the 2024-2025 Capability Year IRM requirements under a range of assumption changes from those used for the base case. The base case utilized the computer simulation, reliability model, and assumptions described in Appendix A. The sensitivity cases determined the extent of how the base case required IRM would change for assumption modifications, either one at a time, or in combination. The methodology used to conduct the sensitivity cases was to start with the preliminary base case 23.0% IRM results then add or remove capacity from all zones in NYCA until the NYCA LOLE approached criterion. The values in Table B.1 on top of next page are the preliminary base case sensitivity results adjusted to the 23.1% final base case.

In addition to showing the IRM requirements for various sensitivity cases, Table B.1 shows the Loss of Load Hours (LOLH) and Expected Unserved Energy (EUE) reliability metrics for each case<sup>6</sup>. These two metrics, along with the LOLE metric, are important measures of reliability risk in that together, they describe the frequency, duration, and magnitude of loss of load events. The reliability risk measures provided by these two metrics, in addition to IRM impacts, provide Executive Committee members with different aspects of system risk for selecting the Final IRM. The data used to calculate LOLH and EUE are collected from GE-MARS output.

Table 7-1 shows the IRM requirements for the various sensitivity cases. Note, Case 0 was the original Preliminary Base Case. All of the sensitivity cases are relative to that. Case 6a with the reduced Emergency Assistance (EA) from neighboring systems was then selected for the new base case and the resulting 23.1% IRM. Because of the lengthy computer run time and personnel needed to perform a full Tan 45 analysis in IRM studies, this method was applied for only select cases as noted in the table. While the parametric analyses are broadly indicative of magnitude and direction of the IRM impacts, it should be recognized that some accuracy is sacrificed when a Tan 45 analysis is not utilized.

These two metrics, along with the LOLE metric, are important measures of reliability risk in that together, they describe the frequency, duration, and magnitude of loss of load events. The reliability risk measures provided by these two metrics, in addition to IRM impacts, provide

---

<sup>6</sup> **LOLH: Loss of Load Hours:** The expected number of hours during loss of load events each year when the system’s hourly demand is projected to exceed the generating capacity.

**EUE: Expected Unserved Energy:** The expected amount of energy (MWh) during loss of load events that cannot be served each year.

Executive Committee members with different aspects of system risk for selecting the Final IRM. The data used to calculate LOLH and EUE are collected from GE-MARS output.

Sensitivity Cases 1 through 5 in Table 7-1 are annually performed and illustrate how the IRM would be impacted if certain major IRM study parameters were not represented in the IRM base case. Case 4, No Wind Capacity, was split into two cases so that the impact of land-based and off-shore wind generation could be evaluated separately.

Case 6 examines the impact of reduced Emergency Assistance (EA) from neighboring systems based on the recommendations from the analysis in the EOP Whitepaper. Case 6b further reduced the winter limits to zero. As mentioned previously, Case 6a was subsequently selected as the new base case going forward. The various versions of Case 7 look at reducing winter capacity due to potential gas constraints. Finally, Case 8 looked at the impact of the delay on the installation of the Dover PAR. While some limits were affected the overall impact on the IRM was negligible.

**Table B.1 Sensitivity Case Result**

Case	Description	IRM (%)	NYC (%)	LI (%)	IRM (%) Change from Base	LOLH (hrs/yr)	EUE (MWh/yr)
0	2024 IRM Preliminary Base Case	20.8	72.7	109.9	-	0.33711	180.827
	These are the Base Case technical results derived from knee of the IRM-LCR curve						
1	NYCA Isolated	27.0	77.2	116.2	+6.2	0.30757	195.821
	Track Total NYCA Emergency Assistance – NYCA system is isolated and receives no emergency assistance from neighboring control areas (New England, Ontario, Quebec, and PJM). UDRs are allowed						
	2	No Internal NYCA transmission constraints	18.8	71.3	107.9	-2.0	0.34624
Track level of NYCA congestion with respect to the IRM model – internal transmission constraints are eliminated and the impact of transmission constraints on statewide IRM requirements is measured							
3	No Load Forecast Uncertainty	15.7	69.1	104.7	-5.1	0.25842	59.361
	Shows sensitivity of IRM to load uncertainty, if the forecast peak loads for NYCA have a 100% probability of occurring						
4a	No Wind Capacity – Land-Based Wind Only	15.1	72.7	109.9	-5.7	0.34157	185.615
	Shows wind impact for the land-based wind units and can be used to understand EFORD sensitivity (A – F Shifting)						

Case	Description	IRM (%)	NYC (%)	LI (%)	IRM (%) Change from Base	LOLH (hrs/yr)	EUE (MWh/yr)
6a	EOP (Emergency Operating Procedures) Whitepaper Recommendation	23.0	72.4	109.5	+2.2	0.36814	227.886
	Shows impact of modifying Emergency Assistance (EA) from neighboring areas modeled during the EOP steps in accordance with the EOP Whitepaper recommendation (Tan45)						
6b	EOP Whitepaper Recommendation plus Winter EA Zeroed Out	23.0	72.4	109.5	- (Based off 6a)	0.36823	227.895
	Built upon Sensitivity 6a, shows impact of reducing EA from neighboring areas to 0 in winter						
7a-1	Winter Constraints plus S06a (3,500 MW)	23.0	72.4	109.5	- (Based off 6a)	0.36814	227.886
	Shows impact to reliability when winter capacity is reduced due to gas constraints and can be used to understand tightening winter conditions						
7a-2	Winter Constraints plus S06a (7,000 MW)	23.1	72.4	109.6	+0.1 (Based off 6a)	0.36537	224.831
	Shows impact to reliability when winter capacity is reduced due to gas constraints and can be used to understand tightening winter conditions						
7b-1	Winter Constraints plus S06b (3,500 MW)	23.0	72.4	109.5	- (Based off 6b)	0.36824	227.898

## B.2 Frequency of Implementing Emergency Operating Procedures

In addition to SCRs, the NYISO will implement several other types of EOPs, such as voltage reductions, as required, to avoid or minimize customer disconnections. Projected 2024 EOP capacity values are based on recent actual data and NYISO forecasts. SCR calls were limited to 5 per month. Table B.2 below presents the expected EOP frequencies for the 2024-25 Capability Year assuming the 23.1% base case IRM with ELR modeling. Table B.3 top of next page presents SCR calls by months.

**Table B.2 Implementation of EOP steps**

<u>Step</u>	<u>EOP</u>	<u>Expected Implementation (Days/Year)</u>
<u>1</u>	<u>Require SCRs (Load and Generation)</u>	<u>8.1</u>
<u>2</u>	<u>5% manual voltage reduction</u>	<u>6.1</u>
<u>3</u>	<u>30-minute reserve to zero</u>	<u>5.9</u>
<u>4</u>	<u>Voluntary load curtailment</u>	<u>2.8</u>
<u>5</u>	<u>Public appeals</u>	<u>2.2</u>
<u>6</u>	<u>5% remote controlled voltage reduction</u>	<u>2.0</u>
<u>7</u>	<u>Emergency purchases</u>	<u>1.4</u>
<u>8</u>	<u>10-minute reserve to 400 MW</u>	<u>0.2</u>
<u>9</u>	<u>Customer disconnections</u>	<u>0.1</u>

Note 1: The expected implementation days per year reported in each EOP step are the expected number of days that MARS calls for that EOP step. If an EOP step has a limitation on the number of days that it can provide load relief, such as the 5 days per month limit for SCRs, it will provide no load relief after the 5<sup>th</sup> day.

**Table B.3 SCR Calls Per Month**

<u>SCR Calls Per Month</u>	
<u>Month</u>	<u>Days/Month</u>
<u>JAN</u>	<u>0.0</u>
<u>FEB</u>	<u>0.0</u>
<u>MAR</u>	<u>0.0</u>
<u>APR</u>	<u>0.0</u>
<u>MAY</u>	<u>0.0</u>
<u>JUN</u>	<u>0.4</u>
<u>JUL</u>	<u>2.6</u>
<u>AUG</u>	<u>3.5</u>
<u>SEP</u>	<u>1.6</u>
<u>OCT</u>	<u>0.0</u>
<u>NOV</u>	<u>0.0</u>
<u>DEC</u>	<u>0.0</u>

### **B.3 LOLE Max & Mins Plus Outage Magnitudes and Durations**

## **Appendix C**

# **Impact of Environmental Regulations**

## **C. Impact of Environmental Regulations- Appendix C (Being Updated by NYISO Staff)**

Federal, state, and local government regulatory programs may impact the operation and reliability of New York's bulk power system. Compliance with state and federal regulatory initiatives and permitting requirements may require investment by the owners of New York's existing thermal power plants to continue in operation. If the owners of those plants must make significant investments to comply, the cost of these investments could lead to retirements, and therefore new resources may be needed to maintain the reliability of the bulk power system. Other regulatory initiatives being undertaken by the State of New York may preclude certain units from continuing in operation in their current configuration. Prior studies have identified the amounts of capacity that may be negatively impacted by new and developing regulations. Most recently, New York has enacted the Climate Leadership and Community Protection Act (CLCPA) and the Accelerated Renewable Energy Growth and Community Benefit Act and promulgated various regulations collectively intended to limit Greenhouse Gas (GHG) emissions and support the development of new renewable energy, energy storage, and energy efficiency resources. This section reviews the status of various regulatory programs.

### **C.1 Combustion Turbine NO<sub>x</sub> Emission Limits**

The New York State Department of Environmental Conservation (DEC) Part 227-3 significantly lowers NO<sub>x</sub> emission limits for simple cycle gas turbines. The rule will be applicable during the ozone season (May 1- September 30) and establishes lower emission limits in two phases, effective May 1, 2023, and May 1, 2025. The rule requires compliance actions for units with approximately 3,300 MW of capacity (nameplate) located predominantly in southeastern New York and required the owners of affected facilities to file compliance plans by March 2020. The NYISO uses compliance plans submitted by generators under Part 227-3 to develop the assumed outage pattern of the impacted units in the Reliability Planning Process. The plans indicated that approximately 1,100 MW and 1,800 MW of nameplate capacity proposed to be unavailable during the summers of 2023 and 2025, respectively. The rule provides for the continued operation of facilities necessary for compliance with reliability standards for a period of up to two years with the possibility of another two-year period if permanent solutions have been identified but not completed.

## C.2 U.S. Clean Water Act: Best Technology Available for Plant Cooling Water Intake

The U.S. Environmental Protection Agency (EPA) has issued a new Clear Water Act Section 316b rule providing standards for the design and operation of power plant cooling systems. This rule is being implemented by the DEC, which has finalized a policy for the implementation of the Best Technology Available (BTA) for plant cooling water intake structures. This policy is activated upon renewal of a plant’s water withdrawal and discharge permit. Based upon a review of current information available from the DEC, the NYISO has estimated that 13,500 MW of nameplate capacity is affected by this rule, some of which could be required to undertake major system retrofits, including closed-cycle cooling systems.

Plant	Status as of October 2022
Arthur Kill	BTA in place, verification under review
Astoria	BTA in place, verification under review
Barrett	Permit drafting underway with equipment enhancements, SAPA extended
Bowline	BTA in place, 15% Capacity Factor, BTA Decision made, monitoring
Brooklyn Navy Yard	Permit drafting underway
Danskammer	BTA in place
East River	BTA in place
Fitzpatrick	BTA studies being evaluated
Ginna	BTA studies being evaluated
Greenidge	BTA Decision made, installing upgrades
Nine Mile Pt 1	BTA studies being evaluated
Northport	BTA in place, verification under review
Oswego	BTA conditions under review
Port Jefferson	BTA in place, 15% Capacity Factor, verification, SAPA extended
Ravenswood	BTA in place, additional studies under review
Roseton	BTA in place
Wheelabrator Hudson Falls	Technical review
Wheelabrator Westchester	BTA in place

### C.2.1 Part 251: Carbon Dioxide Emissions Limits

The DEC promulgated a rule establishing an emission limit for CO<sub>2</sub> for existing fossil-fueled generating units. New York’s coal-fired generation accounted for less than 1% of the total energy produced in the state in 2019. As of April 2020, all coal-fired generation facilities supplying the New York bulk power system deactivated. NYISO generator deactivation assessments found no reliability needs associated with these deactivations.

## C.3 New York City Residual Oil Elimination

New York City passed legislation in December 2017 that prohibits the combustion of fuel

oil numbers 6 and 4 in electric generators within New York City by 2020 and 2025, respectively. The rule applies to about 3,000 MW of generation in New York City. Affected generators have filed compliance plans with NYC agencies to switch to compliant fuels. The affected generators are developing new fuel storage and handling equipment necessary to convert their facilities to comply with the law.

#### **C.4 Regional Greenhouse Gas Initiative (RGGI)**

RGGI is a multi-state carbon dioxide emissions cap-and-trade initiative that requires affected generators to procure emissions allowances authorizing them to emit carbon dioxide. Through a program review, the RGGI states agreed to several program changes, including a 30% cap reduction between 2020 and 2030, essentially ratcheting down the availability of allowances to generators that emit greenhouse gases. The DEC has issued final regulations incorporating these agreed upon program-wide changes and extending RGGI applicability in New York to certain generators of 15 MW (nameplate) or larger. The proposed emission allowance caps are not likely to trigger reliability concerns as the program design provides for mechanisms that consider reliability on various timescales, including multi-year compliance periods, allowance banking provisions, the Cost Containment Reserve, and periodic program reviews. New Jersey rejoined RGGI in 2020 since withdrawing from the program in 2011 and Virginia began RGGI participation in 2021. The Pennsylvania Department of Environmental Protection has filed final regulations and the states participation is anticipated in the next few years. North Carolina received a petition to consider joining RGGI and has advanced to an ongoing rulemaking process. The RGGI States started a third program review which is anticipated to conclude in early 2023.

#### **C.5 Distributed Generator NO<sub>x</sub> Emission Limits**

The DEC has adopted Part 222, a rule to limit the NO<sub>x</sub> emissions from small behind the meter generators that operate as an economic dispatch source in the New York City Metropolitan Area located at facilities with NO<sub>x</sub> emissions less than 25 tons of NO<sub>x</sub> per year and driven by reciprocating or rotary internal combustion engines. The proposed emission limits will become effective in two phases, May 1, 2021 and May 1, 2025. The facility must either obtain a registration or permit by March 15, 2021 and must notify the DEC whether the generator will operate as an economic dispatch source subject to the provisions of Part 222. The first emission limitations can be achieved by engines manufactured subsequent to 2000 and some subset of older engines.

#### **C.6 Cross-State Air Pollution Rule (CSAPR)**

The CSAPR limits emission of SO<sub>2</sub> and NO<sub>x</sub> from fossil fuel fired EGUs >25 MW in 27 eastern

states by establishing new caps and restricting allowance trading programs. Emissions above the statewide trading limit require additional penalty allowances. NYCA Ozone Season NO<sub>x</sub> emissions are highly sensitive to the continued operation of the NYCA nuclear generation fleet. The USEPA recently promulgated the Revised CSAPR Update which proposes to reduce the ozone season NO<sub>x</sub> budget in 12 of the current CSAPR ozone season states between 2021 and 2024. The budget for New York starts in 2021 at 3,416 tons, but has been adjusted upward across the 2021 ozone season to 4,079 tons. The budget in subsequent ozone seasons will return to 3,416 tons and will drop to 3,403 tons in 2024. 2021 ozone season NO<sub>x</sub> emissions were reportedly 3,997 tons across New York. The CSAPR ozone season occurs May 1-September 30.

### **C.7 Climate Leadership and Community Protection Act (CLCPA)**

The CLCPA requires, among other things, that 70% of electric energy be generated from renewable resources by 2030 and 100% of electric energy be provided by zero emission resources by 2040. The statute will require the displacement of New York's fossil-fueled-fired generating fleet with eligible renewable resources and clean energy resources. During this transition, the NPCC and NYSRC resource adequacy rules will require the New York Control Area to maintain resource adequacy for the New York bulk electric system. In addition, the Greenhouse Gas ("GHG") emission reduction requirements necessitate electrification of the building and transportation sectors to reduce economy-wide emissions. The act builds upon programs and targets already established by the Clean Energy Standard (CES) and in other state policies. The combined set of requirements for new resources are outlined below.

### **C.8 Offshore Wind Development**

The CLCPA requires 9,000 MW of offshore wind (OSW) capacity to be developed by 2035. Previously, the New York PSC issued an order directing that NYSERDA, with the involvement of the Long Island Power Authority (LIPA) and the New York Power Authority (NYPA), to procure OSW RECs (ORECs) from developers for up to 2,400 MW of offshore wind. NYSERDA has executed contracts with the winners of two OREC solicitations for a procurement of four OSW projects totaling nearly 4,300 MW. The PSC authorized NYSERDA to procure an additional 2,000 MW to 4,600 MW of OSW without seeking further Commission approval. NYSERDA issued the 2022 OREC solicitation in July 2022 and expects to announce awards in 2023.

### **C.9 Comprehensive Energy Efficiency Initiative**

The PSC has approved an order containing utility budgets and targets to accelerate energy

efficiency deployment in New York State through 2025. A portion of the 185 TBtu all-fuels energy savings target will come from directed utility programs to expand access to and experience with heat pumps to replace/augment existing conventional heating sources, as well as from increased deployment of more conventional utility energy efficiency programs.

### **C.10 Storage Deployment Target**


The CLCPA requires 3,000 MW of energy storage capacity to be developed by 2030. This target builds on top of the goal to deploy 1,500 MW energy storage capacity by 2025 outlined in NYSERDA's Energy Storage Roadmap. The Department of Public Services reported that 1,230 MW in capacity was deployed, awarded, or contracted at the end of 2021. In early 2022, a doubling of the storage target to 6,000 MW in 2030 was announced.

### **C.11 Distributed Solar Program**

The CLCPA requires 6,000 MW of distributed solar capacity by 2025, which is an expansion of the existing 3,000 MW NY-Sun program. The PSC has been charged with developing the regulatory mechanisms to ensure that the incremental 3,000 MW distributed solar comes online by 2025. Currently, NYSERDA administers the NY-Sun program. On April 14, 2022, the PSC extended NYSERDA's NY-Sun Program, raising the total distributed solar capacity goal to at least 10,000 MW by 2030.

The figure below describes the timing and requirements of the major combined clean energy and efficiency policies in New York State.

## State energy policy goals



The PSC issued an Order Modifying the CES on October 15, 2020 to align the existing Clean Energy Standard with the requirements of the CLCPA. Specifically, the order increased the 2030 Renewable Energy Standard from 50% to 70% and modified the definition of eligible renewable energy resources to align with the CLCPA. The Order authorized the procurement schedules for Tier 1 and Offshore Wind resources needed to achieve the 2030 mandates. The Order also addressed treatment of pre-existing resources by defining criteria for Tier 2 resource solicitations and included a new Tier 4 specifically to recognize incremental renewable energy delivered into Zone J. Tier 4 REC contracts with Champlain Hudson Power Express and Clean Path New York, which were approved on April 14, 2022, have the potential to add approximately 2,500 MW of controllable HVDC connections into New York City.

The CLCPA also implements a new approach to accounting for climate impacts of emissions of various GHGs and setting numerical economy wide GHG limits. The inventory and methodology provide greater weight to the impact of methane emissions relative to the emissions of carbon dioxide and accounts for upstream emissions that occur out-of-state. The 1990 inventory, methodology, and limits were finalized as Part 496 in 2020. The DEC is required under the CLCPA to complete additional regulations to enforce the economy wide GHG limits by 2024. In addition, fossil fuel-fired generation projects face further scrutiny under the CLCPA, which requires state agencies to consider consistency with the statewide GHG emission limits and environmental justice impacts when issuing permits.

The CLCPA created a Climate Action Council (CAC), which is tasked with development and approval of a final scoping plan in 2022. The CAC holds meetings to organize the planning process and convened advisory panels focused on various sectors of the economy (such as power generation, transportation, and energy efficiency and buildings) to perform more detailed evaluations. Starting in 2023, the final scoping plan's recommendations will feed into state planning and regulatory processes which will ultimately impact the supply and demand sides of the power grid.

To inform policymakers, the NYISO and its consultants completed two studies in 2020 examining the impact of the CLCPA targets on the future supply mix needed to match future expected hourly loads. Both the Brattle *Grid in Transition* and the Analysis Group *Climate Change Phase 2 Study* showed the long-term need for emissions-free dispatchable resources to operate during extended periods of reduced renewable resource output. These studies highlighted the need for resources with these characteristics even after including the impact of energy storage and load flexibility in the potential supply demand balance. The studies also imply increasing ramping demands placed on resources primarily to respond to the increased intermittent output of renewable generation and increased variability of electrified heating loads. Recently, the NYISO released the System and Resource Outlook study ("The Outlook"),<sup>7</sup> which continued to evolve and amplify the conclusions from the prior studies. According to the NYISO, the Outlook uses several scenarios to identify potential pathways for transmission and supply investments that will support a reliable transition of the electric grid towards achieving state policy.

### **C.11.1 CLCPA Impact on Air Emission Permits**

On October 27, 2021, the New York State Department of Environmental Conservation (DEC) denied air emission permit modification applications by two existing generators to repower their facilities with new natural gas generators. Danskammer Energy Center is seeking authorization to construct a new natural gas fired combined cycle power generation facility of 536 MW to replace its existing 532 MW generating facility. Astoria Gas Turbine Power, LLC, a subsidiary of NRG Energy, is seeking to construct the Astoria Replacement Project, which would consist of a new simple cycle dual fuel (natural gas and distillate oil) peaking combustion turbine generator of 437 MW. On June 30, 2022, the DEC denied the renewal application for Greenidge Generation's air permits citing CLCPA compliance demonstration. The DEC determined that the projects would be inconsistent or interfere with the attainment of statewide greenhouse gas emission limits established by the Environmental

---

<sup>7</sup> See System and Resource Outlook, A Report from the New York Independent System Operator, available at <https://www.nyiso.com/documents/20142/33384099/2021-2040-Outlook-Report.pdf/a6ed272a-bc16-110b-c3f8-0e0910129ade?t=1663848567361>.

Conservation Law amendments contained in the Climate Leadership and Community Protection Act. The DEC found that the applicants had not provided adequate justification, such as resolution of an electric system reliability need, to overcome the DEC's determination that the air emissions would be inconsistent or interfere with attainment of the CLCPA greenhouse gas emission requirements. The DEC noted that the reliability needs the NYISO identified in its 2020 RNA had been resolved by post RNA updates, and that the announced Tier 4 projects that will significantly increase transmission capacity into New York City. All three projects have begun the DEC administered hearings process to appeal the denials.

### **C.12 Accelerated Renewable Energy Growth and Community Benefit Act**

The Accelerated Renewable Energy Growth and Community Benefit Act was signed into law on April 3, 2020 to assist in the achievement of the clean energy and environmental targets outlined in the CLCPA. This Act requires the PSC to establish new planning processes to enable the transmission and distribution expansion to support the CLCPA targets. On May 14, 2020, the PSC commenced a proceeding to implement the Act with respect to utility-based plans for upgrades to local transmission and distribution needed to support the mandates of the CLCPA. Utilities submitted preliminary upgrade proposals by August 1, 2020. On October 15, 2020, the PSC designated the Northern New York transmission projects as priority transmission projects to be carried out by NYPA. The DPS-led working group filed an Initial Power Grid Study report at the PSC on November 2, 2020. The report addresses local transmission system needs, proposals for planning transparency, accounting for CLCPA benefits in planning and investment criteria, and cost containment, cost allocation and cost recovery mechanisms for transmission projects. The PSC subsequently issued orders approving Phase 1 and Phase 2 projects, and other recommendations from the Study, to meet CLCPA requirements. The utilities continue work to develop a Coordinated Grid Planning Process for local transmission and distribution upgrades to coordinate on grid expansion planning and cost sharing.

The Act also creates an Office of Renewable Energy Siting (ORES) in the Department of State to speed up the permitting timeline of large-scale renewable energy facilities. ORES has approved over 1,200 MW of new renewable energy resource capacity as of October 2022. The Act also directs the PSC and NYSERDA to advance "Build Ready" projects that package sites and renewable energy credit contracts in competitive procurements. On October 15, 2020, the PSC issued an order to authorize NYSERDA to begin procurement of Build Ready sites and projects as early as 2022. The program has advanced a 20 MW solar facility at a former mine site as its first project.



# **Appendix D**

## **ICAP to UCAP Translations**

## D. ICAP to UCAP Translation – Appendix C (Yet to be updated)

The NYISO administers the capacity requirements to all loads in the NYCA. In 2002, the NYISO adopted the Unforced Capacity (UCAP) methodology for determining system requirements, unit ratings and market settlements. The UCAP methodology uses individual generating unit data for output and availability to determine an expected level of resources that can be considered for system planning, operation and marketing purposes. EFORD is developed from this process for each generating unit and applied to the units Dependable Maximum Net Capability (DMNC) test value to determine the resulting level of UCAP.

Individual unit EFORD factors are taken in aggregate on both a Statewide and Locational basis and used to effectively “translate” the IRM and LCRs previously determined in the GE-MARS Analysis in terms of ICAP, into an equivalent UCAP basis.

Table C.1 summarizes historical values (since 2000) for NYCA capacity parameters including Base Case IRMs, approved IRMs, UCAP requirements, and NYISO Approved LCRs (for NYC, LI and G-J).

**Table D.1 Historical NYCA Capacity Parameters**

Capability Year (May - April)	Base Case IRM (%)	EC Approved IRM (%)	NYCA Equivalent UCAP Requirement (%)	NYISO Approved J LCR (%)	NYISO Approved K LCR (%)	NYISO Approved G-J LCR (%)
2000	15.5	18.0		80.0	107.0	
2001	17.1	18.0		80.0	98.0	
2002	18.0	18.0		80.0	93.0	
2003	17.5	18.0		80.0	95.0	
2004	17.1	18.0	11.90	80.0	99.0	
2005	17.6	18.0	12.00	80.0	99.0	
2006	18.0	18.0	11.59	80.0	99.0	
2007	16.0	16.5	11.30	80.0	99.0	
2008	15.0	15.0	8.35	80.0	94.0	
2009	16.2	16.5	7.17	80.0	97.5	
2010	17.9	18.0	6.12	80.0	104.5	
2011	15.5	15.5	6.03	81.0	101.5	
2012	16.1	16.0	5.35	83.0	99.0	
2013	17.1	17.0	6.58	86.0	105.0	
2014	17.0	17.0	6.38	85.0	107.0	88.0
2015	17.3	17.0	7.01	83.5	103.5	90.5
2016	17.4	17.5	6.21	80.5	102.5	90.0
2017	18.1	18.0	7.04	81.5	103.5	91.5
2018	18.2	18.2	8.08	80.5	103.5	94.5
2019	16.8	17.0	6.72	82.8	104.1	92.3
2020	18.9	18.9	9.03	86.6	103.4	90.0
2021	20.7	20.7	10.11	80.3	102.9	87.6
2022	19.6	19.6	7.90	81.2	99.5	89.2

## **D.1 NYCA and NYC and LI Locational Translations**

In the “Installed Capacity” section of the NYISO Web site<sup>3</sup>, NYISO Staff regularly post summer and winter Capability Period ICAP and UCAP calculations for NYCA Locational Areas and Transmission District Loads. This information has been compiled and posted since 2006.


Locational ICAP/UCAP calculations are produced for NYC, LI, G-J Locality and the entire NYCA. Exhibits C.1.1 through C.1.4 summarizes the translation of ICAP requirements to UCAP requirements for these areas. The charts and tables included in these exhibits utilize data from the summer capability periods for the most recent 15 years beginning in 2007.

This data reflects the interaction and relationships between the capacity parameters used this study, including Forecast Peak Load, ICAP Requirements, De-rating Factors, UCAP Requirements, IRMs, and LCRs. Since these parameters are so inextricably linked to each other, the graphical representation also helps one more easily visualize the annual changes in capacity requirements.

## D.1.1 New York Control Area ICAP to UCAP Translation

Table D.2 NYCA ICAP to UCAP Translation


Year	Forecast Peak Load (MW)	Installed Capacity Requirement (%)	Derate Factor	ICAP Requirement (MW)	UCAP Requirement (MW)	Effective UCAP (%)
2008	33,809	115.0	0.0578	38,880	36,633	108.4
2009	33,930	116.5	0.0801	39,529	36,362	107.2
2010	33,025	118.0	0.1007	38,970	35,045	106.1
2011	32,712	115.5	0.0820	37,783	34,684	106.0
2012	33,295	116.0	0.0918	38,622	35,076	105.4
2013	33,279	117.0	0.0891	38,936	35,467	106.6
2014	33,666	117.0	0.0908	39,389	35,812	106.4
2015	33,567	117.0	0.0854	39,274	35,920	107.0
2016	33,359	117.5	0.0961	39,197	35,430	106.2
2017	33,178	118.0	0.0929	39,150	35,513	107.0
2018	32,903	118.2	0.0856	38,891	35,562	108.1
2019	32,383	117.0	0.0879	37,888	34,558	106.7
2020	32,296	118.9	0.0830	38,400	35,213	109.3
2021	32,333	120.7	0.0877	39,026	35,604	110.1
2022	31,767	119.6	0.0978	37,993	34,277	107.9



## D.1.2 New York City ICAP to UCAP Translation

Table D.3 New York City ICAP to UCAP Translation


Year	Forecast Peak Load (MW)	Locational Capacity Requirement (%)	Derate Factor	ICAP Requirement (MW)	UCAP Requirement (MW)	Effective UCAP (%)
2008	11,964	80.0	0.0690	9,571	8,911	74.5
2009	12,050	80.0	0.0814	9,640	8,855	73.5
2010	11,725	80.0	0.1113	9,380	8,336	71.1
2011	11,514	81.0	0.0530	9,326	8,832	76.7
2012	11,500	83.0	0.0679	9,545	8,897	77.4
2013	11,485	86.0	0.0559	9,877	9,325	81.2
2014	11,783	85.0	0.0544	10,015	9,471	80.4
2015	11,929	83.5	0.0692	9,961	9,272	77.7
2016	11,794	80.5	0.0953	9,494	8,589	72.8
2017	11,670	81.5	0.0437	9,511	9,095	77.9
2018	11,539	80.5	0.0709	9,289	8,630	74.8
2019	11,607	82.8	0.0409	9,611	9,217	79.4
2020	11,477	86.6	0.0351	9,939	9,590	83.6
2021	11,199	80.3	0.0269	8,993	8,751	78.1
2022	10,906	81.2	0.0326	8,856	8,567	78.6



### D.1.3 Long Island ICAP to UCAP Translation

Table D.4 Long Island ICAP to UCAP Translation


Year	Forecast Peak Load (MW)	Locational Capacity Requirement (%)	Derate Factor	ICAP Requirement (MW)	UCAP Requirement (MW)	Effective UCAP (%)
2008	5,424	94.0	0.0811	5,098	4,685	86.4
2009	5,474	97.5	0.1103	5,337	4,749	86.8
2010	5,368	104.5	0.1049	5,610	5,021	93.5
2011	5,434	101.5	0.0841	5,516	5,052	93.0
2012	5,526	99.0	0.0931	5,470	4,961	89.8
2013	5,515	105.0	0.0684	5,790	5,394	97.8
2014	5,496	107.0	0.0765	5,880	5,431	98.8
2015	5,539	103.5	0.0783	5,733	5,284	95.4
2016	5,479	102.5	0.0727	5,615	5,207	95.0
2017	5,427	103.5	0.0560	5,617	5,302	97.7
2018	5,376	103.5	0.0628	5,564	5,214	97.0
2019	5,240	104.1	0.0647	5,455	5,102	97.4
2020	5,228	103.4	0.0691	5,405	5,032	96.3
2021	5,249	102.9	0.0491	5,401	5,136	97.9
2022	5,138	99.5	0.0627	5,112	4,791	93.3



## D.1.4 GHIJ ICAP to UCAP Translation

Table D.5 GHIJ ICAP to UCAP Translation

Year	Forecast Peak Load (MW)	Locational Capacity Requirement (%)	Derate Factor	ICAP Requirement (MW)	UCAP Requirement (MW)	Effective UCAP (%)
2014	16,291	88.0	0.0587	14,336	13,495	82.8
2015	16,340	90.5	0.0577	14,788	13,934	85.3
2016	16,309	90.0	0.0793	14,678	13,514	82.9
2017	16,061	91.5	0.0731	14,696	13,622	84.8
2018	15,918	94.5	0.0626	15,042	14,100	88.6
2019	15,846	92.3	0.0514	14,625	13,874	87.6
2020	15,695	90.0	0.0418	14,124	13,534	86.2
2021	15,411	87.6	0.0361	13,498	13,011	84.4
2022	15,125	89.2	0.0476	13,492	12,850	85.0




## D.2 Transmission Districts ICAP to UCAP Translation

### D.2.1 Central Hudson Gas & Electric

Table D.6 Central Hudson Gas & Electric ICAP to UCAP Translation


Year	Forecast Peak Load (MW)	ICAP Requirement (MW)	UCAP Requirement (MW)	% ICAP of Forecast Peak	% UCAP of Forecast Peak
2008	1,214.1	1,396.2	1,315.5	115.0%	108.4%
2009	1,196.3	1,393.7	1,282.1	116.5%	107.2%
2010	1,172.3	1,383.3	1,244.0	118.0%	106.1%
2011	1,176.9	1,359.3	1,247.9	115.5%	106.0%
2012	1,133.3	1,314.6	1,193.9	116.0%	105.3%
2013	1,097.5	1,284.1	1,169.7	117.0%	106.6%
2014	1,089.2	1,274.4	1,158.7	117.0%	106.4%
2015	1,083.6	1,267.8	1,159.5	117.0%	107.0%
2016	1,104.2	1,297.4	1,172.7	117.5%	106.2%
2017	1,043.1	1,230.9	1,116.5	118.0%	107.0%
2018	1,069.7	1,264.4	1,156.2	118.2%	108.1%
2019	1,090.8	1,276.3	1,164.1	117.0%	106.7%
2020	1,082.7	1,287.3	1,180.5	118.9%	109.0%
2021	1,104.5	1,333.1	1,216.2	120.7%	110.1%
2022	1,071.3	1,281.3	1,156.0	119.6%	107.9%



## D.2.2 Consolidated Edison (Con Ed)

Table D.7 Con Ed ICAP to UCAP Translation


Year	Forecast Peak Load (MW)	ICAP Requirement (MW)	UCAP Requirement (MW)	% ICAP of Forecast Peak	% UCAP of Forecast Peak
2008	13,911.1	15,997.8	15,073.1	115.0%	108.4%
2009	14,043.0	16,360.1	15,049.6	116.5%	107.2%
2010	13,654.9	16,112.8	14,490.2	118.0%	106.1%
2011	13,450.5	15,535.3	14,261.4	115.5%	106.0%
2012	13,430.5	15,579.4	14,149.2	116.0%	105.4%
2013	13,370.8	15,643.8	14,250.0	117.0%	106.6%
2014	13,718.7	16,050.9	14,593.5	117.0%	106.4%
2015	13,793.0	16,137.8	14,759.6	117.0%	107.0%
2016	13,704.6	16,102.9	14,555.4	117.5%	106.2%
2017	13,534.0	15,970.1	14,486.5	118.0%	107.0%
2018	13,309.6	15,732.0	14,385.3	118.2%	108.1%
2019	13,305.5	15,567.4	14,199.1	117.0%	106.7%
2020	13,170.0	15,659.1	14,359.4	118.9%	109.0%
2021	12,816.7	15,469.8	14,113.1	120.7%	110.1%
2022	12,488.0	14,935.7	13,474.9	119.6%	107.9%



## D.2.3 Long Island Power Authority (LIPA)

Table D.8 LIPA ICAP to UCAP Translation


Year	Forecast Peak Load (MW)	ICAP Requirement (MW)	UCAP Requirement (MW)	% ICAP of Forecast Peak	% UCAP of Forecast Peak
2008	5,358.9	6,162.7	5,806.5	115.0%	108.4%
2009	5,431.7	6,327.9	5,821.1	116.5%	107.2%
2010	5,286.0	6,237.5	5,609.4	118.0%	106.1%
2011	5,404.3	6,242.0	5,730.1	115.5%	106.0%
2012	5,508.3	6,389.6	5,803.1	116.0%	105.4%
2013	5,448.9	6,375.2	5,807.2	117.0%	106.6%
2014	5,470.1	6,400.0	5,818.9	117.0%	106.4%
2015	5,541.3	6,483.3	5,929.7	117.0%	107.0%
2016	5,491.3	6,452.3	5,832.2	117.5%	106.2%
2017	5,427.2	6,404.1	5,809.1	118.0%	107.0%
2018	5,368.1	6,345.1	5,802.0	118.2%	108.1%
2019	5,253.0	6,146.0	5,605.8	117.0%	106.7%
2020	5,172.9	6,150.6	5,640.1	118.9%	109.0%
2021	5,279.7	6,372.6	5,813.7	120.7%	110.1%
2022	5,105.1	6,105.7	5,508.6	119.6%	107.9%



## D.2.4 National Grid (NGRID)

Table D.9 NGRID ICAP to UCAP Translation


Year	Forecast Peak Load (MW)	ICAP Requirement (MW)	UCAP Requirement (MW)	% ICAP of Forecast Peak	% UCAP of Forecast Peak
2008	6,762.5	7,776.9	7,327.3	115.0%	108.4%
2009	6,728.4	7,838.6	7,210.7	116.5%	107.2%
2010	6,732.1	7,943.9	7,144.0	118.0%	106.1%
2011	6,574.7	7,593.8	6,971.1	115.5%	106.0%
2012	6,749.1	7,828.9	7,110.3	116.0%	105.4%
2013	6,821.3	7,980.9	7,269.8	117.0%	106.6%
2014	6,861.9	8,028.4	7,299.4	117.0%	106.4%
2015	6,880.3	8,049.9	7,362.5	117.0%	107.0%
2016	6,776.0	7,961.8	7,196.7	117.5%	106.2%
2017	6,891.4	8,131.9	7,376.4	118.0%	107.0%
2018	6,833.0	8,076.6	7,385.2	118.2%	108.1%
2019	6,608.8	7,732.3	7,052.6	117.0%	106.7%
2020	6,670.2	7,930.9	7,272.6	118.9%	109.0%
2021	6,793.0	8,199.2	7,480.1	120.7%	110.1%
2022	6,817.1	8,153.3	7,355.9	119.6%	107.9%



## D.2.5 New York Power Authority (NYPA)

Table D.10 NYPA ICAP to UCAP Translation


Year	Forecast Peak Load (MW)	ICAP Requirement (MW)	UCAP Requirement (MW)	% ICAP of Forecast Peak	% UCAP of Forecast Peak
2008	579.1	666.0	627.5	115.0%	108.4%
2009	587.2	684.1	629.3	116.5%	107.2%
2010	317.6	374.8	337.0	118.0%	106.1%
2011	319.7	369.3	339.0	115.5%	106.0%
2012	576.1	668.3	606.9	116.0%	105.3%
2013	589.3	689.5	628.1	117.0%	106.6%
2014	506.3	592.4	538.6	117.0%	106.4%
2015	325.8	381.2	348.6	117.0%	107.0%
2016	336.0	394.8	356.9	117.5%	106.2%
2017	305.0	359.9	326.5	118.0%	107.0%
2018	327.6	387.2	354.1	118.2%	108.1%
2019	357.5	418.3	381.5	117.0%	106.7%
2020	392.7	466.9	428.2	118.9%	109.0%
2021	420.8	507.9	463.4	120.7%	110.1%
2022	463.8	554.7	500.4	119.6%	107.9%



## D.2.6 New York State Electric & Gas (NYSEG)

Table D.11 NYSEG ICAP to UCAP Translation


Year	Forecast Peak Load (MW)	ICAP Requirement (MW)	UCAP Requirement (MW)	% ICAP of Forecast Peak	% UCAP of Forecast Peak
2008	3,141.1	3,612.3	3,403.5	115.0%	108.4%
2009	3,111.8	3,625.3	3,334.9	116.5%	107.2%
2010	3,075.0	3,628.5	3,263.1	118.0%	106.1%
2011	3,037.0	3,507.7	3,220.1	115.5%	106.0%
2012	3,126.7	3,627.0	3,294.0	116.0%	105.4%
2013	3,113.4	3,642.7	3,318.1	117.0%	106.6%
2014	3,229.1	3,778.1	3,435.0	117.0%	106.4%
2015	3,179.8	3,720.4	3,402.7	117.0%	107.0%
2016	3,191.6	3,750.1	3,389.7	117.5%	106.2%
2017	3,222.9	3,803.0	3,449.7	118.0%	107.0%
2018	3,254.0	3,846.2	3,517.0	118.2%	108.1%
2019	3,146.6	3,681.5	3,357.9	117.0%	106.7%
2020	3,188.4	3,791.0	3,476.3	118.9%	109.0%
2021	3,244.8	3,916.5	3,573.0	120.7%	110.1%
2022	3,112.4	3,722.4	3,358.4	119.6%	107.9%



## D.2.7 Orange & Rockland (O & R)

Table D.12 O & R ICAP to UCAP Translation


Year	Forecast Peak Load (MW)	ICAP Requirement (MW)	UCAP Requirement (MW)	% ICAP of Forecast Peak	% UCAP of Forecast Peak
2008	1,192.3	1,371.1	1,291.9	115.0%	108.4%
2009	1,179.5	1,374.1	1,264.0	116.5%	107.2%
2010	1,157.4	1,365.7	1,228.2	118.0%	106.1%
2011	1,172.7	1,354.5	1,243.4	115.5%	106.0%
2012	1,158.3	1,343.6	1,220.3	116.0%	105.4%
2013	1,171.7	1,370.9	1,248.7	117.0%	106.6%
2014	1,190.8	1,393.2	1,266.7	117.0%	106.4%
2015	1,162.2	1,359.8	1,243.7	117.0%	107.0%
2016	1,164.3	1,368.1	1,236.6	117.5%	106.2%
2017	1,177.3	1,389.2	1,260.2	118.0%	107.0%
2018	1,146.2	1,354.8	1,238.8	118.2%	108.1%
2019	1,115.5	1,305.1	1,190.4	117.0%	106.7%
2020	1,075.9	1,279.3	1,173.1	118.9%	109.0%
2021	1,108.4	1,337.8	1,220.5	120.7%	110.1%
2022	1,127.7	1,348.7	1,216.8	119.6%	107.9%



## D.2.8 Rochester Gas & Electric (RGE)

Table D.13 RGE ICAP to UCAP Translation

Year	Forecast Peak Load (MW)	ICAP Requirement (MW)	UCAP Requirement (MW)	% ICAP of Forecast Peak	% UCAP of Forecast Peak
2008	1,649.4	1,896.8	1,787.2	115.0%	108.4%
2009	1,652.3	1,924.9	1,770.7	116.5%	107.2%
2010	1,629.7	1,923.0	1,729.4	118.0%	106.1%
2011	1,576.4	1,820.7	1,671.4	115.5%	106.0%
2012	1,612.3	1,870.3	1,698.6	116.0%	105.4%
2013	1,665.7	1,948.9	1,775.2	117.0%	106.6%
2014	1,599.6	1,871.5	1,701.6	117.0%	106.4%
2015	1,601.3	1,873.5	1,713.5	117.0%	107.0%
2016	1,590.8	1,869.2	1,689.6	117.5%	106.2%
2017	1,576.9	1,860.7	1,687.9	118.0%	107.0%
2018	1,594.3	1,884.5	1,723.1	118.2%	108.1%
2019	1,505.5	1,761.4	1,606.6	117.0%	106.7%
2020	1,543.3	1,835.0	1,682.7	118.9%	109.0%
2021	1,565.2	1,889.2	1,723.5	120.7%	110.1%
2022	1,581.3	1,891.2	1,706.3	119.6%	107.9%



### **D.3 Wind Resource Impact on the NYCA IRM and UCAP Markets**

Wind generation is generally classified as an "intermittent" or "variable generation" resource with a limited ability to be dispatched. The effective capacity of wind generation can be quantified and modeled using the GE-MARS program like conventional fossil-fired power plants. There are various modeling techniques to model wind generation in GE-MARS; the method that ICS has adopted uses historical New York hourly wind farm generation outputs for the previous five calendar years. This data can be scaled to create wind profiles for new wind generation facilities.

For a wind farm or turbine, the nameplate capacity is the ICAP while the effective capacity is equal to the UCAP value. Seasonal variability and geographic location are factors that also affect wind resource availability. The effective capacity of wind generation can be either calculated statistically directly from historical hourly wind generation outputs, and/or by using the following information:

- Production hourly wind data.
- Maintenance cycle and duration
- EFOR (not related to fuel)

In general, effective wind capacity depends primarily on the availability of the wind. Wind farms in New York on average have annual capacity factors that are based on their nameplate ratings. A wind plant's output can range from close to nameplate under favorable wind conditions to zero when the wind does not blow. On average, a wind plant's output is higher at night, and has higher output on average in the winter versus the summer.

Another measure of a wind generator's contribution to resource adequacy is its effective capacity which is its expected output during the summer peak hours of 2 p.m. to 6 p.m. for the months of June through August. The effective capacity value for wind generation in New York is based on actual hourly plant output over the previous five-year period – 2017 through 2021 for this year's study, for new units the zonal hourly averages or averages for nearby units will be used. Wind shapes years are selected randomly from those years for each simulation year.

# Appendix **DE**

## Glossary of Terms

## E. Glossary – Appendix DE.

Term	Definition
<b>Availability</b>	A measure of time a generating unit, transmission line, or other facility can provide service, whether or not it actually is in service. Typically, this measure is expressed as a percent available for the period under consideration.
<b>Bubble</b>	A symbolic representation introduced for certain purposes in the GE-MARS model as an area that may be an actual zone, multiple areas or a virtual area without actual load.
<b>Capability Period</b>	Six (6) month periods which are established as follows: (1) from May 1 through October 31 of each year ("Summer Capability Period"); and (2) from November 1 of each year through April 30 of the following year ("Winter Capability Period"); or such other periods as may be determined by the Operating Committee of the NYISO. A summer capability period followed by a winter capability period shall be referred to as a "Capability Year." Each capability period shall consist of on-peak and off-peak periods.
<b>Capacity</b>	The rated continuous load-carrying ability, expressed in megawatts ("MW") or megavolt-amperes ("MVA") of generation, transmission or other electrical equipment.
<b>Contingency</b>	An actual or potential unexpected failure or outage of a system component, such as a generator, transmission line, circuit breaker, switch, or other electrical element. A contingency also may include multiple components, which are related by situations leading to simultaneous component outages.
<b>Control Area (CA)</b>	An electric system or systems, bounded by interconnection metering and telemetry, capable of controlling generation to maintain its interchange schedule with other control areas and contributing to frequency regulation of the interconnection.
<b>Demand</b>	The rate at which energy must be generated or otherwise provided to supply an electric power system.
<b>Emergency</b>	Any abnormal system condition that requires automatic or immediate, manual action to prevent or limit loss of transmission facilities or generation resources that could adversely affect the reliability of an electric system.
<b>Energy Limited Resource (ELR)</b>	Capacity resources, not including BTM:NG Resources, that, due to environmental restrictions on operations, cyclical requirements, such as the need to recharge or refill, or other non-economic reasons, are unable to operate continuously on a daily basis but are able to operate for at least four consecutive hours each day.
<b>Expected Unserved Energy (EUE)</b>	The expected amount of energy (MWh) of unserved load in a given time period (often one year) when a system's resources are insufficient to meet demand.
<b>External Installed Capacity (External ICAP)</b>	Installed capacity from resources located in control areas outside the NYCA that must meet certain NYISO requirements and criteria in order to qualify to supply New York LSEs.
<b>Event-Day</b>	An event-period lasting one day during which at least one Event-Hour occurs.

<b>Term</b>	<b>Definition</b>
<b>Event-Hour:</b>	An event-period lasting one hour during which, at some point, system resources are insufficient to meet demand.
<b>Firm Load</b>	The load of a Market Participant that is not contractually interruptible. Interruptible Load – The load of a Market Participant that is contractually interruptible.
<b>Generation</b>	The process of producing electrical energy from other forms of energy; also, the amount of electric energy produced, usually expressed in kilowatt-hours (kWh) or megawatt-hours (MWh).
<b>Installed Capacity (ICAP)</b>	Capacity of a facility accessible to the NYS Bulk Power System, that is capable of supplying and/or reducing the demand for energy in the NYCA for the purpose of ensuring that sufficient energy and capacity is available to meet the reliability rules.
<b>Installed Capacity Requirement (ICR)</b>	The annual statewide requirement established by the NYSRC in order to ensure resource adequacy in the NYCA.
<b>Installed Reserve Margin (IRM)</b>	That capacity above firm system demand required to provide for equipment forced and scheduled outages and transmission capability limitations.
<b>Interface</b>	The specific set of transmission elements between two areas or between two areas comprising one or more electrical systems.
<b>Load</b>	The electric power used by devices connected to an electrical generating system. (IEEE Power Engineering)
<b>Load Relief</b>	Load reduction accomplished by voltage reduction or load shedding or both. Voltage reduction and load shedding, as defined in this document, are measures by order of the NYISO.
<b>Load Shedding</b>	The process of disconnecting (either manually or automatically) pre-selected customers' load from a power system in response to an abnormal condition to maintain the integrity of the system and minimize overall customer outages. Load shedding is a measure undertaken by order of the NYISO. If ordered to shed load, transmission owner system dispatchers shall immediately comply with that order. Load shall normally all be shed within 5 minutes of the order.
<b>Load Serving Entity (LSE)</b>	In a wholesale competitive market, Central Hudson Gas & Electric Corporation, Consolidated Edison Company of New York, Inc., Long Island Power Authority ("LIPA"), New York State Electric & Gas Corporation, Niagara Mohawk Power Corporation, Orange & Rockland Utilities, Inc., and Rochester Gas and Electric Corporation, the current forty-six (46) members of the Municipal Electric Utilities Association of New York State, the City of Jamestown, Rural Electric Cooperatives, the New York Power Authority ("NYPA"), any of their successors, or any entity through regulatory requirement, tariff, or contractual obligation that is responsible for supplying energy, capacity and/or ancillary services to retail customers within New York State.

Term	Definition
<b>Locational Capacity Requirement (LCR)</b>	Due to transmission constraints, that portion of the NYCA ICAP requirement that must be electrically located within a zone, in order to ensure that sufficient energy and capacity are available in that zone and that NYSRC Reliability Rules are met. Locational ICAP requirements are currently applicable to three transmission constrained zones, New York City, Long Island, and the Lower Hudson Valley, and are normally expressed as a percentage of each zone's annual peak load.
<b>Loss of Load Hours (LOLH)</b>	The expected number of loss of load Event-Hours in a given time period (often one year) when a system's resources are insufficient to meet demand.
<b>Loss of Load expectation (LOLE)</b>	The expected number of loss of load Event Days in a given time period (often one year) when a system's resources are insufficient to meet demand.
<b>New York Control Area (NYCA)</b>	The control area located within New York State which is under the control of the NYISO. See Control Area.
<b>New York Independent System Operator (NYISO)</b>	The NYISO is a not-for-profit organization formed in 1998 as part of the restructuring of New York State's electric power industry. Its mission is to ensure the reliable, safe and efficient operation of the State's major transmission system and to administer an open, competitive and nondiscriminatory wholesale market for electricity in New York State.
<b>New York State Bulk Power System (NYS Bulk Power System or BPS)</b>	The portion of the bulk power system within the New York Control Area, generally comprising generating units 300 MW and larger, and generally comprising transmission facilities 230 kV and above. However, smaller generating units and lower voltage transmission facilities on which faults and disturbances can have a significant adverse impact outside of the local area are also part of the NYS Bulk Power System.
<b>New York State Reliability Council, LLC (NYSRC)</b>	An organization established by agreement (the "NYSRC Agreement") by and among Central Hudson Gas & Electric Corporation, Consolidated Edison Company of New York, Inc., LIPA, New York State Electric & Gas Corporation, Niagara Mohawk Power Corporation, Orange & Rockland Utilities, Inc., Rochester Gas and Electric Corporation, and the New York Power Authority, to promote and maintain the reliability of the Bulk Power System, and which provides for participation by Representatives of Transmission Owners, sellers in the wholesale electric market, large commercial and industrial consumers of electricity in the NYCA, and municipal systems or cooperatively-owned systems in the NYCA, and by unaffiliated individuals.
<b>New York State (NYS) Transmission System</b>	The entire New York State electric transmission system, which includes: (1) the transmission facilities under NYISO operational control; (2) the transmission facilities requiring NYISO notification, and; (3) all remaining facilities within the NYCA.
<b>Normalized Expected Unserved Energy</b>	The Expected Unserved Energy (EUE) as a percent (%) of the total annual system net energy for load.

<b>Term</b>	<b>Definition</b>
<b>Operating Limit</b>	The maximum value of the most critical system operation parameter(s) which meet(s): (a) pre-contingency criteria as determined by equipment loading capability and acceptable voltage conditions; (b) stability criteria; (c) post-contingency loading and voltage criteria.
<b>Operating Procedures</b>	A set of policies, practices, or system adjustments that may be automatically or manually implemented by the system operator within a specified time frame to maintain the operational integrity of the interconnected electric systems.
<b>Operating Reserves</b>	Resource capacity that is available to supply energy, or curtailable load that is willing to stop using energy, in the event of emergency conditions or increased system load and can do so within a specified time period.
<b>Reserves</b>	In normal usage, reserve is the amount of capacity available in excess of the demand.
<b>Resource</b>	The total contributions provided by supply-side and demand-side facilities and/or actions.
<b>Special Sensitivity (SS)</b>	All substantive assumption changes following approval of the final base case assumptions in early October are combined into a single SS Case. The SS Case is conducted using a Tan 45 analysis. As described in Policy 5, SS Cases must meet a specified levels of materiality before being designated as an SS case.
<b>Stability</b>	The ability of an electric system to maintain a state of equilibrium during normal and abnormal system conditions or disturbances.
<b>Thermal Limit</b>	The maximum power flow through a particular transmission element or interface, considering the application of thermal assessment criteria.
<b>Transfer Capability</b>	The measure of the ability of interconnected electrical systems to reliably move or transfer power from one area to another over all transmission lines (or paths) between those areas under specified system conditions.
<b>Transmission District</b>	The geographic area served by the NYCA investor-owned transmission owners and LIPA, as well as customers directly interconnected with the transmission facilities of NYPA.
<b>Transmission Owner</b>	Those parties who own, control and operate facilities in New York State used for the transmission of electric energy in interstate commerce. Transmission owners are those who own, individually or jointly, at least 100 circuit miles of 115 kV or above in New York State and have become a signatory to the TO/NYISO Agreement.
<b>Unforced Capacity:</b>	The measure by which Installed Capacity Suppliers will be rated, in accordance with formulae set forth in the ISO Procedures, to quantify the extent of their contribution to satisfy the NYCA Installed Capacity Requirement, and which will be used to measure the portion of that NYCA Installed Capacity Requirement for which each LSE is responsible.
<b>Voltage Limit</b>	The maximum power flow through some particular point in the system considering the application of voltage assessment criteria.
<b>Voltage Reduction</b>	A means of achieving load reduction by reducing customer supply voltage, usually by 3, 5, or 8 percent. If ordered by the NYISO to go into voltage reduction, Transmission Owner system dispatchers shall immediately comply with that order. Quick response voltage reduction shall normally be accomplished within ten (10) minutes of the order.

Term	Definition
<b>Zone</b>	A defined portion of the NYCA area that encompasses a set of load and generation buses. Each zone has an associated zonal price that is calculated as a weighted average price based on generator LBMPs and generator bus load distribution factors. A "zone" outside the NY control area is referred to as an external zone. Currently New York State is divided into eleven zones, corresponding to ten major transmission interfaces that can become congested.