

Attachment C Load Relief Capability

- Table C-1 tabulates the Load Relief available from Voltage Reduction and load curtailment.
- Table C-2 allocates New York Control Area wide load reduction among the Transmission Owners (TOs).
- Table C-3 allocates load reduction among the TOs on a geographic basis.

Note: The above attachments do not require committee approval and are subject to change at the NYISO's direction.

Table C- 1: Summer 2022 Load Relief Measures

REMOTE TO-->		VOLTAGE REDUCTION CAPABILITY PERIOD SUMMER 2023																																
		LI			CE			OR			CH			PA			NG		NY			RG			NT			LS			TOTAL (NYISO)			
ZONE		3%	5%	8%	3%	5%	8%	3%	5%	8%	3%	5%	8%	3%	5%	8%	3%	5%	8%	3%	5%	8%	3%	5%	8%	3%	5%	8%	3%	5%	8%			
A																	28	28													0	28	28	
B																	8	8														0	17	17
C																	29	29			6	6										0	35	35
D																	2	2														0	2	2
E																	26	26														0	26	26
F																	52	52														0	52	52
G									12	12			16	16																		0	28	28
H						2	2																									0	2	2
I						9	13																									0	9	13
J						251	380																									0	251	380
K		9	28	28																												9	28	28
TOTAL (TO)		9	28	28	0	261	396	0	12	12	0	16	16	0	0	0	0	144	144	0	6	6	0	9	9	0	0	0	0	0	9	476	611	

MANUAL TO-->		VOLTAGE REDUCTION CAPABILITY PERIOD SUMMER 2023																																
ZONE		LI			CE			OR			CH			PA			NG		NY			RG			NT			LS			TOTAL (NYISO)			
		3%	5%	8%	3%	5%	8%	3%	5%	8%	3%	5%	8%	3%	5%	8%	3%	5%	8%	3%	5%	8%	3%	5%	8%	3%	5%	8%	3%	5%	8%			
A																	5	8													5	11	0	
B																	1	2														1	2	0
C																	6	10														6	15	0
D																	6	9														6	9	0
E																	3	4														3	6	0
F																																0	2	0
G																	16															0	16	0
H						3	5																									0	6	5
I						20	31																									0	20	31
J						21	32																									0	21	32
K																	2	4														2	4	0
TOTAL (TO)		0	0	0	44	68	0	0	0	0	16	23	38	0	0	0	15	0	0	0	0	0	0	0	0	0	0	0	0	23	113	68		