

Request to Develop or Modify Reliability Rules and Requirements (NYSRC Policy No. 1-11)
 Submit request to Herb Schrayshuen (herb@poweradvisorsllc.com) via the NYSRC site www.nysrc.org

Item	Information
1. PRR No. & Title of Reliability Rule or Requirement change	PRR 153a: Sudden loss of gas fuel delivery system
2. Rule Change Requester Information	
Name	RRS
Organization	NYSRC
3. New rule or revision to existing rule?	Revision to B.1 - Transmission System Planning Performance Requirements, R1 - Transmission facilities in the NYS Bulk Power System shall be planned to meet the respective performance requirements in Table B-1 and supplemental performance requirements in Table B-2 for the contingency events as specified in Table B-1.
4. Need for rule change, including advantages and disadvantages	<p>Sudden loss of fuel delivery system to multiple plants is currently included as an Extreme Contingency in NYSRC Reliability Rules Table B-3, (Extreme contingency 10). This rule is proposing to add design criteria contingencies of the loss of gas fuel to a single plant for a common-mode failure of the fuel delivery system. Extreme contingency 10 in Table B-3 (sudden loss of a fuel delivery system to multiple plants) would also be revised to clarify applicability to fossil-based generation. It is proposed to make these design criteria contingencies in Table B-1, Category I and Category II contingencies.</p> <p>The proposed contingency for the loss of fossil fuel to a plant for a common-mode failure of the fuel delivery system better aligns to risks to operations present on the system today.</p> <p>There are no disadvantages.</p>
5. Related NYSRC rules	B.1 - Transmission System Planning Performance Requirements
6. Section A – Reliability Rule Elements	
1. Reliability Rule	<p>Table B-1: Category I Event – add new contingency 11, loss of gas fuel to a single plant for a common-mode failure of the fuel delivery system. Add category II event of loss of gas fuel to a single plant for a common-mode failure of the fuel delivery system.</p> <p>Table B-3: Extreme Contingency 10. Sudden loss of fuel delivery system to multiple fossil plants (e.g., gas pipeline contingencies)</p>
2. Associated NERC & NPCC Standards and Criteria	NERC TPL-01, NPCC Directory 1
3. Applicability	NYISO

Formatted Table

Deleted: 5-6-19 rev1

Formatted Table

7. Section B – Requirements													
Requirements	Table B-1												
	<table border="1"> <thead> <tr> <th>Category</th> <th>Contingency Events</th> <th>Fault Type</th> <th>Performance Requirements</th> </tr> </thead> <tbody> <tr> <td>I</td> <td>11. Loss of gas fuel to a <u>single</u> plant for a common-mode failure of the fuel delivery system</td> <td>No <i>fault</i></td> <td>No change from table B-1</td> </tr> <tr> <td>II</td> <td>1g. Loss of gas fuel to a <u>single</u> plant for a common-mode failure of the fuel delivery system</td> <td>No change from table B-1</td> <td>No change from table B-1</td> </tr> </tbody> </table>	Category	Contingency Events	Fault Type	Performance Requirements	I	11. Loss of gas fuel to a <u>single</u> plant for a common-mode failure of the fuel delivery system	No <i>fault</i>	No change from table B-1	II	1g. Loss of gas fuel to a <u>single</u> plant for a common-mode failure of the fuel delivery system	No change from table B-1	No change from table B-1
	Category	Contingency Events	Fault Type	Performance Requirements									
	I	11. Loss of gas fuel to a <u>single</u> plant for a common-mode failure of the fuel delivery system	No <i>fault</i>	No change from table B-1									
	II	1g. Loss of gas fuel to a <u>single</u> plant for a common-mode failure of the fuel delivery system	No change from table B-1	No change from table B-1									
	Table B-3												
<table border="1"> <thead> <tr> <th>Category</th> <th>Contingency Events</th> <th>Fault Type</th> <th>Performance Requirements</th> </tr> </thead> <tbody> <tr> <td>Extreme Contingency</td> <td>10. Sudden loss of fuel delivery system to multiple fossil plants (e.g., gas pipeline contingencies)</td> <td>No change from table B-3</td> <td>No change from table B-3</td> </tr> </tbody> </table>	Category	Contingency Events	Fault Type	Performance Requirements	Extreme Contingency	10. Sudden loss of fuel delivery system to multiple fossil plants (e.g., gas pipeline contingencies)	No change from table B-3	No change from table B-3					
Category	Contingency Events	Fault Type	Performance Requirements										
Extreme Contingency	10. Sudden loss of fuel delivery system to multiple fossil plants (e.g., gas pipeline contingencies)	No change from table B-3	No change from table B-3										
8. Section C – Compliance Elements													
1. Measures	<u>No change</u>												
2. Levels of Non-Compliance	<u>No change</u>												
3. Compliance Monitoring Process (See Policy 4):	<u>No change</u>												
3.1 Compliance Monitoring Responsibility	<u>No change</u>												
3.2 Reporting Frequency	<u>No change</u>												
3.3 Compliance Reporting Requirements	<u>No change</u>												
9. Comments													
10. Date Rule Adopted													
11. PRR Revision Dates													
	10/26/23, 12/4/23, <u>1/24/24</u>												

Deleted: 5-6-19 rev1