

# Transmission Line Protection Under High Penetration of Inverter-Based Resources: Impact Assessments and Mitigation Solutions

Juergen Holbach, Henry Chao, Zheyuan Cheng, Yi Hu  
Quanta Technology

Bruce Fardanesh, Hossein Hooshyar, Thanh Nguyen, Adam O'Leary  
New York Power Authority

Peter Haswell, Louis E. Seiter, Charles T. Hitchings  
National Grid



# Presentation Outline


Project Approach Overview

Line Selection and Simulation Analysis

HIL Setup and Testing Results

Conclusions

# Project Approach Overview



- Focus on select where the impact will be felt the most and the earliest
- Develop the model of the selected feeder
- Assess the impact by HIL testing with real relaying products
- Develop mitigation solutions and verify with the same HIL testing setup

Section 2

# **LINE SELECTION AND SIMULATION ANALYSIS**



# Specific Line Selection

The line selection criteria

- At one of the weak spots in the focus area
- Close to many wind farms, solar farms, and BESS

The results

- A 230 kV line B-D was selected
- A 115 kV line was dropped



# Developed Hi-IBR System Models

| IBR Projects Added           | Capacity (MW) |
|------------------------------|---------------|
| Franklin Solar               | 150           |
| Brookside Solar              | 100           |
| North Country Wind           | 298           |
| Bull Run Wind                | 304           |
| Bull Run Solar Energy Center | 170           |
| North Ridge Wind             | 100           |
| Bangor Solar                 | 107           |
| North Country Energy Storage | 20            |
| Bull Run II Wind             | 145           |

In addition to IBRs added, the Hi-IBR system model (Hi-IBR case #1 )

- Reduced large hydro plant output by 50%
- Retired a 315 MW combined cycle generation, and
- The other side is represented by a weak source (SCR=2.5 and  $X/R < 5$ )

Two variations of the Hi-IBR case #1 are

- Hi-IBR case #2: take the parallel line C-E2 out-of-service
- Hi-IBR case #3: further disconnect the weak source from case #2

# Fault Current Magnitude Changes

- Weak end I1 increased due to increased IBR generation.
- Weak end I2 is decreased for all unbalanced faults.
- I0 fault current is increased for faults involving ground.

| Terminal   | FaultType | Fault Current Magnitude %Change vs Base Case |        |        |        |        |        |        |        |        |
|------------|-----------|--|--------|--------|--------|--------|--------|--------|--------|--------|
|            |           | I1   |        |        | I2     |        |        | I0     |        |        |
|            |           | IBR #1                                       | IBR #2 | IBR #3 | IBR #1 | IBR #2 | IBR #3 | IBR #1 | IBR #2 | IBR #3 |
| Strong End | AG        | -8%  | -6%    | -11%   | 50%    | 57%    | 65%    | 23%    | 22%    | 16%    |
| Strong End | AB        | -19%   | -17%   | -22%   | 16%    | 22%    | 25%    | N/A    | N/A    | N/A    |
| Strong End | ABG       | 9%   | 12%    | 11%    | -4%    | 1%     | -2%    | 92%    | 91%    | 93%    |
| Strong End | ABC       | 12%  | 16%    | 15%    | N/A    | N/A    | N/A    | N/A    | N/A    | N/A    |
| Weak End   | AG        | 29%  | 21%    | 33%    | -26%   | -33%   | -28%   | 24%    | 22%    | 15%    |
| Weak End   | AB        | 25%  | 14%    | 12%    | -43%   | -48%   | -45%   | N/A    | N/A    | N/A    |
| Weak End   | ABG       | 46%  | 28%    | 13%    | -52%   | -57%   | -56%   | 92%    | 91%    | 91%    |
| Weak End   | ABC       | 21%  | 2%     | -20%   | N/A    | N/A    | N/A    | N/A    | N/A    | N/A    |

# Negative Sequence Voltage and Current Angle Difference Changes

- Negative-sequence voltage and current angle relationship
  - Strong end shown consistent angle difference at around minus 100-degree regardless of fault types and simulation scenarios
  - Weak end saw decrease in the angle difference to as low as around minus 200-degree – much larger deviation than around minus 90 degrees in a system dominated by conventional generation
- No noticeable changes are observed for positive and zero sequence angle relationship.


| FaultType | V2- I2 Angle (Deg.) |                 |       |       |
|-----------|---------------------|-----------------|-------|-------|
|           | Base                | IBR Penetration |       |       |
|           |                     | IBR#1           | IBR#2 | IBR#3 |
| AG        | -97                 | -143            | -164  | -198  |
| AB        | -97                 | -143            | -166  | -199  |
| ABG       | -97                 | -143            | -163  | -199  |



# Impact of Declining Fault Current Levels on Protection

- Impact on Over Current Protection

- **Minimum fault current** is critical for pickup settings in overcurrent functions
- The overcurrent function is typically used as backup protection or for the supervision of unit (differential) and non unit (distance) protection
- During protection studies, the minimum current is determined by selecting an N-1 contingency that provides the lowest fault current
- **Maximum fault current** is used for inverse overcurrent elements to determine the correct time dial (time grading) setting




# Impact of IBR Fault Current Levels on Protection

- Impact on Distance Protection Loop Selection

- The selection of the correct fault loop is essential for the performance of the distance relay
- Different manufacturer implement different algorithms to master this complex task
- Typical tasks performed are:
  - Impedance comparison
  - Symmetrical component analysis
  - Load compensation
  - Pattern recognition
- Most assumption used in this algorithm are not correct anymore!



Wrong loop selection causes over or under function of the distance relay.



# Impact of IBR Fault Current Levels on Protection


- Impact on Distance Protection Directional Element

- Direction may be determined together with the impedance measurement,
- but** problems may arise in certain cases (e.g. close-in faults).
- Separate directional determination required!**
  - Cross-polarization
  - Memorized –polarization
- Both solution assume that system voltage angle will not change during fault



# Impact of IBR Fault Current Levels on Protection


- Impact on Distance Protection Accuracy
  - Fault current contribution is limited to 1.0-1.5 pu of rated inverter current
  - Source impedance of inverter based generation is higher than classical synchronous generation
  - The source-to-line-impedance-ratio (SIR) is a value that is used by National Grid to determine whether non-unit protection (distance elements) can be used on a particular line.
  - The SIR ratios will increase in relation to the growing amount of inverter-based generation
  - This is important as when the SIR ratio is above 30, non-unit protection becomes unreliable due to that as the accuracy decreases and operating time increases.



# Impact of IBR Fault Current Levels on Protection

- Directional element based on  $I_2$ 
  - Angle between  $I_2$  and  $V_2$  is used to determine forward or reverse fault
  - IBR don't typically provide  $I_2$
  - The angle between  $I_2$  and  $V_2$  of an IBR produced  $I_2$  is determined by control software in inverter and can have any value



Forward Fault with Synchronous Generator



# Impact of Declining Fault Current Levels on Protection

## ■ Impact on Differential Protection

- The differential protection principle is used for busbar, transformer, and line protection applications
- The basic principle is not affected by lower fault currents as long as the total fault current exceeds the pickup settings for the differential elements
- However, the impact of changing fault current characteristics (e.g. phase angle changes) due to the application of inverter based generation requires further study.




Section 3

# **HIL SETUP AND TESTING RESULTS**


# Protective Relay HIL Testbed

- The HIL testbed includes:
  - 9 relays for 6 relay models from 5 relay manufacturers.
  - RTDS real-time simulator
  - Amplifiers
  - Ethernet switch for network communication
  - Workstations
- The HIL testbed can be accessed remotely.





# HIL Relay Testing Setup Diagram



# Test Results Details – Zone 1 Misoperations

| RM-01  |     | Base        | IBR    |               |        |
|--------|-----|-------------|--------|---------------|--------|
| FLTLOC | TYP |             | Case 1 | Case 2        | Case 3 |
| 0%     | ABC | 0.048       | 0.046  | 0.048         | 0.050  |
| 0%     | AG  | 0.056       | 0.052  | 0.058         |        |
| 0%     | AB  | 0.051       | 0.042  | 0.054         | 0.076  |
| 0%     | ABG | 0.054       | 0.050  | 0.062         | 0.063  |
| 25%    | ABC | 0.049       | 0.049  | 0.051         | 0.053  |
| 25%    | AG  | 0.057       | 0.053  | 0.047         |        |
| 25%    | AB  | 0.054       | 0.044  | 0.046         | 0.063  |
| 25%    | ABG | 0.053       | 0.051  | 0.065         | 0.062  |
| 50%    | ABC | 0.054       | 0.050  | 0.058         | 0.057  |
| 50%    | AG  | 0.056       | 0.054  | 0.055         |        |
| 50%    | AB  | 0.050       | 0.040  | 0.063         | 0.067  |
| 50%    | ABG | 0.049       | 0.054  | 0.065         |        |
| 75%    | ABC | 0.055       | 0.051  | 0.060         | 0.067  |
| 75%    | AG  |             |        |               |        |
| 75%    | AB  | 0.054       | 0.039  | 0.075         | 0.082  |
| 75%    | ABG | 0.050       | 0.054  | 0.070         |        |
| Legend |     |             |        |               |        |
|        |     | Undesirable |        | Mis-operation |        |

| RM-02  |     | Base        | IBR    |               |        |
|--------|-----|-------------|--------|---------------|--------|
| FLTLOC | TYP |             | Case 1 | Case 2        | Case 3 |
| 0%     | ABC | 0.034       | 0.042  |               |        |
| 0%     | AG  | 0.033       | 0.034  | 0.034         |        |
| 0%     | AB  | 0.032       | 0.036  | 0.039         | 0.035  |
| 0%     | ABG | 0.035       | 0.049  | 0.045         | 0.048  |
| 25%    | ABC | 0.039       | 0.043  | 0.045         | 0.063  |
| 25%    | AG  | 0.037       | 0.040  |               |        |
| 25%    | AB  | 0.038       | 0.038  | 0.043         | 0.036  |
| 25%    | ABG | 0.042       | 0.048  | 0.044         | 0.042  |
| 50%    | ABC | 0.045       | 0.042  | 0.039         | 0.047  |
| 50%    | AG  | 0.042       | 0.041  |               |        |
| 50%    | AB  | 0.043       | 0.040  | 0.042         | 0.042  |
| 50%    | ABG | 0.044       | 0.051  | 0.049         | 0.046  |
| 75%    | ABC | 0.054       | 0.049  | 0.063         | 0.046  |
| 75%    | AG  | 0.056       | 0.048  |               |        |
| 75%    | AB  | 0.056       | 0.066  | 0.070         | 0.077  |
| 75%    | ABG | 0.057       | 0.070  | 0.070         | 0.050  |
| Legend |     |             |        |               |        |
|        |     | Undesirable |        | Mis-operation |        |

| RM-03  |     | Base        | IBR    |               |        |
|--------|-----|-------------|--------|---------------|--------|
| FLTLOC | TYP |             | Case 1 | Case 2        | Case 3 |
| 0%     | ABC | 0.042       | 0.043  | 0.042         | 0.048  |
| 0%     | AG  | 0.043       | 0.041  | 0.038         | 0.034  |
| 0%     | AB  | 0.037       | 0.041  | 0.034         | 0.038  |
| 0%     | ABG | 0.050       | 0.043  | 0.052         | 0.044  |
| 25%    | ABC | 0.041       | 0.042  | 0.046         | 0.044  |
| 25%    | AG  | 0.042       | 0.039  | 0.044         | 0.032  |
| 25%    | AB  | 0.039       | 0.038  | 0.035         | 0.034  |
| 25%    | ABG | 0.044       | 0.048  | 0.049         | 0.046  |
| 50%    | ABC | 0.043       | 0.044  | 0.042         | 0.046  |
| 50%    | AG  | 0.042       | 0.047  | 0.038         | 0.041  |
| 50%    | AB  | 0.042       | 0.037  | 0.042         | 0.038  |
| 50%    | ABG | 0.041       | 0.050  | 0.049         | 0.043  |
| 75%    | ABC | 0.046       | 0.051  | 0.050         | 0.047  |
| 75%    | AG  | 0.038       | 0.040  | 0.043         | 0.038  |
| 75%    | AB  | 0.038       | 0.040  | 0.042         | 0.042  |
| 75%    | ABG | 0.043       | 0.047  | 0.050         | 0.049  |
| Legend |     |             |        |               |        |
|        |     | Undesirable |        | Mis-operation |        |

| RM-04  |     | Base        | IBR    |               |        |
|--------|-----|-------------|--------|---------------|--------|
| FLTLOC | TYP |             | Case 1 | Case 2        | Case 3 |
| 0%     | ABC | 0.037       | 0.040  | 0.040         | 0.038  |
| 0%     | AG  | 0.038       | 0.037  |               |        |
| 0%     | AB  | 0.030       | 0.036  | 0.034         |        |
| 0%     | ABG | 0.042       | 0.038  | 0.047         | 0.051  |
| 25%    | ABC | 0.041       | 0.038  | 0.041         | 0.045  |
| 25%    | AG  | 0.039       | 0.050  |               |        |
| 25%    | AB  | 0.038       | 0.038  | 0.034         | 0.040  |
| 25%    | ABG | 0.077       | 0.047  | 0.041         | 0.044  |
| 50%    | ABC | 0.040       | 0.046  | 0.046         | 0.042  |
| 50%    | AG  | 0.042       | 0.046  |               |        |
| 50%    | AB  | 0.038       | 0.038  | 0.041         |        |
| 50%    | ABG | 0.048       | 0.054  | 0.054         | 0.052  |
| 75%    | ABC | 0.046       | 0.044  | 0.048         | 0.043  |
| 75%    | AG  | 0.050       |        |               |        |
| 75%    | AB  | 0.038       | 0.044  | 0.041         |        |
| 75%    | ABG | 0.049       | 0.055  | 0.062         |        |
| Legend |     |             |        |               |        |
|        |     | Undesirable |        | Mis-operation |        |

| RM-05  |     | Base        | IBR    |               |        |
|--------|-----|-------------|--------|---------------|--------|
| FLTLOC | TYP |             | Case 1 | Case 2        | Case 3 |
| 0%     | ABC | 0.035       | 0.012  | 0.013         | 0.015  |
| 0%     | AG  | 0.034       | 0.014  | 0.026         | 0.022  |
| 0%     | AB  | 0.031       | 0.022  |               | 0.019  |
| 0%     | ABG | 0.038       | 0.013  | 0.015         | 0.018  |
| 25%    | ABC | 0.035       | 0.013  | 0.017         | 0.014  |
| 25%    | AG  | 0.038       | 0.014  | 0.015         | 0.026  |
| 25%    | AB  | 0.031       | 0.022  |               | 0.022  |
| 25%    | ABG | 0.036       | 0.018  | 0.014         | 0.014  |
| 50%    | ABC | 0.034       | 0.017  | 0.017         | 0.032  |
| 50%    | AG  | 0.043       | 0.014  | 0.014         | 0.029  |
| 50%    | AB  | 0.033       | 0.027  | 0.014         |        |
| 50%    | ABG | 0.038       | 0.014  | 0.017         | 0.015  |
| 75%    | ABC | 0.040       | 0.026  | 0.038         | 0.058  |
| 75%    | AG  | 0.049       | 0.013  | 0.047         | 0.054  |
| 75%    | AB  |             |        |               |        |
| 75%    | ABG |             | 0.053  | 0.058         | 0.036  |
| Legend |     |             |        |               |        |
|        |     | Undesirable |        | Mis-operation |        |

| RM-06  |     | Base        | IBR    |               |        |
|--------|-----|-------------|--------|---------------|--------|
| FLTLOC | TYP |             | Case 1 | Case 2        | Case 3 |
| 0%     | ABC | 0.032       | 0.026  | 0.026         | 0.037  |
| 0%     | AG  | 0.032       | 0.030  | 0.041         |        |
| 0%     | AB  | 0.028       | 0.025  | 0.038         | 0.052  |
| 0%     | ABG | 0.034       | 0.037  | 0.044         | 0.067  |
| 25%    | ABC | 0.031       | 0.026  | 0.030         | 0.036  |
| 25%    | AG  | 0.034       | 0.032  | 0.048         |        |
| 25%    | AB  | 0.030       | 0.030  | 0.042         | 0.053  |
| 25%    | ABG | 0.032       | 0.034  | 0.055         | 0.066  |
| 50%    | ABC | 0.031       | 0.054  | 0.050         | 0.055  |
| 50%    | AG  | 0.036       | 0.044  | 0.046         |        |
| 50%    | AB  | 0.030       | 0.043  | 0.050         | 0.059  |
| 50%    | ABG | 0.030       | 0.059  | 0.064         | 0.062  |
| 75%    | ABC | 0.050       | 0.056  | 0.057         | 0.056  |
| 75%    | AG  | 0.039       | 0.050  | 0.053         |        |
| 75%    | AB  | 0.037       | 0.057  | 0.054         | 0.070  |
| 75%    | ABG | 0.045       | 0.060  | 0.067         | 0.073  |
| Legend |     |             |        |               |        |
|        |     | Undesirable |        | Mis-operation |        |

- Root Cause for Zone 1 misoperations
  - Use of Zone 5 as instantaneous zone → missing stabilization
  - Wrong fault loop selection
  - Wrong direction determination
- Mitigation
  - Only use Zone 1 as instantaneous element
  - Select CCVT transient filter
  - Use specialized logic (proposed solution from manufacturer)

# Test Results Details – Zone 2 Misoperations

- Root Cause for Zone 2 misoperations
  - Wrong fault loop selection
  - Wrong direction determination
- Mitigation
  - Use specialized logic (proposed solution from manufacturer)

| RM-02  |     | Base        | IBR    |               |        |
|--------|-----|-------------|--------|---------------|--------|
| FLTLOC | TYP |             | Case 1 | Case 2        | Case 3 |
| 100%   | ABC | 0.530       | 0.532  | 0.531         | 0.533  |
| 100%   | AG  | 0.526       | 0.530  |               |        |
| 100%   | AB  | 0.529       | 0.535  | 0.532         | 0.535  |
| 100%   | ABG | 0.529       | 0.532  | 0.531         | 0.532  |
| 115%   | ABC | 0.530       | 0.530  | 0.530         | 0.536  |
| 115%   | AG  | 0.533       | 0.535  |               |        |
| 115%   | AB  | 0.535       | 0.534  | 0.535         | 0.531  |
| 115%   | ABG | 0.537       | 0.539  | 0.533         | 0.538  |
| 130%   | ABC | 0.541       |        |               |        |
| 130%   | AG  |             |        |               |        |
| 130%   | AB  |             |        |               |        |
| 130%   | ABG |             |        | 0.811         | 0.744  |
| Legend |     |             |        |               |        |
|        |     | Undesirable |        | Mis-operation |        |

| RM-03  |     | Base        | IBR    |               |        |
|--------|-----|-------------|--------|---------------|--------|
| FLTLOC | TYP |             | Case 1 | Case 2        | Case 3 |
| 100%   | ABC | 0.537       | 0.538  | 0.540         | 0.555  |
| 100%   | AG  | 0.531       | 0.529  | 0.538         | 0.541  |
| 100%   | AB  | 0.531       | 0.536  | 0.538         | 0.542  |
| 100%   | ABG | 0.529       | 0.538  | 0.537         | 0.534  |
| 115%   | ABC | 0.533       | 0.536  | 0.536         | 0.550  |
| 115%   | AG  | 0.534       | 0.542  | 0.539         | 0.533  |
| 115%   | AB  | 0.535       | 0.547  | 0.537         | 0.545  |
| 115%   | ABG | 0.534       | 0.539  | 0.532         | 0.542  |
| 130%   | ABC | 0.530       |        |               |        |
| 130%   | AG  | 0.533       |        |               |        |
| 130%   | AB  |             |        |               |        |
| 130%   | ABG |             |        |               |        |
| Legend |     |             |        |               |        |
|        |     | Undesirable |        | Mis-operation |        |

| RM-04  |     | Base        | IBR    |               |        |
|--------|-----|-------------|--------|---------------|--------|
| FLTLOC | TYP |             | Case 1 | Case 2        | Case 3 |
| 100%   | ABC | 0.528       | 0.533  | 0.532         | 0.534  |
| 100%   | AG  | 0.531       |        |               |        |
| 100%   | AB  | 0.531       | 0.533  | 0.532         |        |
| 100%   | ABG | 0.530       | 0.529  | 0.529         |        |
| 115%   | ABC | 0.535       | 0.534  | 0.534         | 0.534  |
| 115%   | AG  | 0.532       |        |               |        |
| 115%   | AB  | 0.534       | 0.539  | 0.538         |        |
| 115%   | ABG | 0.532       | 0.538  | 0.536         |        |
| 130%   | ABC |             |        |               |        |
| 130%   | AG  |             |        |               |        |
| 130%   | AB  |             |        |               |        |
| 130%   | ABG |             |        |               |        |
| Legend |     |             |        |               |        |
|        |     | Undesirable |        | Mis-operation |        |

| RM-05  |     | Base        | IBR    |               |        |
|--------|-----|-------------|--------|---------------|--------|
| FLTLOC | TYP |             | Case 1 | Case 2        | Case 3 |
| 100%   | ABC | 0.527       | 0.522  | 0.513         | 0.523  |
| 100%   | AG  | 0.530       | 0.515  | 0.529         | 0.527  |
| 100%   | AB  | 0.529       |        |               |        |
| 100%   | ABG | 0.526       | 0.522  | 0.525         | 0.527  |
| 115%   | ABC | 0.530       | 0.529  | 0.526         | 0.535  |
| 115%   | AG  | 0.528       | 0.554  | 0.541         | 0.541  |
| 115%   | AB  | 0.545       |        |               |        |
| 115%   | ABG | 0.543       | 0.559  | 0.538         | 0.534  |
| 130%   | ABC |             |        |               |        |
| 130%   | AG  |             |        |               |        |
| 130%   | AB  |             |        |               |        |
| 130%   | ABG |             |        |               |        |
| Legend |     |             |        |               |        |
|        |     | Undesirable |        | Mis-operation |        |

| RM-06  |     | Base        | IBR    |               |        |
|--------|-----|-------------|--------|---------------|--------|
| FLTLOC | TYP |             | Case 1 | Case 2        | Case 3 |
| 100%   | ABC | 0.514       | 0.515  | 0.516         | 0.525  |
| 100%   | AG  | 0.516       | 0.525  | 0.551         |        |
| 100%   | AB  | 0.517       | 0.528  | 0.527         |        |
| 100%   | ABG | 0.518       | 0.515  | 0.590         |        |
| 115%   | ABC | 0.515       | 0.516  | 0.545         | 0.526  |
| 115%   | AG  | 0.514       | 0.529  |               |        |
| 115%   | AB  | 0.522       | 0.526  | 0.530         |        |
| 115%   | ABG | 0.522       | 0.550  |               |        |
| 130%   | ABC |             |        |               |        |
| 130%   | AG  |             |        |               |        |
| 130%   | AB  |             |        |               |        |
| 130%   | ABG | 0.662       |        |               |        |
| Legend |     |             |        |               |        |
|        |     | Undesirable |        | Mis-operation |        |

# Test Results Details – Zone 4 Misoperations

| RM-02  |     | Base        | IBR    |               |        |
|--------|-----|-------------|--------|---------------|--------|
| FLTLOC | TYP |             | Case 1 | Case 2        | Case 3 |
| 100%   | ABC | 1.023       | 1.024  | 1.023         | 1.025  |
| 100%   | AG  | 1.021       | 1.019  |               |        |
| 100%   | AB  | 1.021       | 1.026  | 1.025         |        |
| 100%   | ABG | 1.022       | 1.032  | 1.025         | 1.023  |
| 115%   | ABC | 1.023       | 1.030  | 1.030         | 1.024  |
| 115%   | AG  | 1.022       | 1.021  |               |        |
| 115%   | AB  | 1.025       | 1.030  | 1.033         |        |
| 115%   | ABG | 1.026       | 1.029  | 1.033         | 1.046  |
| 130%   | ABC | 1.025       | 1.029  | 1.031         | 1.025  |
| 130%   | AG  | 1.025       |        |               |        |
| 130%   | AB  | 1.028       | 1.026  | 1.032         |        |
| 130%   | ABG | 1.023       | 1.030  | 1.032         | 1.026  |
| 145%   | ABC | 1.029       | 1.030  | 1.031         | 1.025  |
| 145%   | AG  | 1.022       |        |               |        |
| 145%   | AB  | 1.028       |        | 1.032         |        |
| 145%   | ABG | 1.027       | 1.032  | 1.034         |        |
| 160%   | ABC | 1.030       | 1.034  | 1.031         | 1.054  |
| 160%   | AG  | 1.026       |        |               |        |
| 160%   | AB  | 1.029       |        | 1.032         |        |
| 160%   | ABG | 1.030       |        | 1.034         |        |
| Legend |     |             |        |               |        |
|        |     | Undesirable |        | Mis-operation |        |

| RM-03  |     | Base        | IBR    |               |        |
|--------|-----|-------------|--------|---------------|--------|
| FLTLOC | TYP |             | Case 1 | Case 2        | Case 3 |
| 100%   | ABC | 1.032       | 1.038  | 1.039         | 1.054  |
| 100%   | AG  | 1.034       | 1.028  | 1.038         | 1.040  |
| 100%   | AB  | 1.026       | 1.035  | 1.037         | 1.041  |
| 100%   | ABG | 1.029       | 1.038  | 1.035         | 1.034  |
| 115%   | ABC | 1.037       | 1.034  | 1.034         | 1.050  |
| 115%   | AG  | 1.033       | 1.042  | 1.038         | 1.032  |
| 115%   | AB  | 1.031       | 1.046  | 1.036         | 1.043  |
| 115%   | ABG | 1.032       | 1.040  | 1.031         | 1.041  |
| 130%   | ABC | 1.031       | 1.037  | 1.036         | 1.057  |
| 130%   | AG  | 1.031       | 1.032  | 1.031         | 1.057  |
| 130%   | AB  | 1.033       | 1.039  | 1.038         | 1.042  |
| 130%   | ABG | 1.034       | 1.042  | 1.031         | 1.041  |
| 145%   | ABC | 1.034       | 1.050  | 1.041         | 1.052  |
| 145%   | AG  | 1.035       | 1.037  | 1.037         | 1.070  |
| 145%   | AB  | 1.041       | 1.047  | 1.042         | 1.038  |
| 145%   | ABG | 1.034       | 1.040  | 1.037         | 1.042  |
| 160%   | ABC | 1.033       | 1.054  | 1.044         | 1.054  |
| 160%   | AG  | 1.032       | 1.040  | 1.041         | 1.058  |
| 160%   | AB  | 1.039       | 1.065  | 1.045         | 1.065  |
| 160%   | ABG | 1.034       | 1.037  | 1.038         | 1.037  |
| Legend |     |             |        |               |        |
|        |     | Undesirable |        | Mis-operation |        |

| RM-04  |     | Base        | IBR    |               |        |
|--------|-----|-------------|--------|---------------|--------|
| FLTLOC | TYP |             | Case 1 | Case 2        | Case 3 |
| 100%   | ABC | 1.023       | 1.028  | 1.027         | 1.028  |
| 100%   | AG  | 1.024       |        |               |        |
| 100%   | AB  | 1.027       | 1.028  | 1.029         |        |
| 100%   | ABG | 1.023       | 1.037  | 1.022         |        |
| 115%   | ABC | 1.025       | 1.029  | 1.030         | 1.026  |
| 115%   | AG  | 1.023       |        |               |        |
| 115%   | AB  | 1.027       | 1.030  | 1.030         |        |
| 115%   | ABG | 1.025       | 1.024  | 1.022         |        |
| 130%   | ABC | 1.028       | 1.032  | 1.030         | 1.028  |
| 130%   | AG  | 1.026       |        |               |        |
| 130%   | AB  | 1.028       | 1.033  | 1.033         |        |
| 130%   | ABG | 1.027       | 1.028  | 1.024         |        |
| 145%   | ABC | 1.031       | 1.033  | 1.031         | 1.024  |
| 145%   | AG  | 1.026       |        |               |        |
| 145%   | AB  |             | 1.034  | 1.034         |        |
| 145%   | ABG | 1.032       |        | 1.066         |        |
| 160%   | ABC | 1.032       | 1.036  | 1.034         | 1.026  |
| 160%   | AG  | 1.030       |        |               |        |
| 160%   | AB  |             |        | 1.037         |        |
| 160%   | ABG |             |        |               |        |
| Legend |     |             |        |               |        |
|        |     | Undesirable |        | Mis-operation |        |

- Root Cause for Zone 4 misoperations
  - Wrong fault loop selection
  - Wrong direction determination
- Mitigation
  - Use specialized logic (proposed solution from manufacturer)
  - Use stabilization logic to stabilize intermittent pick-up

| RM-05  |     | Base        | IBR    |               |        |
|--------|-----|-------------|--------|---------------|--------|
| FLTLOC | TYP |             | Case 1 | Case 2        | Case 3 |
| 100%   | ABC | 1.027       | 1.022  | 1.016         | 1.017  |
| 100%   | AG  | 1.027       | 1.012  | 1.012         | 1.014  |
| 100%   | AB  | 1.026       |        |               |        |
| 100%   | ABG | 1.029       | 1.022  | 1.018         | 1.015  |
| 115%   | ABC | 1.026       | 1.026  | 1.022         | 1.022  |
| 115%   | AG  | 1.028       | 1.014  | 1.014         | 1.014  |
| 115%   | AB  | 1.031       |        |               |        |
| 115%   | ABG | 1.030       | 1.016  | 1.016         | 1.017  |
| 130%   | ABC | 1.025       | 1.020  | 1.021         | 1.020  |
| 130%   | AG  | 1.028       | 1.018  | 1.014         | 1.026  |
| 130%   | AB  | 1.027       |        |               |        |
| 130%   | ABG | 1.026       | 1.022  | 1.015         | 1.026  |
| 145%   | ABC | 1.030       | 1.029  | 1.025         | 1.022  |
| 145%   | AG  | 1.028       | 1.023  | 1.015         | 1.025  |
| 145%   | AB  |             |        |               |        |
| 145%   | ABG | 1.026       | 1.023  | 1.024         | 1.022  |
| 160%   | ABC | 1.025       | 1.030  | 1.021         | 1.027  |
| 160%   | AG  | 1.023       | 1.025  | 1.030         | 1.026  |
| 160%   | AB  |             |        |               |        |
| 160%   | ABG | 1.026       | 1.022  | 1.025         | 1.026  |
| Legend |     |             |        |               |        |
|        |     | Undesirable |        | Mis-operation |        |

| RM-06  |     | Base        | IBR    |               |        |
|--------|-----|-------------|--------|---------------|--------|
| FLTLOC | TYP |             | Case 1 | Case 2        | Case 3 |
| 100%   | ABC | 1.022       | 1.024  | 1.024         | 1.023  |
| 100%   | AG  | 1.022       | 1.023  | 1.051         |        |
| 100%   | AB  | 1.023       | 1.024  | 1.025         |        |
| 100%   | ABG | 1.026       | 1.023  |               |        |
| 115%   | ABC | 1.022       | 1.024  | 1.024         | 1.022  |
| 115%   | AG  | 1.022       | 1.022  |               |        |
| 115%   | AB  | 1.024       | 1.026  | 1.030         |        |
| 115%   | ABG | 1.022       | 1.027  |               |        |
| 130%   | ABC | 1.022       | 1.024  | 1.025         | 1.024  |
| 130%   | AG  | 1.023       | 1.031  |               |        |
| 130%   | AB  | 1.023       | 1.028  | 1.030         |        |
| 130%   | ABG | 1.024       |        |               |        |
| 145%   | ABC | 1.023       | 1.026  | 1.024         | 1.023  |
| 145%   | AG  | 1.023       |        |               |        |
| 145%   | AB  | 1.024       | 1.031  | 1.046         |        |
| 145%   | ABG | 1.028       |        |               |        |
| 160%   | ABC | 1.024       | 1.028  | 1.026         | 1.054  |
| 160%   | AG  | 1.022       |        |               |        |
| 160%   | AB  | 1.027       | 1.046  | 1.046         |        |
| 160%   | ABG | 1.027       |        |               |        |
| Legend |     |             |        |               |        |
|        |     | Undesirable |        | Mis-operation |        |


# Evaluated Vendor-Recommended Mitigation Solutions

- Relay model RM-02 – Vendor suggested to only use zone 1 for high-speed tripping instead of using Quadrilateral characteristics with zone 5 (it has the same reach as zone 1) for high-speed tripping
  - Zone 2 to 5 are used for delayed trip applications
- Results show some improvement
  - Reduced the total number of misoperations from 8 to 4 for zone 2, mostly for Hi-IBR case #2
  - Similar results for zone 4
- Another relay model RM-04
  - Vendor recommended to disable the CCVT transient compensation for zone 1 misoperation
- Results mixed
  - Solution solves the underreach issue for Hi-IBR case #1 and #2, but does not for Hi-IBR case #3, and
  - The solution created the overreach misoperation issues

# Evaluated Proposed Mitigation Solutions

- For mitigating incorrect directional determination – Use most reliable polarizing quantity for directional element
  - Ground directional polarization priorities:  $V_0 \geq I_0 \geq V_2$
  - Phase directional polarization priorities:  $V_1 \geq V_2$
  - Decrease the sensitivity of the negative-sequence based directional elements
- Results show great improvement but not 100%

- For mitigating unstable fault type selection – Use a sample-and-hold logic
  - The logic as shown below to sustain the Zone 4 pickup triggered by Z4G or Z4P
- Results show significant improvement but not 100%



Section 4

# CONCLUSIONS

# Conclusions

- This directional elements and fault type identification logic are the most impacted relay protection functions.
- The key negative impact on distance protection is the under-reach issue. Our investigation suggests that the unconventional angle relationship between voltage and current is the leading cause for this project.
- No obvious negative impact is observed on the current differential protection.
- High IBR penetration negatively impacts most of relay models tested in this project, but the severity level varies significantly.
- We developed two mitigation strategies for directional and fault identification issues, respectively. These mitigation solutions have shown to be effective in reducing the number of misoperations. Still, they are insufficient to correct all reported misoperations, and some relay models lack the necessary setting customization to implement the proposed mitigation strategy.
- Further investigation will be needed to determine whether setting customization would be sufficient to mitigate the identified issues. If not, new relaying algorithms/methods must be developed and implemented to address the identified issues fully.