



**QUANTA
TECHNOLOGY**
A QUANTA SERVICES COMPANY

JANUARY 4, 2024

Transmission Line Protection Under High Penetration of Inverter-based Resources: Impact Assessments and Mitigation Solutions

Juergen Holbach, Henry Chao, Zheyuan Cheng, Yi Hu
Quanta Technology

Bruce Fardanesh, Hossein Hooshyar, Thanh Nguyen,
Adam O'Leary
New York Power Authority


Peter Haswell, Louis E. Seiter, Charles T. Hitchings
National Grid

Proprietary & Confidential
© 2024 Quanta Technology, LLC

QUANTA-TECHNOLOGY.COM



Presentation Outline





Project Approach Overview



Project Approach Overview

Pickup and electric feeder and relaying schemes

Electric feeder selection

Relay scheme selection

Create simulation models

IBR RTDS models development

RTDS system model with high IBRs

Setup the lab for hardware-the-the-loop (HIL) testing

Test plan and wiring diagram development

Agile lab HIL test setup

Assess impact

Perform the test per test plan

Test results analysis and impact assessment

Develop mitigation solutions

Mitigation solution development

Mitigation solution verification

- **Focus** on the selection where the impact will be felt the most and the earliest
- **Develop** the model of the selected feeder
- **Assess** the impact by HIL testing with real relaying products
- **Develop** mitigation solutions and verify with the same HIL testing setup



Line Selection and Simulation Analysis





Specific Line Selection

The line selection criteria:

- At one of the weak spots in the focus area
- Close to many wind farms, solar farms, and BESS

The results:

- A 230 kV line B-D was selected
- A 115 kV line was dropped



https://www.nyiso.com/documents/20142/1397960/nyca_zonemaps.pdf



Developed Hi-IBR System Models

IBR projects added	Capacity (MW)
Franklin Solar	150
Brookside Solar	100
North Country Wind	298
Bull Run Wind	304
Bull Run Solar Energy Center	170
North Ridge Wind	100
Bangor Solar	107
North Country Energy Storage	20
Bull Run II Wind	145

In addition to IBRs added, the Hi-IBR system model (Hi-IBR case #1)

- Reduced large hydro plant output by 50%
- Retired a 315 MW combined cycle generation, and
- The other side is represented by a weak source (SCR=2.5 and $X/R < 5$)

Two variations of the Hi-IBR case #1:

- Hi-IBR case #2: Take the parallel line C-E2 out-of-service
- Hi-IBR case #3: Further disconnect the weak source from case #2



Fault Current Magnitude Changes

- Weak end I1 increased due to increased IBR generation
- Weak end I2 is decreased for all unbalanced faults
- I0 fault current is increased for faults involving ground

		Fault current magnitude %change vs. base case								
Terminal	Fault type	I1			I2			I0		
		IBR #1	IBR #2	IBR #3	IBR #1	IBR #2	IBR #3	IBR #1	IBR #2	IBR #3
Strong end	AG	-8%	-6%	-11%	50%	57%	65%	23%	22%	16%
Strong end	AB	-19%	-17%	-22%	16%	22%	25%	N/A	N/A	N/A
Strong end	ABG	9%	12%	11%	-4%	1%	-2%	92%	91%	93%
Strong end	ABC	12%	16%	15%	N/A	N/A	N/A	N/A	N/A	N/A
Weak end	AG	29%	21%	33%	-26%	-33%	-28%	24%	22%	15%
Weak end	AB	25%	14%	12%	-43%	-48%	-45%	N/A	N/A	N/A
Weak end	ABG	46%	28%	13%	-52%	-57%	-56%	92%	91%	91%
Weak end	ABC	21%	2%	-20%	N/A	N/A	N/A	N/A	N/A	N/A



Negative Sequence Voltage and Current Angle Difference Changes

Negative-sequence voltage and current angle relationship


- Strong end shows consistent angle difference at around minus 100-degrees regardless of fault types and simulation scenarios
- Weak end presents decrease in the angle difference to as low as around minus 200-degrees – much larger deviation than around minus 90 degrees in a system dominated by conventional generation

No noticeable changes are observed for positive and zero sequence angle relationship

Fault type	$\angle V2 - \angle I2$ angle (degree)			
	Base	IBR penetration		
		#1	#2	#3
AG	-97	-143	-164	-198
AB	-97	-143	-166	-199
ABG	-97	-143	-163	-199



Impact of Declining Fault Current Levels on Protection



Impact on over current protection

- **Minimum fault current** is critical for pickup settings in overcurrent functions
- The overcurrent function is typically used as backup protection or for the supervision of unit (differential) and non-unit (distance) protection
- During protection studies, the minimum current is determined by selecting an N-1 contingency that provides the lowest fault current
- **Maximum fault current** is used for inverse overcurrent elements to determine the correct time dial (time grading) setting




Impact of IBR Fault Current Levels on Protection

Impact on distance protection loop selection

- The selection of the correct fault loop is essential for the performance of the distance relay
- Different manufacturer implement different algorithms to master this complex task
- Typical tasks performed include:
 - Impedance comparison
 - Symmetrical component analysis
 - Load compensation
 - Pattern recognition
- Most assumption used in this algorithm are not correct anymore!

Wrong loop selection causes over or under function of the distance relay






Impact of IBR Fault Current Levels on Protection


Impact on distance protection directional element

- Direction may be determined together with the impedance measurement
- **But** problems may arise in certain cases (e.g., close-in faults)
- **Separate directional determination required!**
 - Cross-polarization
 - Memorized-polarization

Both solutions assume that the system voltage angle will not change during a fault




Method 1



healthy-phase voltage
(phase-to-phase voltage)

Method 2




voltage memory
(pre-fault voltage)



Impact of IBR Fault Current Levels on Protection

Impact on distance protection accuracy

- Fault current contribution is limited to 1.0-1.5 pu of rated inverter current
- Source impedance of inverter-based generation is higher than classical synchronous generation
- The source-to-line-impedance-ratio (SIR) is a value that is used by National Grid to determine whether non-unit protection (distance elements) can be used on a particular line.
- The SIR ratios will increase in relation to the growing amount of inverter-based generation
- This is important as when the SIR ratio is above 30, non-unit protection becomes unreliable due to that as the accuracy decreases and operating time increases






Impact of IBR Fault Current Levels on Protection

Directional element based on I_2

- The angle between I_2 and V_2 is used to determine a forward or reverse fault
- IBRs don't typically provide I_2
- The angle between I_2 and V_2 of an IBR-produced I_2 is determined by control software in the inverter and can have any value

Forward fault with a synchronous generator







Impact of Declining Fault Current Levels on Protection

Impact on differential protection

- The differential protection principle is used for busbar, transformer, and line protection applications
- The basic principle is not affected by lower fault currents as long as the total fault current exceeds the pickup settings for the differential elements
- However, the impact of changing fault current characteristics (e.g., phase-angle changes) due to the application of IBRs requires further study






HIL Setup and Testing Results



Protective Relay HIL Testbed




The HIL testbed includes:

- Nine relays for six relay models from five relay manufacturers
- RTDS real-time simulator
- Amplifiers
- Ethernet switch for network communication
- Workstations

The HIL testbed can be accessed remotely



HIL Relay Testing Setup Diagram





Test Results Details – Zone 1 Misoperations

RM-01		Base	IBR		
FLTLOC	TYP		Case 1	Case 2	Case 3
0%	ABC	0.048	0.046	0.048	0.050
0%	AG	0.056	0.052	0.058	
0%	AB	0.051	0.042	0.054	0.076
0%	ABG	0.054	0.050	0.062	0.063
25%	ABC	0.049	0.049	0.051	0.053
25%	AG	0.057	0.053	0.047	
25%	AB	0.054	0.044	0.046	0.063
25%	ABG	0.053	0.051	0.065	0.062
50%	ABC	0.054	0.050	0.058	0.057
50%	AG	0.056	0.054	0.055	
50%	AB	0.050	0.040	0.063	0.067
50%	ABG	0.049	0.054	0.065	
75%	ABC	0.055	0.051	0.060	0.067
75%	AG				
75%	AB	0.054	0.039	0.075	0.082
75%	ABG	0.050	0.054	0.070	
Legend					
		Undesirable		Mis-operation	

RM-02		Base	IBR		
FLTLOC	TYP		Case 1	Case 2	Case 3
0%	ABC	0.034	0.042		
0%	AG	0.033	0.034	0.034	
0%	AB	0.032	0.036	0.039	0.035
0%	ABG	0.035	0.049	0.045	0.048
25%	ABC	0.039	0.043	0.045	0.063
25%	AG	0.037	0.040		
25%	AB	0.038	0.038	0.043	0.036
25%	ABG	0.042	0.048	0.044	0.042
50%	ABC	0.045	0.042	0.039	0.047
50%	AG	0.042	0.041		
50%	AB	0.043	0.040	0.042	0.042
50%	ABG	0.044	0.051	0.049	0.046
75%	ABC	0.054	0.049	0.063	0.046
75%	AG	0.056	0.048		
75%	AB	0.056	0.066	0.070	0.077
75%	ABG	0.057	0.070	0.070	0.050
Legend					
		Undesirable		Mis-operation	

RM-03		Base	IBR		
FLTLOC	TYP		Case 1	Case 2	Case 3
0%	ABC	0.042	0.043	0.042	0.048
0%	AG	0.043	0.041	0.038	0.034
0%	AB	0.037	0.041	0.034	0.038
0%	ABG	0.050	0.043	0.052	0.044
25%	ABC	0.041	0.042	0.046	0.044
25%	AG	0.042	0.039	0.044	0.032
25%	AB	0.039	0.038	0.035	0.034
25%	ABG	0.044	0.048	0.049	0.046
50%	ABC	0.043	0.044	0.042	0.046
50%	AG	0.042	0.047	0.038	0.041
50%	AB	0.042	0.037	0.042	0.038
50%	ABG	0.041	0.050	0.049	0.043
75%	ABC	0.046	0.051	0.050	0.047
75%	AG	0.038	0.040	0.043	0.038
75%	AB	0.038	0.040	0.042	0.042
75%	ABG	0.043	0.047	0.050	0.049
Legend					
		Undesirable		Mis-operation	

RM-04		Base	IBR		
FLTLOC	TYP		Case 1	Case 2	Case 3
0%	ABC	0.037	0.040	0.040	0.038
0%	AG	0.038	0.037		
0%	AB	0.030	0.036	0.034	
0%	ABG	0.042	0.038	0.047	0.051
25%	ABC	0.041	0.038	0.041	0.045
25%	AG	0.039	0.050		
25%	AB	0.038	0.038	0.034	0.040
25%	ABG	0.077	0.047	0.041	0.044
50%	ABC	0.040	0.046	0.046	0.042
50%	AG	0.042	0.046		
50%	AB	0.038	0.038	0.041	
50%	ABG	0.048	0.054	0.054	0.052
75%	ABC	0.046	0.044	0.048	0.043
75%	AG	0.050			
75%	AB	0.038	0.044	0.041	
75%	ABG	0.049	0.055	0.062	
Legend					
		Undesirable		Mis-operation	

RM-05		Base	IBR		
FLTLOC	TYP		Case 1	Case 2	Case 3
0%	ABC	0.035	0.012	0.013	0.015
0%	AG	0.034	0.014	0.026	0.022
0%	AB	0.031	0.022		0.019
0%	ABG	0.038	0.013	0.015	0.018
25%	ABC	0.035	0.013	0.017	0.014
25%	AG	0.038	0.014	0.015	0.026
25%	AB	0.031	0.022		0.022
25%	ABG	0.036	0.018	0.014	0.014
50%	ABC	0.034	0.017	0.017	0.032
50%	AG	0.043	0.014	0.014	0.029
50%	AB	0.033	0.027	0.014	
50%	ABG	0.038	0.014	0.017	0.015
75%	ABC	0.040	0.026	0.038	0.058
75%	AG	0.049	0.013	0.047	0.054
75%	AB				
75%	ABG		0.053	0.058	0.036
Legend					
		Undesirable		Mis-operation	

RM-06		Base	IBR		
FLTLOC	TYP		Case 1	Case 2	Case 3
0%	ABC	0.032	0.026	0.026	0.037
0%	AG	0.032	0.030	0.041	
0%	AB	0.028	0.025	0.038	0.052
0%	ABG	0.034	0.037	0.044	0.067
25%	ABC	0.031	0.026	0.030	0.036
25%	AG	0.034	0.032	0.048	
25%	AB	0.030	0.030	0.042	0.053
25%	ABG	0.032	0.034	0.055	0.066
50%	ABC	0.031	0.054	0.050	0.055
50%	AG	0.036	0.044	0.046	
50%	AB	0.030	0.043	0.050	0.059
50%	ABG	0.030	0.059	0.064	0.062
75%	ABC	0.050	0.056	0.057	0.056
75%	AG	0.039	0.050	0.053	
75%	AB	0.037	0.057	0.054	0.070
75%	ABG	0.045	0.060	0.067	0.073
Legend					
		Undesirable		Mis-operation	

Root cause for Zone 1 misoperations:

- Use of Zone 5 as instantaneous zone → missing stabilization
- Wrong fault type selection
- Wrong direction determination

Mitigation

- Only use Zone 1 as an instantaneous element
- Select CCVT transient filter
- Use specialized logic (proposed solution from manufacturer)



Test Results Details – Zone 2 Misoperations

Root cause for Zone 2 misoperations:

- Wrong fault type selection
- Wrong direction determination

Mitigation:

- Use specialized logic (proposed solution from manufacturer)

RM-02		Base	IBR		
FLTLOC	TYP		Case 1	Case 2	Case 3
100%	ABC	0.530	0.532	0.531	0.533
100%	AG	0.526	0.530		
100%	AB	0.529	0.535	0.532	0.535
100%	ABG	0.529	0.532	0.531	0.532
115%	ABC	0.530	0.530	0.530	0.536
115%	AG	0.533	0.535		
115%	AB	0.535	0.534	0.535	0.531
115%	ABG	0.537	0.539	0.533	0.538
130%	ABC	0.541			
130%	AG				
130%	AB				
130%	ABG		0.811	0.744	
Legend					
		Undesirable	Mis-operation		

RM-03		Base	IBR		
FLTLOC	TYP		Case 1	Case 2	Case 3
100%	ABC	0.537	0.538	0.540	0.555
100%	AG	0.531	0.529	0.538	0.541
100%	AB	0.531	0.536	0.538	0.542
100%	ABG	0.529	0.538	0.537	0.534
115%	ABC	0.533	0.536	0.536	0.550
115%	AG	0.534	0.542	0.539	0.533
115%	AB	0.535	0.547	0.537	0.545
115%	ABG	0.534	0.539	0.532	0.542
130%	ABC	0.530			
130%	AG	0.533			
130%	AB				
130%	ABG				
Legend					
		Undesirable	Mis-operation		

RM-04		Base	IBR		
FLTLOC	TYP		Case 1	Case 2	Case 3
100%	ABC	0.528	0.533	0.532	0.534
100%	AG	0.531			
100%	AB	0.531	0.533	0.532	
100%	ABG	0.530	0.529	0.529	
115%	ABC	0.535	0.534	0.534	0.534
115%	AG	0.532			
115%	AB	0.534	0.539	0.538	
115%	ABG	0.532	0.538	0.536	
130%	ABC				
130%	AG				
130%	AB				
130%	ABG				
Legend					
		Undesirable	Mis-operation		

RM-05		Base	IBR		
FLTLOC	TYP		Case 1	Case 2	Case 3
100%	ABC	0.527	0.522	0.513	0.523
100%	AG	0.530	0.515	0.529	0.527
100%	AB	0.529			
100%	ABG	0.526	0.522	0.525	0.527
115%	ABC	0.530	0.529	0.526	0.535
115%	AG	0.528	0.554	0.541	0.541
115%	AB	0.545			
115%	ABG	0.543	0.559	0.538	0.534
130%	ABC				
130%	AG				
130%	AB				
130%	ABG				
Legend					
		Undesirable	Mis-operation		

RM-06		Base	IBR		
FLTLOC	TYP		Case 1	Case 2	Case 3
100%	ABC	0.514	0.515	0.516	0.525
100%	AG	0.516	0.525	0.551	
100%	AB	0.517	0.528	0.527	
100%	ABG	0.518	0.515	0.590	
115%	ABC	0.515	0.516	0.545	0.526
115%	AG	0.514	0.529		
115%	AB	0.522	0.526	0.530	
115%	ABG	0.522	0.550		
130%	ABC				
130%	AG				
130%	AB				
130%	ABG	0.662			
Legend					
		Undesirable	Mis-operation		



Test Results Details – Zone 4 Misoperations

Root cause for Zone 4 misoperations

- Wrong fault loop selection
- Wrong direction determination

Mitigation

- Use specialized logic (proposed solution from manufacturer)
- Use stabilization logic to stabilize intermittent pick-up

RM-02						RM-03						RM-04					
FLTLOC	TYP	Base	Case 1	Case 2	Case 3	FLTLOC	TYP	Base	Case 1	Case 2	Case 3	FLTLOC	TYP	Base	Case 1	Case 2	Case 3
100%	ABC	1.023	1.024	1.023	1.025	100%	ABC	1.032	1.038	1.039	1.054	100%	ABC	1.023	1.028	1.027	1.028
100%	AG	1.021	1.019			100%	AG	1.034	1.028	1.038	1.040	100%	AG	1.024			
100%	AB	1.021	1.026	1.025		100%	AB	1.026	1.035	1.037	1.041	100%	AB	1.027	1.028	1.029	
100%	ABG	1.022	1.032	1.025	1.023	100%	ABG	1.029	1.038	1.035	1.034	100%	ABG	1.023	1.037	1.022	
115%	ABC	1.023	1.030	1.030	1.024	115%	ABC	1.037	1.034	1.034	1.050	115%	ABC	1.025	1.029	1.030	1.026
115%	AG	1.022	1.021			115%	AG	1.033	1.042	1.038	1.032	115%	AG	1.023			
115%	AB	1.025	1.030	1.033		115%	AB	1.031	1.046	1.036	1.043	115%	AB	1.027	1.030	1.030	
115%	ABG	1.026	1.029	1.033	1.046	115%	ABG	1.032	1.040	1.031	1.041	115%	ABG	1.025	1.024	1.022	
130%	ABC	1.025	1.029	1.031	1.025	130%	ABC	1.031	1.037	1.036	1.057	130%	ABC	1.028	1.032	1.030	1.028
130%	AG	1.025				130%	AG	1.031	1.032	1.031	1.057	130%	AG	1.026			
130%	AB	1.028	1.026	1.032		130%	AB	1.033	1.039	1.038	1.042	130%	AB	1.028	1.033	1.033	
130%	ABG	1.023	1.030	1.032	1.026	130%	ABG	1.034	1.042	1.031	1.041	130%	ABG	1.027	1.028	1.024	
145%	ABC	1.029	1.030	1.031	1.025	145%	ABC	1.034	1.050	1.041	1.052	145%	ABC	1.031	1.033	1.031	1.024
145%	AG	1.022				145%	AG	1.035	1.037	1.037	1.070	145%	AG	1.026			
145%	AB	1.028		1.032		145%	AB	1.041	1.047	1.042	1.038	145%	AB		1.034	1.034	
145%	ABG	1.027	1.032	1.034		145%	ABG	1.034	1.040	1.037	1.042	145%	ABG	1.032		1.066	
160%	ABC	1.030	1.034	1.031	1.054	160%	ABC	1.033	1.054	1.044	1.054	160%	ABC	1.032	1.036	1.034	1.026
160%	AG	1.026				160%	AG	1.032	1.040	1.041	1.058	160%	AG	1.030			
160%	AB	1.029		1.032		160%	AB	1.039	1.065	1.045	1.065	160%	AB			1.037	
160%	ABG	1.030		1.034		160%	ABG	1.034	1.037	1.038	1.037	160%	ABG				

RM-05						RM-06					
FLTLOC	TYP	Base	Case 1	Case 2	Case 3	FLTLOC	TYP	Base	Case 1	Case 2	Case 3
100%	ABC	1.027	1.022	1.016	1.017	100%	ABC	1.022	1.024	1.024	1.023
100%	AG	1.027	1.012	1.012	1.014	100%	AG	1.022	1.023	1.051	
100%	AB	1.026				100%	AB	1.023	1.024	1.025	
100%	ABG	1.029	1.022	1.018	1.015	100%	ABG	1.026	1.023		
115%	ABC	1.026	1.026	1.022	1.022	115%	ABC	1.022	1.024	1.024	1.022
115%	AG	1.028	1.014	1.014	1.014	115%	AG	1.022	1.022		
115%	AB	1.031				115%	AB	1.024	1.026	1.030	
115%	ABG	1.030	1.016	1.016	1.017	115%	ABG	1.022	1.027		
130%	ABC	1.025	1.020	1.021	1.020	130%	ABC	1.022	1.024	1.025	1.024
130%	AG	1.028	1.018	1.014	1.026	130%	AG	1.023	1.031		
130%	AB	1.027				130%	AB	1.023	1.028	1.030	
130%	ABG	1.026	1.022	1.015	1.026	130%	ABG	1.024			
145%	ABC	1.030	1.029	1.025	1.022	145%	ABC	1.023	1.026	1.024	1.023
145%	AG	1.028	1.023	1.015	1.025	145%	AG	1.023			
145%	AB					145%	AB	1.024	1.031	1.046	
145%	ABG	1.026	1.023	1.024	1.022	145%	ABG	1.028			
160%	ABC	1.025	1.030	1.021	1.027	160%	ABC	1.024	1.028	1.026	1.054
160%	AG	1.023	1.025	1.030	1.026	160%	AG	1.022			
160%	AB					160%	AB	1.027	1.046	1.046	
160%	ABG	1.026	1.022	1.025	1.026	160%	ABG	1.027			



Evaluated Vendor Recommended Mitigation Solutions

Relay model RM-02

- Vendor suggested to only use zone 1 for high-speed tripping instead of using quadrilateral characteristics with zone 5 (it has the same reach as zone 1) for high-speed tripping
- Zones 2 to 5 are used for delayed trip applications

Results show some improvement

- Reduced the total number of misoperations from eight to four for zone 2, mostly for Hi-IBR case #2
- Similar results for zone 4

Relay model RM-04

- Vendor recommended to disable the CCVT transient compensation for zone 1 misoperation

Results mixed

- Solution solves the underreach issue for Hi-IBR cases #1 and #2, but does not for Hi-IBR case #3
- The solution created the overreach misoperation issues



Evaluated Proposed Mitigation Solutions

For mitigating incorrect directional determination – use the most reliable polarizing quantity for the directional element:


- Ground directional polarization priorities:
 $V_0 \geq I_0 \geq V_2$
- Phase directional polarization priorities:
 $V_1 \geq V_2$
- Decrease the sensitivity of the negative-sequence based directional elements

Results show a great improvement, but not 100%

For mitigating unstable fault type selection – use a sample-and-hold logic:

- The logic as shown below to sustain the Zone 4 pickup triggered by Z4G or Z4P

Results show significant improvement, but not 100%





Conclusions



Conclusions

- + **Directional elements and fault type identification logic are the most impacted relay protection functions.**
- + **The key negative impact on distance protection is the under-reach issue.** Our investigation suggests that the unconventional angle relationship between voltage and current is the leading cause for this project.
- + **No obvious negative impact is observed on the current differential protection.**
- + **High IBR penetration negatively impacts most of relay models** tested in this project, but the severity level varies significantly.
- + **We developed two mitigation strategies for directional and fault identification issues, respectively.** These mitigation solutions have shown to be effective in reducing the number of misoperations. Still, they are insufficient to correct all reported misoperations, and some relay models lack the necessary setting customization to implement the proposed mitigation strategy.
- + **Further investigation will be needed** to determine whether setting customization would be sufficient to mitigate the identified issues. If not, new relaying algorithms/methods must be developed and implemented to address the identified issues fully.



Questions or Comments?





Accelerate Successful Outcomes for Your Projects



919-334-3000



[quanta-technology.com](https://www.quanta-technology.com)




info@quanta-technology.com



[linkedin.com/company/quanta-technology/](https://www.linkedin.com/company/quanta-technology/)



twitter.com/quantatech



Contact us and follow us today