

NYISO Self-Certification

Description:

NYSRC Reliability Rule Reference (No. and Name)

C.1: Establishing Operating Transfer Capabilities

NYSRC Requirement(s) for which compliance is being self-certified

R2. The *NYISO* shall maintain procedures and systems that ensure that appropriate actions are taken when *thermal, voltage, and/or stability limits* are exceeded. These procedures shall identify system states that warrant the *NYISO* to invoke *emergency transfer criteria*. The *NYISO* must notify the *NYSRC* of any changes to these procedures and systems.

Compliance Monitoring Process

Compliance Monitoring Responsibility:

- M1: RCMS

Compliance Documentation Reporting Frequency:

- M1: In accordance with *NYSRC* Compliance Monitoring Program schedules.

Compliance Reporting Requirements:

- M1: *NYISO* Self-Certification

Measure No.

<input checked="" type="checkbox"/> Full Compliance	<p>M1. The <i>NYISO</i> maintained procedures and systems in accordance with R1 and R2 which identify appropriate actions to be taken whenever the bulk power transmission system’s thermal, voltage, and <i>stability limits</i> are exceeded. The procedures identified system states that warrant the <i>NYISO</i> to invoke <i>emergency transfer criteria</i>. Any revisions to these procedures or systems were reported to the <i>NYSRC</i>.</p>
---	--

Levels of Non-Compliance

___ Level 1	M1. Revisions to existing procedures or systems were not reported to the <i>NYSRC</i> .
___ Level 2	M1. Documentation of <i>NYISO</i> procedures and systems for exceedance of thermal, voltage, and <i>stability limits</i> was incomplete in one or more areas.
___ Level 3	M1. Not applicable.
___ Level 4	M1. Documentation of <i>NYISO</i> procedures and systems for exceedance of thermal, voltage, and <i>stability limits</i> was not provided.

Reliability Rule C.1 Narrative (R2):

The NYISO Emergency Operations Manual section 4 - Monitored Conditions, describe the procedures for all monitored conditions/actions to be taken when thermal, voltage, and stability limits are exceeded.

Certified by: Jon Sawyer

Title: Director, Grid Operations

Date: April 4, 2024