Exception Reference No.	то	Exception Category	Exception	NYSRC Reliability Rule	
1	NYPA	Run Back of Generators	Post Contingency Flow on Marcy-New Scotland  Post-contingency flow on the Marcy-New Scotland 18 line is allowed to exceed its LTE rating, without going above its STE rating, for either:  • the loss of the Edic-Gordon Road New Scotland 14 line, • or the double-circuit loss of the Edic-Princetown 351 and 352,  by the amount of relief that can be obtained by tripping the Gilboa pumping load as a single corrective action.  Also, the post-contingency flow on the Edic-Gordon Road New Scotland 14 line is allowed to exceed its LTE rating, without going above its STE rating, for either:  • the loss of the Marcy-New Scotland 18 line alone, • or the double-circuit loss of the Marcy-New Scotland 18 and Adirondack-Porter 12 lines.;  by the amount of relief that can be obtained by tripping the Gilboa pumping load as a single corrective action.	C.1	Formatted: Normal, No bullets or numbering  Formatted: Indent: Left: 0.05"  Formatted: Normal, Indent: Left: 0.05", No bullets or numbering

Also, the post-contingency flow on the Princetown-New Scotland 55 line is allowed to exceed its LTE rating, without going above its STE rating, for either: the loss of

- the loss of the Marcy-New Scotland 18 line alone, or the double-circuit loss of the Marcy-New Scotland 18 and Adirondack-Porter 12 lines,
- or the double-circuit loss of the Princetown-New Scotland 361 and 362..

by the amount of relief that can be obtained by tripping the Gilboa pumping load as a single corrective action.

Approved-NYSRC MMDDYRNYPP Operating Committee
September 27, 2024. Approved NYPP Operating Committee
January 27, 1988.

Approved NYPP Operating Committee September 27, 2024.

**Formatted:** Normal, Indent: Left: 0.05", No bullets or numbering

Formatted: Right, Indent: Left: 0.25"