

**NEW YORK STATE RELIABILITY COUNCIL
EC #313 – Friday May 9, 2025**

Status Report - RCMS Meeting #294 – Thursday May 1, 2025

- **2025 Reliability Compliance Program**

- NYISO Requirements for Con Edison Planning & Operating Procedures [G.1: R5]
 - NYISO Grid Operations described the Application Reliability Rules (“ARR’s”) process to RCMS.
 - **Action:** Found NYISO in full compliance
 - NYISO Grid Operations
- NYISO Requirements for Con Ed 10-Minutes Reserve Procedures [G.1: R5]
 - NYISO Grid Operations described the Day Ahead Market reporting of NYC committed reserves and described the operating actions to mitigate identified reserve shortages.
 - **Action:** Found the NYISO in full compliance
- Generator Owner Dual Fuel Capability testing of combined cycle units. [G.2: R6]
 - NYISO compliance documentation provided the test dates and results for each applicable unit.
 - **Action:** Found the NYISO in full compliance
- Operations Monthly Report [C.8: R1]
 - **Action:** RCMS reviewed the NYISO March Operating Report and found the NYISO in full compliance

- **Other RCMS Matters**

- None

- **Next Meeting RCMS #295**

- Thursday June 5, 2025 @ 10:00 am (WEBEX or Teams)