NYISO OPERATIONS REPORT FOR the Month of August 2025

Peak Load

The peak load for the month was 27,720 MW, which occurred Tuesday, August 12, 2025, for hour beginning 18:00. At that time, the Operating Reserve requirement was 1,965 MW. This resulted in a minimum total Operating Capacity requirement of 29,685 MW for that hour.

Reserve Requirements:

Reserve	10 sync	Non sync	30 min
Requirement	655	1,310	1,965
For Hour	1,436	1,954	3,404
DSASP Cont.	163	0	163

The NYCA all time Summer peak load of 33,956 MW, which occurred on Friday, July 19, 2013 for hour beginning 16:00.

Major Emergencies

None

The Major Emergency state was declared 0 times during August of 2024

Alert States

- ON 2 OCCASIONS AN ALERT STATE WAS DECLARED:
 - 1 SYSTEM FREQUENCY 1 LOW 0 HIGH
 - 1 ACE GREATER THAN (+OR-) 500MW
 - SHORTAGE OF 10 MIN SYNCHRONIZED RESERVE
 - 0 SHORTAGE OF 10 MIN TOTAL RESERVE
 - 0 ACTUAL FLOW EXCEEDING LTE FOR LESS THAN 5 MIN
 - 0 ACTUAL VOLTAGE BELOW PRE-CONTIGENCY LOW LIMIT
 - 0 EXCEEDING CENTRAL EAST VOLTAGE CONTINGENCY LIMIT
 - 0 EXCEEDING TRANSIENT STABILITY LIMIT
 - 0 NYISO COMPUTER PROBLEM
 - NEIGHBORING SYSTEM 5% VOLTAGE REDUCTION
 - 0 EMERGENCY TRANSFER DECLARED
 - 0 GIC (SMD) ACTIVITY
 - 0 SEVERE WEATHER
 - 0 OTHER

The Alert state was declared 0 times during August of 2024

Thunder Storm Alerts

1 Thunder Storm Alerts were declared for the month of August for a total of 6.5 hours

Reserve Activations

- ON 4 OCCASIONS RESERVES WERE ACTIVATED DURING THE MONTH:
 - 3 LOSS OF NEW YORK CONTROL AREA GENERATORS
 - MAINTENANCE OF SYNCHRONIZED RESERVES
 - 1 SIMULTANEOUS ACTIVATION OF RESERVES
 - o FOR ISO-NE
 - o FOR IESO
 - o FOR PJM
 - 1 FOR NYISO
 - o FOR NB
 - 1 LARGE CONTROL ERRORS (ABOVE 200MW)
 - 1 LOAD PICKUP
 - 0 SCHEDULE CHANGE & LOAD PICKUP
 - **0** SCHEDULE CHANGE
 - 0 SCHEDULE CHANGE DUE TO TLR
 - **0** OTHER (FIXED GEN CHANGES / COMPUTER PROBLEMS)
- 1 OF THESE RESERVE ACTIVATION'S DID NOT RESULT IN THE ACE-CROSSING ZERO
- OF THE NON-ZERO CROSSINGS REQUIRED ANOTHER RESERVE PICKUP TO BE INITIATED
- 1 NON-ZERO CROSSINGS WERE ASSOCIATED WITH A UNIT LOSS
- ON 7 OCCASIONS RESERVES WERE ACTIVATED DURING THE MONTH OF AUGUST 2024
- 2 OF THESE PICKUPS WHERE FOR ACE.

Emergency Actions

Special Case Resources:

Emergency Demand Response Program:

Purchases:

None
Sales:

None

TLR 3 Declared

TLR Level 3's were declared for the month of August for a total of 0 hours

Inadvertent Accumulations for July 2025

Monthly End of Month
Accumulation Balance

 On-Peak:
 4,100 MWh
 -47,375 MWh

 Off-Peak:
 1,561 MWh
 7.771 MWh

NERC Control Performance

CPS1: 134.51 % BAAL VIOLATIONS: 0

NERC/NPCC Reportable DCS Events

None