



Manual 20

System Restoration Manual

Issued: August 2024

3.1.7 Inclusion of Black Start Resources in the Con Edison SRP

NYSRC Reliability Rule G-R4 requires that the NYISO have procedures and implement actions to provide for the inclusion or continued inclusion of an eligible Black Start Resource in the Con Edison SRP if it would provide a material benefit to the Con Edison SRP. The NYISO procedures adopted to satisfy NYSRC Reliability Rule G-R4 are found in the Services Tariff, Rate Schedule 5, Section 15.5.4 (available from the NYISO Web site at the following URL: <https://www.nyiso.com/regulatory-viewer>).