

NYISO OPERATIONS REPORT**FOR the Month of
September 2025****Peak Load**

The peak load for the month was 21,342 MW, which occurred Friday, September 5, 2025 for hour beginning 17:00. At that time the Operating Reserve requirement was 1,965 MW. This resulted in a minimum total Operating Capacity requirement of 23,307 MW for that hr.

Reserve Requirements:

Reserve	10 sync	Non sync	30 min
Requirement	655	1,310	1,965
For Hour	1,424	2,911	4,328
DSASP Cont.	63	0	63

The NYCA all time Summer peak load of 33,956 MW, which occurred on Friday, July 19, 2013 for hour beginning 16:00

Major Emergencies

None

The Major Emergency state was declared 0 times during September of 2024

Alert States

ON 2 OCCASIONS AN ALERT STATE WAS DECLARED:

1	SYSTEM FREQUENCY	1	LOW	0	HIGH
1	ACE GREATER THAN (+OR-) 500MW				
0	SHORTAGE OF 10 MIN SYNCHRONIZED RESERVE				
0	SHORTAGE OF 10 MIN TOTAL RESERVE				
0	ACTUAL FLOW EXCEEDING LTE FOR LESS THAN 5 MIN				
0	ACTUAL VOLTAGE BELOW PRE-CONTINGENCY LOW LIMIT				
0	EXCEEDING CENTRAL EAST VOLTAGE CONTINGENCY LIMIT				
0	EXCEEDING TRANSIENT STABILITY LIMIT				
0	NYISO COMPUTER PROBLEM				
0	NEIGHBORING SYSTEM 5% VOLTAGE REDUCTION				
0	EMERGENCY TRANSFER DECLARED				
0	GIC (SMD) ACTIVITY				
0	SEVERE WEATHER				
0	OTHER				

The Alert state was declared 1 time during September of 2024

Thunder Storm Alerts

2 Thunder Storm Alerts were declared for the month of September for a total of 10.9 hours

Reserve Activations

ON 0 OCCASIONS RESERVES WERE ACTIVATED DURING THE MONTH:

- 0 LOSS OF NEW YORK CONTROL AREA GENERATORS
- 0 MAINTENANCE OF SYNCHRONIZED RESERVES
- 0 SIMULTANEOUS ACTIVATION OF RESERVES
 - 0 FOR ISO-NE
 - 0 FOR IESO
 - 0 FOR PJM
 - 0 FOR NYISO
 - 0 FOR NB
- 0 LARGE CONTROL ERRORS (ABOVE 200MW)
 - 0 LOAD PICKUP
 - 0 SCHEDULE CHANGE & LOAD PICKUP
 - 0 SCHEDULE CHANGE
 - 0 SCHEDULE CHANGE DUE TO TLR
 - 0 OTHER (FIXED GEN CHANGES / COMPUTER PROBLEMS)

- 0 OF THESE RESERVE ACTIVATION'S DID NOT RESULT IN THE ACE-CROSSING ZERO
- 0 OF THE NON-ZERO CROSSINGS REQUIRED ANOTHER RESERVE PICKUP TO BE INITIATED
- 0 NON-ZERO CROSSINGS WERE ASSOCIATED WITH A UNIT LOSS

ON 3 OCCASIONS RESERVES WERE ACTIVATED DURING THE MONTH OF SEPTEMBER 2024

0 OF THESE PICKUPS WHERE FOR ACE.

Emergency Actions

Special Case Resources:	None
Emergency Demand Response Program:	None
Purchases:	None
Sales:	None

TLR 3 Declared

0 TLR Level 3's were declared for the month of September for a total of 0 hours

Inadvertent Accumulations for August 2025

	<u>Monthly Accumulation</u>		<u>End of Month Balance</u>	
On-Peak:	5,246	MWh	-42,129	MWh
Off-Peak:	-444	MWh	7,327	MWh

NERC Control Performance

CPS1: 135.15 %

BAAL VIOLATIONS: 0

NERC/NPCC Reportable DCS Events

None