

# Technical Study Report

---

## New York Control Area Installed Capacity Requirement



For the Period May ~~2025~~  
2026 to April ~~2026~~2027

~~December 6~~November 5, 2024

---

New York State Reliability Council, LLC  
Installed Capacity Subcommittee

## About the New York State Reliability Council

The New York State Reliability Council (NYSRC) is a not-for-profit corporation responsible for promoting and preserving the reliability of the New York State power system by developing, maintaining and, from time to time, updating the reliability rules which must be complied with by the New York Independent System Operator, Inc. (NYISO) and all entities engaging in electric power transactions on the New York State power system. One of the responsibilities of the NYSRC is the establishment of the annual statewide Installed Capacity Requirement for the New York Control Area.

## Table of Contents

<b>EXECUTIVE SUMMARY .....</b>	<b>2</b>
1. Introduction.....	5
2. NYSRC Resource Adequacy Reliability Criterion .....	6
3. IRM Study Procedures .....	7
4. Study Results – Base Case .....	<del>11</del> <a href="#">10</a>
5. Models and Key Input Assumptions.....	<del>12</del> <a href="#">10</a>
5.1 The Load Model.....	<del>12</del> <a href="#">11</a>
5.1.1 Peak Load Forecast .....	<del>12</del> <a href="#">11</a>
5.1.2 Load Forecast Uncertainty .....	<del>13</del> <a href="#">12</a>
5.1.3 Load Shape Model .....	<del>13</del> <a href="#">12</a>
5.2 The Capacity Model .....	<del>14</del> <a href="#">13</a>
5.2.1 Conventional Resources: Planned New Capacity, Retirements, Deactivations, and Behind the Meter Generation.....	<del>14</del> <a href="#">13</a>
5.2.2 Renewable Resources .....	<del>15</del> <a href="#">14</a>
5.2.3 Energy Limited Resources .....	<del>16</del> <a href="#">15</a>
5.2.4 Generating Unit Availability .....	<del>17</del> <a href="#">15</a>
5.2.5 Emergency Operating Procedures (EOPs).....	<del>17</del> <a href="#">16</a>
5.2.6 Unforced Capacity Deliverability Rights (UDRs) .....	<del>18</del> <a href="#">17</a>
5.3 The Transmission Model.....	<del>19</del> <a href="#">18</a>
5.4 The Outside World Model.....	<del>21</del> <a href="#">20</a>
5.5 Database Quality Assurance Review .....	<del>22</del> <a href="#">21</a>
6. Parametric Comparison with 2024-2025 IRM Study Results .....	<del>22</del> <a href="#">21</a>
7. Sensitivity Case Study .....	<del>27</del> <a href="#">25</a>
8. NYISO Implementation of the NYCA Capacity Requirement .....	<del>34</del> <a href="#">29</a>
NOTE: Appendices A, B, C and D are included in a separate document. ....	

## EXECUTIVE SUMMARY

A New York Control Area (NYCA) Installed Reserve Margin (IRM) study is conducted annually by the New York State Reliability Council (NYSRC) Installed Capacity Subcommittee (ICS). ICS has the overall responsibility of managing studies for establishing NYCA IRM requirements for the upcoming Capability Year<sup>1</sup> including the development and approval of all modeling and database assumptions to be used in the reliability calculation process. This report covers the period May 1, ~~2025-2026~~ through April 30, ~~2026-2027~~ (~~2025-2026-2026-2027~~ Capability Year). The IRM study described in this report for the ~~2025-2026-2026-2027~~ Capability Year is referred to as the "~~2025-2026-2026-2027~~ IRM Study."

The NYSRC technical study was performed pursuant to the NYSRC Policy for setting the Installed Reserve margin.<sup>2</sup> The report shows that the calculated NYCA IRM for the ~~2025-2026-2026-2027~~ Capability Year is ~~24.4%~~25.3% under final base case assumptions. This IRM satisfies the NYSRC resource adequacy criterion of a Loss of Load Expectation (LOLE) of no greater than 0.1 Event-Days/year. The base case, along with other relevant factors, will be considered by the NYSRC Executive Committee on December ~~65, 2024~~2025, for its adoption of the Final NYCA IRM requirement for the ~~2025-2026-2026-2027~~ Capability Year. Of note this year is the fact that 14% of the risk occurred in the winter season.

In addition to calculating the LOLE, the analysis also determined that the Hourly Loss of Load Expectation (LOLH) was ~~0.374~~0.361 hours per year and the Expected Unserved Energy (EUE) was ~~216.980~~169.506 MWh per year. The NYSRC does not have criteria for LOLH or EUE. For comparison to other systems, a Normalized Expected Unserved Energy (NEUE) can also be determined, which divides the EUE by the expected load energy. Using the NYISO's projected ~~2025-2026~~ NYCA energy value of ~~150,540~~155,460 GWh/year (~~2024-2025~~ NYISO Load & Capacity Data report or "Gold Book") this produces a NEUE of ~~0.00014000011~~0.00014000011%. Other systems around the world that design to LOLH have a criteria of less than 3 to 8 hours per year. Criteria based on NEUE is typically less than 0.002%. Both of the NYCA results represent a significantly higher level of reliability than either of these criteria.<sup>3</sup>

The NYSRC study procedure used to establish the NYCA IRM<sup>4</sup> also produces corresponding "Minimum Locational Capacity Requirements" (MLCRs) for New York City and Long Island to satisfy the NYCA resource adequacy criterion, along with the calculated NYCA IRM. The ~~20265-20276~~ IRM Study determined related MLCRs of ~~75.679.2%~~ and ~~107.3106.7%~~ for the New York City and Long Island

<sup>1</sup> A Capability Year begins on May 1 and ends on April 30 of the following year.

<sup>2</sup> Policy No. 5-17; Procedure for Establishing New York Control Area Installed Capacity Requirements.

<sup>3</sup> See, Resource Adequacy for a Decarbonized Future *available*

at: <https://www.epri.com/research/products/000000003002023230>

<sup>4</sup> This procedure is described in Section 3, IRM Study Procedures. The procedure for calculating IRM requirements and initial LCRs is sometimes referred to in this report as the "Tan 45 process."

localities, respectively. This represents an increase of 4.1% for NYC and an ~~increase-decrease~~ of ~~2.90.6~~% in Long Island from the MLCRs determined as part of the ~~20242025-2025-2026~~ IRM Study. In accordance with its responsibility of setting the Locational Minimum Installed Capacity Requirements (LCRs), the NYISO will calculate and approve *final LCRs* for all NYCA localities using a separate process that utilizes the NYSRC approved Final NYCA IRM and adheres to NYSRC Reliability Rules and policies.

The ~~24.425.3~~% IRM base case value for the ~~20252026-2026-2027~~ Capability Year represents a ~~1.30.9~~% increase from the ~~20242025-2025-2026~~ IRM Study base case IRM of ~~23.124.4~~%. Table 6-1 shows the IRM impacts of individual updated study parameters that result in this change. Note, the values in Table 6-1 have NOT been ratioed up or down in order to “true-up” the parametric results with the resulting tan-45 values. The initial parametric deltas from the PBC were off by roughly a factor of two and it was felt that ratioing the numbers would give a false sense of accuracy for the process. One of the goals for the NYISO next year is to investigate changes in the parametric process to improve the accuracy. In summary:

- There are ~~fourteen-sixteen~~ parameter drivers that in combination *increased* the ~~20252026-2026-2027~~ IRM from the ~~20242025-2025-2026~~ IRM Study base case IRM by ~~1.986.29~~%. Of these ~~fourteen-sixteen~~ drivers, the most significant was the Winter Fuel Availability Constraints followed closely by the Fall Load Forecast reduction and the explicit modeling of the Behind the Meter (BTM) Solar modeling. Each of these three items increased the IRM by over 1% each. The addition of the Champlain Hudson Power Express (CHPE) with its 1250 MW transfer capability into Zone J for the summer months only, resulted in just a 0.317% increase in the IRM but caused significant shifts in the Locational Requirements. Zone J increased by 8.474%, Zone K decreased by 3.397% and Zones G-J increased by 5.272%. Because of the seasonal capability of this line it also exacerbated the impact of the winter fuel constraints. ~~limit on certain~~ Emergency Operating Procedure (EOP) calls which increased the IRM by 0.46%. The next three most significant are the addition of the new renewable generators which increased the IRM by 0.29%, the change in Special Case Resource (SCR) capacities which increased the IRM by 0.24% and the change in generator ratings which increased the IRM by 0.19%. The remaining changes resulted in relatively minor changes to the IRM.
- ~~Seven-Twelve~~ parameter drivers in combination *decreased* the IRM from the 2024-2025 IRM Study base case by ~~0.684.66~~%. Of these ~~seven-twelve~~ drivers, the most significant was the change in the SCR ~~modeling-elections~~ which decreased the IRM by ~~0.261.569~~%. The Gowanus and Narrows generator deactivations decreased the IRM by 0.686% followed closely by the initial 2025 Gold Book Load Forecast which decreased the IRM by 0.619%. All other modifications, individually, had less than a ~~0.1550~~% impact each on the IRM.

The overall parametric impact from both the PBC and FBC cases showed an increase of 1.495%, while the final Tan45 analysis resulted in an increase of only 0.9% from last year’s Final Base Case (FBC).

Formatted: Font: Not Italic

Formatted: Font: Not Italic

The complete parametric analysis showing the above and other results can be found in Section 6 of this report.

This study also evaluated IRM impacts of several sensitivity cases. The results of these sensitivity cases are discussed in Section 7 and summarized in Table 7-1 of this report. The base case IRM and sensitivity case results, along with other relevant factors, will be considered by the NYSRC Executive Committee in adopting the Final NYCA IRM requirement for the ~~20252026-2026-2027~~ Capability Year. NYSRC Policy 5-18 describes the Executive Committee process for establishing the Final NYCA IRM.

The study also included a confidence interval analysis to demonstrate that there is a high confidence that the base case ~~24-425.3%~~ IRM will fully meet NYSRC and Northeast Power Coordinating Council (NPCC) resource adequacy criterion that require a LOLE of no greater than 0.1 Event-Days/year. Initial convergence at 90% confidence was reached within 3000 replications, but because of a handful of outlier replications the 95% confidence could not be reached for the final parametric case. 95% confidence limit was reached with the final Tan45 rounded case at 5000 replications.

The ~~20252026-2026-2027~~ IRM Study also evaluated Unforced Capacity (UCAP) trends. The NYISO values capacity sold and purchased in the market in a manner that considers the forced outage ratings of individual units, whereby generating unit capacity is derated to an unforced capacity basis recognizing the impact of forced outages. This derated capacity is referred to as "UCAP." This analysis shows that required UCAP margins, which steadily decreased over the 2006-2012 period to about 5%, remained relatively steady through 2019 but have increased through 2021 (see Figure 8-1). Since then it has varied between 6% and 10%. Due to lower contributions to reliability, the increase in wind and solar resources lowers the translation factor from required ICAP to required UCAP which reflects the performance of all resources on the system. Overall, the required ICAP remained roughly constant to last year although the existing amount of ICAP increased by about 3%

## 1. Introduction

This report describes a technical study, conducted by the NYSRC Installed Capacity Subcommittee (ICS), for establishing the NYCA Installed Reserve Margin (IRM) for the period of May 1, ~~2025-2026~~ through April 30, ~~2026-2027~~ (~~2025-2026-2026-2027~~ Capability Year). This study is conducted each year in compliance with Section 3.03 of the NYSRC Agreement, which states that the NYSRC shall establish the annual statewide Installed Capacity Requirement (ICR) for the NYCA. The ICR relates to the IRM through the following equation:

$$\text{ICR} = \left( 1 + \frac{\text{IRM Requirement (\%)}}{100} \right) * \text{Forecast NYCA Peak Load}$$

The base case and sensitivity case study results, along with other relevant factors, will be considered by the NYSRC Executive Committee for its adoption of the Final NYCA IRM requirement for the ~~2025-2026-2026-2027~~ Capability Year.

The NYISO will implement the Final NYCA IRM as determined by the NYSRC, in accordance with the NYSRC Reliability Rules, NYSRC Policy 5-18, *Procedure for Establishing New York Control Area Installed Capacity Requirement and the Installed Reserve Margin (IRM)*; the NYISO Market Administration and Control Area Services Tariff; and the NYISO Installed Capacity (ICAP) Manual. The NYISO translates the required IRM to a UCAP basis. These values are also used in ICAP Spot Market Auctions based on FERC-approved ICAP Demand Curves. The schedule for conducting the ~~2025-2026-2026-2027~~ IRM Study was based on meeting the NYISO's timetable for conducting such auctions.

The study criteria, procedures, and types of assumptions used for the study for establishing the NYCA IRM for the ~~2025-2026-2026-2027~~ Capability Year are set forth in NYSRC Policy 5-18. The primary reliability criterion used in the IRM study requires a LOLE of no greater than 0.1 Event-Days/year for the NYCA. This NYSRC resource adequacy criterion is consistent with the NPCC resource adequacy criterion. IRM study procedures include the use of two reliability study methodologies: The *Unified Methodology* and the *IRM Anchoring Methodology*. NYSRC reliability criteria and IRM study methodologies and models are described in Policy 5-18 and discussed in detail later in this report.

The NYSRC procedure for determining the IRM also identifies corresponding MLCRs for the New York City and Long Island localities. The NYISO, using a separate process – in accordance with the NYISO tariffs and procedures, while adhering to NYSRC Reliability Rules and NYSRC Sections 3.2 and 3.5 of Policy 5-18 – is responsible for setting *final* LCRs for New York City, Long Island and the G-J Locality. For its determination of LCRs for the ~~2025-2026-2026-2027~~ Capability Year, the NYISO will continue utilizing an economic optimization methodology approved by the Federal Energy Regulatory Commission (FERC).

The ~~2025-2026-2026-2027~~ IRM Study was managed and conducted by the NYSRC ICS and supported by technical assistance from the NYSRC's technical consultants and NYISO staff.

Previous IRM Study reports, from year 2000 to year ~~2024-2025~~, can be found on the NYSRC website.<sup>5</sup> Appendix D, Table D.1 provides a record of previous NYCA base case and final IRMs for the 2000-2001 through ~~2024-2025-2025-2026~~ Capability Years. Figure 8-1 and Appendix D, Table D.1.1, show UCAP reserve margin trends over previous years. Definitions of certain terms in this report can be found in the Glossary (Appendix E).

Different reliability analyses, separate from the IRM study process covered in this report, are conducted by the NYISO and are called the Reliability Needs Assessment (RNA) and the Short-Term Assessment of Reliability (STAR). These analyses together assess the resource adequacy and transmission security of the NYCA for up to ten years into the future. The RNA is conducted once every two years and examines years four through ten of the study period, while the STAR is conducted quarterly and analyzes years one through five, with a focus on fulfilling any identified reliability needs in years one through three. These assessments determine whether the NYSRC resource adequacy reliability criterion, as defined in Section 2 below, is expected to be maintained over the study period; and if not, identifies reliability needs or compensatory MW of capacity or other measures of solutions required to meet those needs.

## 2. NYSRC Resource Adequacy Reliability Criterion

The required reliability level used for establishing NYCA IRM Requirements is dictated by Requirement 1.1 of NYSRC Reliability Rule A.1, *Establishing NYCA Statewide Installed Reserve Margin Requirements*, which states that the NYSRC shall:

*Probabilistically establish the IRM requirement for the NYCA such that the loss of load expectation (LOLE) of disconnecting firm load due to resource deficiencies shall be, on average, no more than 0.1 Event-Days/year. This evaluation shall make due allowances for demand uncertainty, scheduled outages and de-ratings, forced outages and de-ratings, assistance over interconnections with neighboring control areas, NYS Transmission System emergency transfer capability, and capacity and/or load relief from available operating procedures.*

The above NYSRC Reliability Rule is consistent with NPCC's Resource Adequacy criterion in NPCC Directory 1, *Design and Operation of the Bulk Power System*. This criterion is interpreted to mean that planning reserve margins, including the IRM, needs to be high enough that the probability of an involuntary load shedding due to inadequate resources is limited to only one event-day in ten years or 0.1 Event-Days/ year. This criterion has been widely accepted by most electric power systems in North

---

<sup>5</sup>See, NYSRC New York Control Area Installed Capacity Requirement Reports, available at: <https://www.nysrc.org/documents/reports/nysrc-new-york-control-area-installed-capacity-requirement-reports/>



America for reserve capacity planning. In New York, use of the LOLE criterion of 0.1 Event-Days/year has provided an acceptable level of reliability for many years.

In addition to calculating the LOLE reliability metric the calculations shall also include the calculation and reporting of LOLH and EUE reliability metrics in the probabilistic resource capacity assessments.

In accordance with NYSRC Reliability Rule A.2, Establishing Load Serving Entity (LSE) Installed Capacity Requirements, the NYISO is required to establish LSE installed capacity requirements, including LCRs, for meeting the statewide IRM requirement established by the NYSRC in compliance with NYSRC Reliability Rule A.1 above.

### 3. IRM Study Procedures

The study procedures used for the ~~2025~~2026-2026-2027 IRM Study are described in detail in NYSRC Policy 5-18, *Procedure for Establishing New York Control Area Installed Capacity Requirements and the Installed Reserve Margin (IRM)*. Policy 5-18 also describes the computer program used for reliability calculations and the types of input data and models used for the IRM Study.

This study utilizes a *probabilistic approach* for determining NYCA IRM requirements. This technique calculates the probabilities of generator unit outages, in conjunction with load and transmission representations, to determine the Event-Days per year of expected resource capacity shortages.


General Electric's Multi-Area Reliability Simulation (GE-MARS) is the primary computer program used for this probabilistic analysis. This program includes detailed load, generation, and transmission representation for eleven NYCA load zones — plus four Outside World Control Areas (Outside World Areas) directly interconnected to the NYCA. The Outside World Areas are as follows: Ontario, New England, Quebec, and the PJM Interconnection. The eleven NYCA zones are depicted in Figure 3-1. GE-MARS calculates LOLE, expressed in Event-Days/year, to provide a consistent measure of system reliability. The GE-MARS program is described in detail in Appendix A, Section A.1.

Prior to the 2016-2017 IRM Study, the IRM base case and sensitivity analyses were simulated using only weekday peak loads rather than evaluating all 8,760 hours per year in order to reduce computational run times. However, the 2016-2017 IRM Study determined that the difference between study results using the daily peak hour versus the 8,760-hour methodologies would be significant. Therefore, the base case and sensitivity cases in the 2016-2017 IRM Study and all later studies, including this ~~2025~~2026-2026-2027 IRM Study, were simulated using all hours in the year.

Using the GE-MARS program, a procedure is utilized for establishing NYCA IRM requirements (termed the *Unified Methodology*) which establishes a relationship between NYCA IRM and corresponding MLCRs, as illustrated in Figure 3-2. All points on these curves meet the NYSRC 0.1 Event-Days/year LOLE reliability criterion described in Section 2. Note that the area above the curve is more reliable than the criterion, and the area below the curve is less reliable. This methodology develops a pair of

curves for two zones with locational capacity requirements, New York City (NYC) or Load Zone J; and Long Island (LI) or Load Zone K. Appendix A of NYSRC Policy 5-18 provides a more detailed description of the Unified Methodology.



Figure 3-1 NYCA Load Zones





Base case NYCA IRM requirements and corresponding initial locality reserve margins for Zones J and K are established by a supplemental procedure (termed the *IRM Anchoring Methodology*), which is used to define an *inflection point* on each of these curves. These inflection points are selected by applying a tangent of 45 degrees (Tan 45) analysis at the bend (or “knee”) of each curve. Mathematically, each curve is fitted using a second order polynomial regression analysis. Setting the derivative of the resulting set of equations to minus one yields the points at which the curves achieve the Tan 45-degree inflection point. Appendix B of NYSRC Policy 5-18 provides a more detailed description of the methodology for computing the Tan 45 inflection point.

Figure 3-2: Relationship Between NYCA IRM and Corresponding  
Initial Locational Capacity Requirements for ~~2025~~2026-2027 IRM  
For review and approval at the 11/05/2025 NYSRC ICS Meeting

IRM 2026-2027 Final Base Case Tan45





## 4. Study Results – Base Case

Results of the NYSRC technical study show that the calculated NYCA IRM is 24.425.3% for the 20252026-2026-2027 Capability Year under final base case assumptions. Figure 3-2 on the previous page depicts the relationship between NYCA IRM requirements and corresponding MLCRs for New York City and Long Island.

The tangent points on these curves were evaluated using the Tan 45 analysis described in Section 3. Accordingly, maintaining a NYCA IRM of 24.425.3% for the 20252026-2026-2027 Capability Year, together with corresponding MLCRs of 75.682.6 % and 107.3106.7% for New York City and Long Island, respectively, will achieve applicable NYSRC and NPCC reliability criteria for the base case study assumptions shown in Appendix A.3.

Comparing the corresponding MLCRs in this 20252026-2026-2027 IRM Study to 20242025-2025-2026 IRM Study results (New York City LCR= 72.775.6%, Long Island LCR= 103.2107.3%), the corresponding 20252026-2026-2027 New York City MLCR increased by 2.97.0%, and the corresponding Long Island MLCR increased-decreased by 4.10.6%. The key factors driving the increase of the NYC MLCR was a reduction in the number of EOP calls for voluntary curtailments and public appeals, as well as a reduction in the fall load forecast, the addition of the CHPE line.

In accordance with NYSRC Reliability Rule A.2, *Load Serving Entity ICAP Requirements*, the NYISO is responsible for separately calculating and establishing the final LCRs. The NYISO will calculate and approve *final LCRs* for all NYCA localities using a separate process that utilizes the NYSRC approved Final NYCA IRM and adheres to NYSRC Reliability Rules and policies.

For this analysis, the Base Case required 1,050 replications to converge to a standard error of 0.05 and required 4,236 replications to converge to a standard error of 0.025. For our cases, the model was run to 4,250 replications at which point the daily LOLE of 0.100 Event Days/year for NYCA was met with a standard error of less than 0.025. The confidence interval at this point ranges from 24.3% to 24.7%. It should be recognized that an IRM of 24.4% is in full compliance with the NYSRC Resource Adequacy rules and criteria (see Base Case Study Results section).

These cases were run with 3000 replications and converged to a confidence interval of only 94% rather than the goal of 95%. Due to some replications having a higher number of outages it was estimated that over 9000 replications would be required to reach the 95% goal. This situation is being further investigated to isolate the causes. The final rounded Tan45 case did reach the 95% confidence interval at 5000 replications.

▲▲

Formatted: Underline

Formatted: Font: Not Bold

Formatted: Font: Not Bold

Formatted: ui-provider, Font: (Default) Cambria Bold, 16 pt, Not Bold, Underline color: Blue, Font color: Blue

Formatted: Space Before: 6 pt, After: 6 pt

## 5. Models and Key Input Assumptions **Note: The redline Chapter 5 is presented separately.**

This section describes the models and related base case input assumptions for the 2025-2026 IRM Study. The models represented in the GE-MARS analysis include a *Load Model*, *Capacity Model*, *Transmission Model*, and *Outside World Model*. A *Database Quality Assurance Review* of the 2025-2026 base case assumptions are also addressed in this section. The input assumptions for the final base case were approved by the Executive Committee on October 10, 2024. Appendix A, Section A.3 provides more details on these models and assumptions and comparisons of several key assumptions with those used for this 2025-2026 IRM Study.

### 5.1 The Load Model

#### 5.1.1 Peak Load Forecast

The NYCA peak load forecast is based upon a model that incorporates forecasts of economic drivers, end use and technology trends, and normal weather conditions. A 2025 NYCA summer peak load forecast of 31,649.7 MW was assumed in the 2025-2026 IRM Study, a decrease of 115.9 MW from the forecast used in the 2024-2025 IRM Study. This “Fall 2025 Summer Load Forecast” was prepared for the 2025-2026 IRM Study by NYISO staff in collaboration with the NYISO Load Forecasting Task Force and presented to the ICS on October 4, 2024 (2025 Fall Load Forecast). The 2025 Fall Load Forecast considered actual 2024 summer load conditions.

The peak load forecast changes are shown on Table 5-1 below. Relative to the 2024-2025 IRM Study forecast, the load forecast for the 2025-2026 IRM Study has increased in Load Zones A through I, and decreased in Load Zones J and K. The primary factors behind year-over-year load declines are the continued strong load-reducing impact of state policy-incented energy efficiency programs, and behind-the-meter (BTM) solar installations. A secondary factor is slower economic growth relative to projections used for prior forecasts. In future years, electrification of vehicles and building appliances is expected to add to summer peak load levels. At this point, these positive load impacts are generally smaller than the load-reducing impacts of energy efficiency and BTM solar generation.

**Table 5-1: Comparison of 2024 and 2025 Actual and Forecast Coincident Peak Summer Loads (MW)**

	Fall 2024 Forecast	2024 Actual	2024 Normalized	Fall 2025 Forecast	Forecast Change
	(a)	(b)	(c)	(d)	=(d)-(a)
Zones A-I	15,515	14,110	15,565	15,831	316
Zones J&K	16,284	14,880	15,762	15,818	-466
NYCA	31,766	28,990	31,327	31,650	-116

### 5.1.2 Load Forecast Uncertainty

As with all forecasting, uncertainty exists relative to forecasting NYCA loads for any given year. This uncertainty is incorporated in the base case model by using a load forecast probability distribution that is sensitive to different weather conditions. Recognizing the unique load forecast uncertainty (LFU) of individual NYCA areas, separate LFU models are prepared for five areas: New York City (Load Zone J), Long Island (Load Zone K), Westchester (Load Zones H and I), and two rest of New York State areas (Load Zones A-E and Load Zones F-G).

These LFU models are intended to measure the load response to weather at high peak producing temperatures. The LFU is based on the slope of load versus temperature, or the weather response of load. If the weather response of load increases, the slope of load versus temperature will increase, and the upper bin LFU multipliers (Bins 1-3) will increase.

The LFU multipliers for the 2025-2026 IRM Study remained unchanged from the 2024-2025 IRM Study. A sensitivity case shows that recognizing LFU in the 2025-2026 IRM Study has an effect of increasing IRM requirements by 5.1% (Table 7-1, Case 3), as compared to a range of 5.1% to 9.1% in the previous five IRM studies.

### 5.1.3 Load Shape Model

The GE MARS model allows for the representation of multiple load shapes. This feature has been utilized since the 2014-2015 IRM Study and was again utilized for the 2025-2026 IRM Study. This multiple load shape feature enables a different load shape to be assigned to each of seven load forecast uncertainty bins.

Starting with the 2023-2024 IRM Study, a combination of load shapes from the years 2013, 2017, and 2018 were selected by ICS as representative years, as recommended under the LFU

Phase 2 Study.<sup>6</sup> The LFU Phase 2 Study recommended representing Bin 1 and 2 using the 2013 load shape, representing Bins 3 and 4 using the 2018 load shape, and representing Bins 5, 6, and 7 using the 2017 load shape. The recommendation to change representative load shapes was initially adopted in the base case of the 2023-2024 IRM Study and is also applied in the 2025-2026 IRM Study.

During the 2025-2026 IRM study cycle, the NYISO developed a methodology of modeling BTM solar explicitly as a supply resource in the IRM study. With the new modeling construct, it is possible to quantify the impact of evolving BTM solar resource in the system. BTM solar is not modeled as a supply resource in the 2025-2026 IRM study base case. Therefore, the 2013, 2017, and 2018 historical load shapes were adjusted by scaling up the underlying BTM solar impacts from those years to reflect the load shapes that would result from the projected 2025-2026 BTM solar capacity.

The NYISO is working on developing an enhanced load adjustment methodology reflecting seasonal peak load forecasts and annual energy demand, model-based synthetic load shapes reflecting expected load patterns, as well as dynamic winter LFU development, with the goal of implementing these refinements in future IRM studies.

## **5.2 The Capacity Model**

### **5.2.1 Conventional Resources: Planned New Capacity, Retirements, Deactivations, and Behind-the-Meter Generation**

Planned conventional generation facilities that are represented in the 2025-2026 IRM Study are shown in Appendix A, Section A.3. The rating for each existing and planned resource facility in the capacity model is based on its Dependable Maximum Net Capability (DMNC). In circumstances where the ability to deliver power to the grid is restricted, the value of the resource is limited to its Capacity Resource Interconnection Service (CRIS) value. The source of DMNC ratings for existing facilities is seasonal tests required by procedures in the NYISO Installed Capacity Manual.

There are no new thermal/conventional units planned in the 2025-2026 IRM Study, however, three units (New Athens Units 1, 2 and 3) were awarded additional CRIS rights (totaling 47 MW across the three units) compared to what is recorded in the 2024 Gold Book. There are six projected retirements totaling 165.4 MW for the 2025-2026 Capability Year. Four of the six units were previously removed in the 2023-2024 IRM Study under the New York State Department of Environmental Conservation (DEC) regulation to limit NO<sub>x</sub> emissions from

---

<sup>6</sup> [https://www.nysrc.org/wp-content/uploads/2023/05/A.I.10-LDC\\_Recommendation\\_IC54098.pdf](https://www.nysrc.org/wp-content/uploads/2023/05/A.I.10-LDC_Recommendation_IC54098.pdf)



simple-cycle combustion turbines (“the Peaker Rules”) but were reinstated back in the 2024-2025 IRM Study after confirming their intent to continue operations beyond June 2024. These units are modeled as retired for the 2025-2026 IRM Study.

A behind-the-meter net-generation (BTM:NG) program resource, for the purpose of this study, contributes its full capacity while its entire host load is exposed to the electric system. Several BTM:NG resources with a total resource capacity of 367.3 MW and a total host load of 170.6MW, are included in this 2025-2026 IRM Study. The full resource capacity of these BTM:NG facilities is included in the NYCA capacity model, while their host loads are included in the NYCA 2025 summer peak load forecast used for this study.

The NYISO has identified several State and Federal environmental regulatory programs that could potentially impact operation of the NYS Bulk Power System. The NYISO’s analysis concluded that these environmental initiatives would not result in NYCA capacity reductions or retirements that would impact IRM requirements during the summer of 2025. The analysis further identified those regulations that could potentially limit the availability of existing resources, and those that will require the addition of new non-emitting resources. For more details, see Appendix C.

### **5.2.2 Renewable Resources**

Intermittent types of renewable resources, including wind and solar resources, are becoming an increasing component of the NYCA generation mix. These intermittent resources are included in the GE MARS capacity model as described below. These resources, plus the existing 4,717 MW of hydro facilities, will account for a total of 8,881 MW of NYCA renewable resources represented in the 2025-2026 IRM Study. This does not include the capacity of any intermittent resources that are installed Behind the Meter (i.e., on the distribution system and not participating in the NYISO wholesale market).

It is projected that during the 2025 summer period there will be a total wind capacity of 2,566.2 MW participating in the capacity market in New York State. There were no new wind units included for the 2025-2026 IRM study.

GE MARS allows the input of multiple years of wind data. This multiple wind shape model randomly draws wind shapes from historical wind production data. The 2025-2026 IRM Study used available wind production data covering the years 2019 through 2023. For any new wind facilities, zonal hourly wind shape averages or the wind shapes of nearby wind units will be modeled. As the offshore wind resources are new to the NYCA system, the NYISO retained a

consultant to develop synthesized historical offshore wind production profiles<sup>7</sup> based on the historical weather conditions in the areas along New York's shoreline where offshore wind development is expected. These synthesized production profiles covered the period between 2000-2021. The offshore wind resources in the 2025-2026 IRM Study are modeled using the synthesized offshore wind production profiles for 2017 through 2021. In order to capture the weather correlation between the offshore wind and the rest of the intermittent resources in GE MARS simulation, the 2019-2021 offshore profiles are grouped with the same period as other intermittent resources, the 2017 offshore profile is grouped with the 2022 intermittent profiles, and the 2018 offshore profile is grouped with the 2023 intermittent profiles.

Overall, inclusion of the projected 2,566.2 MW of wind capacity in the 2025-2026 IRM Study accounts for 6.6% of the 2025-2026 IRM requirement (Table 7-1, Case 4). This relatively high IRM impact is a direct result of the wind facilities low capacity factor during the summer peak period. The impact of wind capacity on Unforced Capacity is discussed in Appendix C.3, "Wind Resource Impact on the NYCA IRM and UCAP Markets." For wind units, a detailed summary of existing and planned wind resources is shown in Appendix A, Table A.9.

Land Fill Gas (LFG) units account for 102.2 MW.

For the 2025-2026 IRM Study, 267 MW of utility level solar generation additions are included. The total New York State bulk power system solar capacity in the 2025-2026 IRM Study is 571.4 MW. Actual hourly solar plant output over the 2019-2023 period is used to represent the solar shape for existing units, while new solar units are represented by zonal hourly averages of nearby units.

### 5.2.3 Energy Limited Resources

Based on the FERC approved NYISO tariff, Energy Limited Resource (ELR) units started to participate in the NYISO markets in 2021. The NYISO and GE developed the dynamic ELR functionality within the GE MARS program and the recommended TC4C configuration in the ELR Whitepaper.<sup>8</sup> The recommended modeling would reduce the IRM and lower the SCR program activations as compared to a fixed output profile modeling approach, and it was adopted in the final base case in the 2023-2024 IRM Study. The TC4C configuration contains a static time period limitation for the output from the ELR units. Starting with the 2024-2025 IRM Study, a process is recommended to update the time period of the output limitation on an

<sup>7</sup>See, NYISO, Offshore Wind Hourly Net Capacity Factor Profiles, available at: <https://www.nyiso.com/documents/20142/36079056/4%20NYISO+OffshoreWind+Hourly+NetCapacityFactor.xlsx/dc15eb6a-b6fe-6a6a-e1d0-467d5c964079>

<sup>8</sup>New York State Reliability Council Installed Capacity Subcommittee White Paper on Energy Limited Resources Modeling (May 7, 2021), available at: <https://www.nysrc.org/wp-content/uploads/2023/03/ELR-Modeling-White-Paper-May-2021-FINAL.pdf>

annual basis, based on the beginning of the 90% LOLE risk period from previous year's LCR study conducted by the NYISO. In the 2025-2026 IRM Study, output from the ELRs will be available starting Hour Beginning 14, which is the beginning of the 90% LOLE risk window from the 2024-2025 LCR study. This process aims to keep the ELR output limitation in close proximity to the period with the highest LOLE risk and the annual update process could have, if any, a small reduction on the IRM on a year over year basis.

#### **5.2.4 Generating Unit Availability**

Generating unit forced and partial outages are modeled in GE-MARS by inputting a multistate outage model that represents an equivalent demand forced outage rate (EFORD) for each unit represented. Outage data used to determine the EFORD is received by the NYISO from generator owners based on outage data reporting requirements established by the NYISO. Capacity unavailability is modeled by considering the average forced and partial outages for each generating unit that have occurred over the most recent five year time period. The time span considered for the 2025-2026 IRM Study covered the 2019-2023 period.

The weighted average five year EFORD calculated for generating units in Load Zones A-F is higher while Load Zones G-J and K is lower than the 2018-2022 period, which were used in the 2024-2025 IRM Study. The overall NYCA wide weighted average EFORD in the 2025-2026 IRM Study is higher than the 2024-2025 IRM Study. Appendix A, Figure A.5 depicts NYCA and zonal five year average EFORD trends from 2016-2023.

#### **5.2.5 Emergency Operating Procedures (EOPs)**

As part of the Preliminary Base Case (PBC) for the 2025-2026 IRM Study, a new "Enhanced SCR Modeling"<sup>9</sup> technique was adopted for SCRs. This decreased the IRM by 0.26% (Table 6-1). For the 2025-2026 IRM Study, limitations are implemented for certain EOP steps. Specifically, EOP calls for Voluntary Curtailments and Public Appeals for the 2025-2026 IRM Study are limited to 3 calls per year which increased the IRM by 0.46% (Table 6-1). Previous IRM studies did not limit calls on Voluntary Curtailments and Public Appeals.

##### **(1) Special Case Resources (SCRs)**

SCRs are loads capable of being interrupted and distributed generators that are rated at 100 kW or higher. SCRs are ICAP resources that provide load curtailment only when activated as needed in accordance with NYISO emergency operating procedures. GE-MARS represents SCRs

---

<sup>9</sup> See, NYISO Enhanced SCR Modeling: IRM Impact Assessment, Installed Capacity Subcommittee Meeting #286 (Jan. 30, 2024) available at: <https://www.nysrc.org/wp-content/uploads/2024/01/SCR-Modeling-ICS-01302024-Market-Sensitive27154.pdf>.

as an EOP step, which is activated to avoid or to minimize expected loss of load. SCRs are modeled with monthly values based on July 2024 registration data. For the month of July, the forecast SCR value for the 2025–2026 IRM Study base case assumes that 1,487 MW will be registered, with varying amounts during other months based on historical experience. This is 206 MW higher than that assumed for the 2024–2025 IRM Study.

The new “Enhanced SCR Modeling” that was adopted into the PBC of the 2025–2026 IRM Study models SCRs as energy limited resources, using the GE MARS EL3 unit type. SCRs are modeled as zonal duration limited resources with hourly response rates, subject to a 1 call per day limit. SCRs continue to be deployed as the first EOP step but are not subject to an annual or monthly limit to the maximum number of activations. Performance factors are captured in the hourly response rates rather than in setting the maximum modeled capacities.

The SCR model used for the 2025–2026 IRM Study is based on a recent analysis of performance data for the 2012–2023 period. Incorporation of “Enhanced SCR Modeling” decreased the IRM by 0.26% (Table 6-1) while the incorporation of the updated SCR enrollments in the NYCA capacity model has the effect of increasing the IRM by 2.4% (Table 7-1, Case 5).

## (2) Other Emergency Operating Procedures

In addition to SCRs, the NYISO will implement several other types of EOP steps, such as voltage reductions, as required, to avoid or minimize customer disconnections. Projected 2025–2026 EOP capacity values are based on recent actual data and NYISO forecasts.

The 2025–2026 IRM Study implements a three call per year limit for Voluntary Curtailments and Public Appeals. This increased the IRM by 0.46% (Table 6-1). The 2025–2026 IRM Study also implemented dynamic emergency assistance interface group limits which apply bin-specific limits for the external areas (see Attachment E5 from the 2025–2026 IRM FBC Assumptions Matrix).

Refer to Appendix B, Table B.2 for projected EOP frequencies for the 2025–2026 Capability Year assuming the 24.4% base case IRM.

### **5.2.6 Unforced Capacity Deliverability Rights (UDRs)**

The capacity model includes UDRs, which are capacity rights that allow the owner of an incremental controllable transmission project to provide locational capacity when coupled with a non-locational ICAP Supplier. The owners of the UDRs annually elect whether they will utilize their capacity deliverability rights. This decision determines how UDR transfer capability will be represented in the MARS model. The IRM modeling accounts for both the availability of the resource that is identified for each UDR line as well as the availability of the UDR facility itself.

The following facilities are represented in the 2025–2026 IRM Study as having UDR capacity rights: LIPA’s 330 MW High Voltage Direct Current (HVDC) Cross Sound Cable (CSC), LIPA’s 660 MW HVDC Neptune Cable, and the 315 MW Linden Variable Frequency Transformer (VFT). The owners of these facilities have the option, on an annual basis, of selecting the MW quantity of UDRs they plan on utilizing for capacity contracts over these facilities. Any remaining capability on the cable can be used to support emergency assistance, which may reduce locational and IRM capacity requirements. The 2025–2026 IRM Study incorporates the confidential elections that these facility owners made for the 2025–2026 Capability Year. The Hudson Transmission Partners 660 MW HVDC Cable (HTP) has been granted UDR rights but has lost its right to import capacity and therefore is modeled as being fully available to support emergency assistance.

UDRs, along with other cables captured in the IRM study, are modeled with outage rates based on their historical performance. In prior IRM studies, the most recent 5-year period was used in this process. Following an NYSRC recommendation, a switch to using the most recent 10-year period was implemented in the 2025–2026 IRM Study. Therefore, in the 2025–2026 IRM Study, the cable performance for 2014–2023 was used to develop the cable outage rate assumptions. The aggregated cable outage rate, which covers the facilities of CSC, Neptune, VFT, HTP, Dunwoodie South, Y49/Y50, Norwalk Northport, A Line, and Jamaica Ties, decreased slightly from 5.36% (based on a 5-year historical period from 2018–2022) to 5.31% for the 2025–2026 IRM Study compared to the 2024–2025 IRM Study.

### 5.3 The Transmission Model<sup>10</sup>

A detailed NYCA transmission system model is represented in the GE-MARS topology. The transmission system topology which includes eleven NYCA zones and four Outside World Areas, along with relevant transfer limits, is depicted in Appendix A, Figure A-10. The transfer limits employed for the 2025–2026 IRM Study were developed from emergency transfer limit analysis included in various studies performed by the NYISO, and from input from Transmission Owners and neighboring regions. The transfer limits are further refined by additional assessments conducted for this 2025–2026 IRM Study topology.

The transmission model assumptions included in the 2025–2026 IRM Study are listed in Table A.10 in the Appendix which reflects changes from the model used for the 2024–2025 IRM Study. These topology changes are as follows:

#### ***Update to Central East Forward Limit due to Marcy STATCOM outage***

---

<sup>10</sup> The transmission model is discussed in Appendix A Section 3.5

- The Central East voltage-collapse limit was reduced from 3,885 MW to 3,810 MW; each dynamic limit is also reduced by 75 MW. The updated transfer limits for Central East have been adopted from the Central East Voltage Limit Study (CEVC 2024).
- The Central East + Marcy South Group (Total East interface) is not impacted by the STATCOM outage because it is thermally constrained.

#### ***Update to West Central Reverse Limit***

- The West Central reverse limit was reduced from 2,275 MW to 2,200 MW. This update is driven by changes in load patterns in Load Zone A and Load Zone B.

#### ***Update to Dynamic Limits from Staten Island to Load Zone J (New York City):***

- Dynamic limit updates from Con Edison's 2023 Local Transmission Plan (LTP) increased export capability from Staten Island to Load Zone J by 200-250 MW depending on the operating status of certain generation facilities.
- The base export limit from Staten Island to Load Zone J remains 815 MW.

Forced transmission outages based on historical performance are represented in the GE-MARS model for the underground cables that connect New York City and Long Island to surrounding zones. The GE-MARS model uses transition rates between operating states for each interface, which were calculated based on the probability of occurrence from the historic failure rates and the time to repair. Transition rates into the different operating states for each interface were calculated based on the circuits comprising each interface, including failure rates and repair times for the individual cables, and for any transformer and/or phase angle regulator associated with that cable.

The applicable Transmission Owners provided updated transition rates for their associated cable interfaces. Updated cable outage rates assumed in the 2025-2026 IRM Study resulted in a non-material impact to the IRM compared with the 2024-2025 IRM Study (Table 6-1). In the 2024-2025 IRM Study, cable outage rates were based on the annualized average of the past 5 years of historical data. However, the 2025-2026 IRM Study adopts a new methodology, using the annualized average over the past 10 years. This change smooths the impact of tail events or years with unusually long cable outages, ensuring more stable and reliable estimates. Additionally, the 10-year average better captures long-term trends in cable performance, providing a more comprehensive understanding of outage patterns.

As in all previous IRM studies, forced outage rates for overhead transmission lines were not represented in the 2025-2026 IRM Study. Historical overhead transmission availability was evaluated in a study conducted by ICS in 2015, *Evaluation of the Representation of Overhead*

~~Transmission Outages in IRM Studies, which concluded that representing overhead transmission outages in IRM studies would have no material impact on the IRM ([www.nysrc.org/reports](http://www.nysrc.org/reports)).~~

~~The impact of NYCA transmission constraints on NYCA IRM requirements depends on the level of resource capacity in any of the downstream zones from a constraining interface, especially in New York City (Load Zone J) and Long Island (Load Zone K). To illustrate the impact of transmission constraints on the IRM, if internal NYCA transmission constraints were eliminated, the required 2025-2026 IRM could decrease by 1.85% (Table 7-1, Case 2).~~

~~The 2025-2026 IRM Study modeled limits on emergency assistance from neighboring jurisdictions during severe and extreme conditions by implementing additional topology limitations between each of the external areas and NYCA. Such topology limitations do not reflect the real constraints on the transmission system, but rather, represent an estimate of the neighboring area's ability to provide support to the NYCA at EOP steps during the GE-MARS simulation. More details on this modeling are discussed in section 5.4.~~

## **5.4 The Outside World Model**

~~The Outside World Model consists of four interconnected Outside World Areas contiguous with NYCA: Ontario, Quebec, New England, and the PJM Interconnection (PJM). NYCA reliability is improved and IRM requirements can be reduced by recognizing available emergency assistance (EA) from these neighboring interconnected control areas, in accordance with control area agreements governing emergency operating conditions.~~

~~For the 2025-2026 IRM Study, two Outside World Areas, New England and PJM, are each represented as multi-area models—i.e., 14 zones for New England and five zones for PJM. Another consideration for developing models for the four Outside World Areas is to recognize internal transmission constraints within those areas that may limit EA into the NYCA. This recognition is explicitly considered through direct multi-area modeling of well-defined Outside World Area “bubbles” and their internal interface constraints. The model's representation explicitly requires adequate data in order to accurately model transmission interfaces, load areas, resource and demand balances, load shapes, and coincidence of peaks, among the load zones within these Outside World Areas.~~

~~In 2019, the ICS conducted an analysis of the IRM study's Outside World Area Model to review its compliance with a NYSRC Policy 5 objective that “interconnected Outside World Areas shall be modeled to avoid NYCA's over dependence on Outside World Areas for emergency assistance.” This analysis resulted in a change in the methodology to scale loads proportional to excess capacities in each zone of each Outside World Area to meet the LOLE criterion and the Control Area's minimum IRM requirement, as well as the implementation of global EA limit~~

of 3,500 MW. For the past IRM studies, EA assumptions have reduced IRM requirements by approximately 5.5% (Table 7-1, Case 1).

For the 2024-2025 IRM Study, an EOP whitepaper<sup>11</sup> was conducted and the whitepaper concluded that further refinement of the previous EA assumptions would improve the reasonableness of expectations for availability of EA. Additional topology limits to constraint EA by LFU bin in the IRM study were recommended. In the 2024-2025 IRM Study, the static EA limit was modified as follows: LFU Bin 1: 1,470 MW; LFU Bin 2: 2,600 MW; LFU Bin 3-7: 3,500 MW. These limits were also implemented on each of the external Control Areas, based on historical extra reserves available in these Control Areas during NYCA peak load periods to better reflect potential support that external Control Areas can provide when New York is in need. For the 2025-2026 IRM Study, the dynamic emergency assistance modeling was expanded to include the HVDC lines to reflect the proportional limits to emergency assistance from the external control areas.

### 5.5 Database Quality Assurance Review

It is critical that the database used for IRM studies undergo sufficient review in order to verify its accuracy. The NYISO, GE, and two Transmission Owners conducted independent data quality assurance reviews after the preliminary base case assumptions were developed and prior to preparation of the final base case. Masked and encrypted input data was provided by the NYISO to the two Transmission Owners for their review. Also, certain confidential data is reviewed by two of the NYSRC consultants as required.

The NYISO, GE, and Transmission Owner reviews found minor errors within the assumptions matrix for the 2025-2026 IRM Study preliminary base case, which were subsequently corrected. A summary of these quality assurance reviews for the 2025-2026 IRM Study input data is shown in Appendix A, Section A.4. There were no material errors found in the final base case data.

## 6. Parametric Comparison with 2024-2025 IRM Study Results

The results of this 2025-2026-2026-2027 IRM Study of 24.425.3% show that the final base case IRM result represents a 1.30.9% increase from the 2024-2025-2025-2026 IRM Study base case value of 23.124.4%. Note, the final approved IRM value for the 2024-2025-2025-2026 Capability Year was 22.024.4%. Table 6-1 compares the estimated IRM impacts of updating several key study assumptions and revising models from those used in last year's study. The estimated percentage IRM change for each parameter was calculated from the results of a parametric analysis in which a series of IRM

<sup>11</sup> See, New York State Reliability Council, EOP Whitepaper, available at: <https://www.nysrc.org/wp-content/uploads/2023/10/EOP-Review-Whitepaper-Report-FINAL-For-Posting.pdf>



sensitivity runs were conducted to update the underlying IRM model data and test the IRM impact of individual parameters. In practice, the parametric analysis is conducted in a sequential manner and the parametric results can be largely affected by the study sequence and the selected parametric adjustment method. The total parametric change on the IRM is ~~over 2.9%~~ roughly 1.5%, while the final Tan-45 analysis shows that there is only a ~~1-30.9%~~ increase from last year's final base case. Table 6-1 also provides a summary for the IRM changes for some of the study parameters from the ~~2024-2025-~~ 2025-2026 IRM Study.

There are sixteen parameter drivers that in combination increased the 2026-2027 IRM from the 2025-2026 IRM Study base case IRM by 6.29%. Of these sixteen drivers, the most significant was the Winter Fuel Availability Constraints followed closely by the Fall Load Forecast reduction and the explicit modeling of the Behind the Meter (BTM) Solar modeling. Each of these three items increased the IRM by over 1% each. The addition of the Champlain Hudson Power Express (CHPE) with its 1250 MW transfer capability into Zone J for the summer months only, resulted in just a 0.317% increase in the IRM but caused significant shifts in the Locational Requirements. Zone J increased by 8.474%, Zone K decreased by 3.397% and Zones G-J increased by 5.272%. Because of the seasonal capability of this line it also exacerbated the impact of the winter fuel constraints.

Twelve parameter drivers in combination decreased the IRM from the 2024-2025 IRM Study base case by 4.66%. Of these twelve drivers, the most significant was the change in the SCR elections which decreased the IRM by 1.569%. The Gowanus and Narrows generator deactivations decreased the IRM by 0.686% followed closely by the initial 2025 Gold Book Load Forecast which decreased the IRM by 0.619%. All other modifications, individually, had less than a 0.50% impact each on the IRM. There are fourteen parameter drivers that in combination ~~increased~~ the 2025-2026 IRM from the 2024-2025 base case IRM by 1.98%. Of these fourteen drivers, the most significant was the limit on certain EOP calls which increased the IRM by 0.46%. The next three most significant are the addition of the new renewable generators which increased the IRM by 0.29%, the change in SCR capacity which increased the IRM by 0.24%, and the change in generator ratings which increased the IRM by 0.19%. The remaining changes had relatively minor changes in the IRM.

Seven parameter drivers in combination decreased the IRM from the 2024 base case by 0.68%. Of these seven drivers, the most significant was the change in the SCR modeling which decreased the IRM by 0.26%. All other modifications had less than a 0.15% individual impact on the IRM.

The parameters in Table 6-1 are discussed under *Models and Key Input Assumptions*.

**Formatted:** Font: (Default) Calibri, Font color: Black, Text Outline

**Formatted:** Normal, No bullets or numbering

**Formatted:** Font: (Default) Calibri, Font color: Black, Text Outline

**Formatted:** Normal, No bullets or numbering

**Table 6-1: 2025-2026 vs 2026-2027 Parametric Impact Comparison**

<u>Parameter</u>	<u>Impact on Margins</u>		<u>-</u>		<u>Reason for Change</u>
	<u>IRM</u>	<u>NYC</u>	<u>LI</u>	<u>G-J</u>	
<u>2025-2026 IRM Final Base Case (FBC)</u>	<u>24.400%</u>	<u>75.581%</u>	<u>107.295%</u>	<u>86.912%</u>	-
<b>Study Parameters that Increased the IRM</b>					
<u>Winter Fuel Availability Constraints</u>	<u>1.368%</u>	<u>1.053%</u>	<u>1.318%</u>	<u>1.090%</u>	<u>Adoption of Winter Fuel Availability Constraints modeling</u>
<u>Fall Load Forecast</u>	<u>1.291%</u>	<u>-0.857%</u>	<u>-1.039%</u>	<u>-0.625%</u>	-
<u>Behind the Meter (BTM) Solar</u>	<u>1.112%</u>	<u>0.783%</u>	<u>1.081%</u>	<u>0.846%</u>	<u>Modeling BTM Solar explicitly as a supply resource</u>
<u>New Generator Screening</u>	<u>0.704%</u>	<u>0.101%</u>	<u>-0.047%</u>	<u>0.081%</u>	-
<u>EFORD Thermal Outage Rate (2020-2024)</u>	<u>0.371%</u>	<u>0.266%</u>	<u>0.332%</u>	<u>0.297%</u>	-
<u>Champlain Hudson Power Express (CHPE) Inclusion</u>	<u>0.317%</u>	<u>8.474%</u>	<u>-3.397%</u>	<u>5.272%</u>	-
<u>2025 BTM Solar Generator Shapes</u>	<u>0.236%</u>	<u>0.170%</u>	<u>0.233%</u>	<u>0.181%</u>	-
<u>Generator Deactivations and ICAP Ineligible Forced Outages (IIFOs)</u>	<u>0.194%</u>	<u>0.900%</u>	<u>-1.556%</u>	<u>1.005%</u>	-
<u>Topology Update: Limit Update for Sprain Brook Dunwoodie South</u>	<u>0.174%</u>	<u>0.240%</u>	<u>0.330%</u>	<u>0.256%</u>	-
<u>HQ Imports Modeling Update</u>	<u>0.112%</u>	<u>0.000%</u>	<u>0.000%</u>	<u>0.000%</u>	-
<u>Inclusion of Distributed Energy Resources (DERs)</u>	<u>0.103%</u>	<u>0.000%</u>	<u>0.000%</u>	<u>0.001%</u>	<u>Modeling DER enrollments</u>
<u>Cable Transition Rates</u>	<u>0.084%</u>	<u>0.060%</u>	<u>0.083%</u>	<u>0.064%</u>	-
<u>Load Zone K Topology Update</u>	<u>0.075%</u>	<u>0.108%</u>	<u>0.134%</u>	<u>0.112%</u>	-
<u>Load Forecast Uncertainty</u>	<u>0.050%</u>	<u>0.038%</u>	<u>0.048%</u>	<u>0.040%</u>	-
<u>MARS Version</u>	<u>0.050%</u>	<u>0.036%</u>	<u>0.049%</u>	<u>0.038%</u>	-
<u>Manual &amp; Remote Voltage Reduction MW Update</u>	<u>0.050%</u>	<u>0.037%</u>	<u>0.046%</u>	<u>0.039%</u>	-
<b>Study Parameters that Decreased the IRM</b>					
<u>Special Case Resources (SCR)</u>	<u>-1.569%</u>	<u>-0.033%</u>	<u>0.103%</u>	<u>-0.070%</u>	<u>Updated SCR enrollments</u>
<u>Gowanus 1 &amp; 2 and Narrows 2 &amp; 3 Deactivations</u>	<u>-0.686%</u>	<u>-3.339%</u>	<u>1.535%</u>	<u>-2.028%</u>	-
<u>2025 Gold Book Load Forecast</u>	<u>-0.619%</u>	<u>0.945%</u>	<u>0.983%</u>	<u>0.517%</u>	-
<u>2026 Solar Adjusted Load Shapes</u>	<u>-0.473%</u>	<u>-0.339%</u>	<u>-0.466%</u>	<u>-0.362%</u>	-

<u>Voluntary Curtailment Call Limit Update</u>	<u>-0.298%</u>	<u>-0.224%</u>	<u>-0.279%</u>	<u>-0.234%</u>	<u>3 days/month call limit implemented</u>
<u>Unforced Capacity Deliverability Rights (UDR) Elections</u>	<u>-0.260%</u>	<u>-1.146%</u>	<u>0.549%</u>	<u>-0.694%</u>	-
<u>Revised SCR Start Times</u>	<u>-0.249%</u>	<u>0.000%</u>	<u>0.000%</u>	<u>0.000%</u>	<u>Adoption of new SCR start time methodology</u>
<u>External Data + Policy 5 Adjustment</u>	<u>-0.168%</u>	<u>-0.129%</u>	<u>-0.162%</u>	<u>-0.134%</u>	-
<u>Enhanced Load Modeling (ELM)</u>	<u>-0.152%</u>	<u>-0.107%</u>	<u>-0.147%</u>	<u>-0.115%</u>	<u>Calibrate annual energy and seasonal peak forecasts</u>
<u>NERC EFORD: 2020-2024</u>	<u>-0.075%</u>	<u>-0.056%</u>	<u>-0.070%</u>	<u>-0.059%</u>	-
<u>2025 Gold Book DMNC</u>	<u>-0.061%</u>	<u>0.233%</u>	<u>0.016%</u>	<u>-0.013%</u>	-
<u>Solar Shapes (2020 - 2024)</u>	<u>-0.052%</u>	<u>-0.035%</u>	<u>-0.056%</u>	<u>-0.038%</u>	-
<b>Total Impact/Results</b>					
<u>Sum of Non-Material Changes (FBC&amp;PBC)</u>	<u>-0.134%</u>	<u>-0.080%</u>	<u>-0.148%</u>	<u>-0.086%</u>	-
<u>Total Parametric Impact</u>	<u>1.495%</u>	<u>7.099%</u>	<u>-0.526%</u>	<u>5.381%</u>	-
<u>2026-2027 IRM Parametric Results</u>	<u>25.761%</u>	<u>82.600%</u>	<u>106.621%</u>	<u>92.208%</u>	-
<u>2026-2027 IRM FBC Tan45 Results</u>	<u>25.300%</u>	<u>79.200%</u>	<u>106.700%</u>	<u>88.800%</u>	<u>Results of FBC Tan45</u>
<u>Tan45 Delta</u>	<u>-0.461%</u>	<u>-3.400%</u>	<u>0.079%</u>	<u>-3.408%</u>	<u>Delta between the Parametric Results and the Tan45 Results</u>

**Table 6-1: 2024 vs 2025 Parametric Impact Comparison**

Parameter	Impact on Margins				Reason for Change
	IRM	NYC	LI	G-I	
2024-2025 IRM Final Base Case (FBC)	23.100%	72.730%	103.207%	84.577%	-
<b>Study Parameters that Increased the IRM</b>					
NYSRC Recommendation: EOP Calls Limit	0.46%	2.60%	1.45%	2.02%	3-Call/Year Limit to Voluntary Curtailment and Public Appeals
New Generators	0.29%	0.00%	0.00%	0.00%	-

SCR Capacity	0.24%	0.46%	-0.16%	0.26%	-
Generator Capacity	0.19%	-1.34%	0.99%	-0.15%	-
NYSRC Recommendation: PJM Dynamic Limits	0.15%	0.87%	0.48%	0.67%	Apply Dynamic Limits Across All PJM Interfaces
UDR Elections	0.14%	-0.76%	4.03%	-0.59%	-
BTM:NG	0.14%	0.66%	-0.31%	0.51%	-
EOP Updates	0.13%	0.38%	0.22%	0.29%	Update to Amounts for Voluntary Curtailment, Public Appeals, and Voltage Reduction
Load Updates	0.12%	1.26%	-0.40%	0.21%	-
Cable Outage Rate Update	0.06%	0.36%	0.21%	0.28%	-
Summer Maintenance	0.03%	0.16%	0.09%	0.12%	-
Increased Replications	0.01%	0.03%	0.02%	0.03%	Increase to 4,250 Replications to Maintain Standard Error Criteria
PJM Western Ties Update	0.01%	0.02%	0.01%	0.02%	-
Generator Deactivations	0.00%	0.66%	-1.06%	0.62%	-
Study Parameters that Decreased the IRM					
Enhanced SCR Modeling	-0.26%	-0.76%	-0.43%	-0.59%	Adoption of Enhanced SCR Modeling

Topology Updates	-0.13%	-0.73%	-0.43%	-0.56%	Update to Dynamic Limits from Staten Island to Load Zone-J
External Area Modeling	-0.11%	-0.33%	-0.19%	-0.26%	-
NYSRC Recommendation: 10 Year Cable Outage Rates	-0.06%	-0.35%	-0.20%	-0.27%	Update from 5 Year to 10 Year Cable Outage Rates
Intermittent Resource Shapes Update	-0.06%	-0.21%	-0.12%	-0.16%	-
Generator Outage Rate Update	-0.03%	-0.06%	-0.08%	-0.05%	-
External Sales/Purchases	-0.02%	-0.07%	-0.04%	-0.05%	-
Total Impact/Results					
Total Parametric Impact	1.30%	2.85%	4.09%	2.33%	-
2025-2026 Parametric Results	24.40%	75.58%	107.30%	86.91%	-
2025-2026 FBC Tan45 Results	24.40%	75.58%	107.30%	86.91%	Results of FBC Tan45
Tan45-Delta	0.00%	0.00%	0.00%	0.00%	Delta between the Parametric Results and the Tan45 Results

## 7. Sensitivity Case Study

In addition to calculating the IRM using base case assumptions, sensitivity analyses are run as part of an IRM study to determine IRM outcomes using different assumptions than in the base case. Sensitivity studies provide a mechanism for illustrating “cause and effect” of how some performance and/or

operating parameters and study assumptions can impact reliability. Certain sensitivity studies, termed “IRM impacts of base case assumption changes,” serve to inform the NYSRC Executive Committee when determining the Final NYCA IRM regarding how the IRM may be affected by reasonable deviations from selected base cases assumptions. The methodology used to conduct sensitivity cases starts with the base case IRM results and adds or removes capacity from all NYCA zones until the NYCA LOLE approaches 0.1 Event-Days/year.

Table 7-1 shows the IRM requirements for the various sensitivity cases. Notably, all of the sensitivities are run on the approved ~~2025~~2026-2026-2027 IRM PBC. It is expected that the relative impact on the PBC remain unchanged on the ~~2055~~2026-2026-2027 IRM Final Base Case (FBC), Table 7-1 is adjusted to show the same relative impact from the approved sensitivity case result on the FBC (Table 7-1, Case 0)<sup>12</sup>. In addition to showing the IRM requirements for various sensitivity cases, Table 7-1 shows the LOLH and EUE reliability metrics for each case<sup>13</sup>. These two metrics, along with the LOLE metric, are important measures of reliability risk in that together, they describe the frequency, duration, and magnitude of loss of load events<sup>16</sup>. The reliability risk measures provided by these two metrics, in addition to IRM impacts, provide Executive Committee members with different aspects of system risk for selecting the Final NYCA IRM. The data used to calculate LOLH and EUE are collected from GE-MARS output.

Sensitivity Cases 1 through 5 in Table 7-1 are annually performed and illustrate how the IRM would be impacted if certain major IRM study parameters were not represented in the IRM base case. These parameters and their IRM impacts are discussed in Sections 5.1.2 and 5.4, respectively.

~~Case 6a examines the impact of reduced oil availability in the winter, reducing the oil capacity to 11,000 MW—the amount of firm fuel resources the NYISO said they expect to have in Zones F–K that the NYISO has stated they expect from past fuel surveys. Case 6b further reduced the winter oil availability to only 8,000 MW. Case 7 shows the impact of modeling BTM solar resources explicitly as supply resources. This modeling will allow better understanding of the impact of solar generation on the system.~~

~~In June 2023, the NYSRC issued a study, “Offshore Wind Data Review—NYSRC Preliminary Findings,” raising concerns about the correlated availability and performance of offshore wind within the NYCA system and across the Northeast, particularly between New York and New England. In November 2024, NYISO conducted an updated analysis of offshore wind facilities in neighboring systems, which included the Vineyard Offshore Wind facility in New England. However, results concluded that offshore wind levels in both NYCA and New England are still too low to materially impact the IRM, limiting the~~

<sup>12</sup> See, New York State Reliability Council 2025-2026 Installed Reserve Margin Study - Sensitivity Cases and Case Comparison, available at: [https://www.nysrc.org/wp-content/uploads/2024/08/IRM25\\_Sensitivities\\_Results-09042024-ICS.pdf](https://www.nysrc.org/wp-content/uploads/2024/08/IRM25_Sensitivities_Results-09042024-ICS.pdf)

<sup>13</sup> **LOLH:** The expected number of hours during loss of load events each year when the system’s hourly demand is projected to exceed the generating capacity.

**EUE:** The expected amount of energy (MWh) during loss of load events that cannot be served each year.

~~ability to assess correlated impacts. Inconsistencies persist in this year's modeling approach for offshore wind and other intermittent resources in neighboring regions compared to NYCA's IRM methodology. Consequently, actions are being taken to urge the NPCC to establish consistent modeling assumptions that recognize the intermittent nature of the resource across all interconnected systems, and the NYISO will collaborate with the NYSRC Extreme Weather Working Group to continue monitoring system impacts as offshore wind capacity grows.~~

Case 6 looks at the impact of removing the Winter Fuel Availability constraint. If there were no limits on the fuel in winter then the IRM would drop by 1.8% to only 23.5%. The base case assumed that CHPE was in and the barges were removed, resulting in an IRM of 25.3%. Case 7a assumes the reverse – The CHPE line is out and the barges are kept in. This results in a drop in IRM of 0.8% resulting in a 24.5% value. Case 7b assumes that CHPE is in and that the barges are retained. This increases the IRM by 0.5% to a final value of 25.8%

**Table 7-1. 2025-2026 Installed Reserve Margin (IRM) Study – Sensitivity Cases**

Case	Description	IRM (%)	NYC (%)	LI (%)	IRM (%) Change from Base	LOLH (hrs/yr)	EUE (MWh/yr)
0	2025-2026 IRM Final Base Case (FBC)	24.40	75.58	107.30	-	0.374	216.980
	These are the Base Case technical results derived from knee of the IRM-LCR curve						
1	NYCA Isolated	29.87	79.42	112.41	5.47	0.341	198.973
	Track Total New York Control Area (NYCA) Emergency Assistance (EA)—NYCA system is isolated and receives no emergency assistance from neighboring control areas (New England, Ontario, Quebec, and PJM). Unforced Capacity Deliverability Rights (UDRs) are allowed						
2	No Internal NYCA transmission constraints	22.55	74.28	105.56	-1.85	0.364	326.999
	Track level of NYCA congestion with respect to the IRM model—eliminates internal transmission constraints and measures the impact of transmission constraints on statewide IRM requirements						
3	No Load Forecast Uncertainty	19.35	72.03	102.57	-5.05	0.268	51.274
	Shows sensitivity of IRM to load uncertainty, if the forecast peak loads for NYCA have a 100% probability of occurring						
4	No Wind Capacity	17.77	76.60	105.96	-6.63	0.366	228.969
	Shows wind impact for both land-based and off-shore wind units and can be used to understand Equivalent Demand Forced Outage Rate (EDFORd) sensitivity						
5	No SCR Capacity	22.05	72.82	108.17	-2.35	0.359	211.508
	Shows sensitivity of IRM to the Special Case Resource (SCR) program						



Case	Description	IRM (%)	NYC (%)	LI (%)	IRM (%) Change from Base	LOLH (hrs/yr)	EUE (MWh/yr)
6a	Gas Constraints (Tan45) 11,000 MW of oil modeled	25.30	76.20	107.52	0.90	0.349	186.396
	Shows impact to reliability when winter capacity is reduced due to gas constraints and can be used to understand tightening winter conditions						
6b	Gas Constraints (Tan45) 8,000 MW of oil modeled	31.60	78.10	108.27	7.20	0.310	129.996
	Shows impact to reliability when winter capacity is reduced due to gas constraints and can be used to understand tightening winter conditions						
7	BTM Solar (Tan45)	25.45	76.48	108.92	1.05	0.396	242.431
	Shows the impact of modeling Behind the Meter (BTM) solar resources explicitly. The modeling can be used to understand the impact of evolving BTM solar penetration in the system.						

Notes: 1. All results are calculated by adding/removing capacity from Load Zones A – K unless otherwise noted.

2. All of the sensitivities are run on the approved 2025–2026 IRM PBC. It is expected that the relative impact on the PBC remain unchanged on the 2025–2026 IRM FBC, Table 7-1 is adjusted to show the same relative impact from the approved sensitivity case result on the FBC (Table 7-1, Case 0), the IRM and LCRs in Table 7-1 are adjusted using the deltas from the approved sensitivities.

Table 7.1. 2026-2027 Installed Reserve Margin (IRM) Study - Sensitivity Cases

Case	Description	IRM (%)	NYC (%)	LI (%)	IRM (%) Change from Base	LOLH (hrs/yr)	EUE (MWh/yr)
0	2026-2027 IRM Final Base Case (FBC)	25.30	79.20	106.73	-	0.36	169.51
	These are the Base Case technical results derived from knee of the IRM-LCR curve						
1	NYCA Isolated	30.08	82.88	111.33	4.78	0.31	176.64
	Track Total New York Control Area (NYCA) Emergency Assistance (EA) – NYCA system is isolated and receives no emergency assistance from neighboring control areas (New England, Ontario, Quebec, and PJM). Unforced Capacity Deliverability Rights (UDRs) are allowed						
2	No Internal NYCA transmission constraints	23.09	77.50	104.60	-2.21	0.33	256.59
	Track level of NYCA congestion with respect to the IRM model – eliminates internal transmission constraints and measures the impact of transmission constraints on statewide IRM requirements						
3	No Load Forecast Uncertainty	19.71	74.90	101.35	-5.59	0.30	74.15
	Shows sensitivity of IRM to load uncertainty, if the forecast peak loads for NYCA have a 100% probability of occurring						
4	No Wind Capacity	18.53	80.38	105.78	-6.77	0.36	178.73
	Shows wind impact for both land-based and off-shore wind units and can be used to understand Equivalent Demand Forced Outage Rate (EFORd) sensitivity						

Formatted Table

Formatted Table

Formatted Table

Formatted Table

Formatted Table

<u>5</u>	<u>No SCR Capacity</u>	<u>22.10</u>	<u>75.96</u>	<u>107.50</u>	<u>-3.20</u>	<u>0.36</u>	<u>179.97</u>
	<u>Shows sensitivity of IRM to the Special Case Resource (SCR) program</u>						

Formatted Table

Formatted Table

<u>Case</u>	<u>Description</u>	<u>IRM (%)</u>	<u>NYC (%)</u>	<u>LI (%)</u>	<u>IRM (%) Change from Base</u>	<u>LOLH (hrs/yr)</u>	<u>EUE (MWh/yr)</u>
<u>6</u>	<u>No Winter Fuel Availability Constraints (Tan45)</u>	<u>23.50</u>	<u>78.14</u>	<u>107.26</u>	<u>-1.80</u>	<u>0.38</u>	<u>217.82</u>
	<u>Shows the level of winter reliability risk due to the winter fuel availability constraints</u>						
<u>7a</u>	<u>Barges + No CHPE (Tan45)</u>	<u>24.50</u>	<u>76.01</u>	<u>108.73</u>	<u>-0.80</u>	<u>0.39</u>	<u>197.86</u>
	<u>Show impact of modeling alternative assumptions for the status of CHPE and the Gowanus/Narrows barges</u> • <u>With the FBC assuming that CHPE is included and barges are out-of-service, the sensitivity will exclude CHPE and include the barges</u>						
<u>7b</u>	<u>Barges + CHPE both included (Tan45)</u>	<u>25.80</u>	<u>80.44</u>	<u>106.28</u>	<u>0.50</u>	<u>0.36</u>	<u>163.78</u>
	<u>Show impact of modeling alternative assumptions for the status of CHPE and the Gowanus/Narrows barges</u> • <u>With the FBC assuming that CHPE is included and barges are out-of-service, this sensitivity will include both CHPE and the barges in-service to understand their combined impact</u>						

Formatted Table

Formatted Table

Formatted Table

Note: All results are calculated by adding/removing capacity from Load Zones A - K unless otherwise noted

## 8. NYISO Implementation of the NYCA Capacity Requirement

The NYISO values capacity sold and purchased in the market in a manner that considers the forced outage ratings of individual units, whereby generating unit capacity is derated to an unforced capacity basis recognizing the impact of historic unit forced outages. This derated capacity is referred to as “UCAP.” In the NYCA, these translations occur twice during the course of each Capability Year, prior to the start of the Summer and Winter Capability Periods.


Additionally, the IRM and LCRs are translated into equivalent UCAP values during these periods. The conversion to UCAP essentially translates from one index to another; it is not a reduction of actual installed resources. Therefore, no degradation in reliability is expected. The NYISO employs a translation methodology that converts ICAP requirements to UCAP in a manner that ensures compliance with NYSRC Resource Adequacy Rule A.1: R1. The conversion to UCAP provides financial incentives to decrease the forced outage rates while improving reliability.

Due to lower contribution to reliability, the increase in wind and solar resources lowers the translation factor from required ICAP to required UCAP which reflects the performance of all resources on the system. Figure 8.1 shows that required UCAP margins decrease slightly through 2024 even though the required ICAP margins increase slightly. This is due to resources with below average performance being removed from the system and the required UCAP being a function of required ICAP and the weighted average availability of system resources. Last year both the ICAP and UCAP increased slightly. Overall, the required ICAP remained roughly constant to last year although the existing ICAP increased by about 3%.

Appendix D provides details of the ICAP to UCAP conversion.

Figure 8-1 NYCA Reserve Margins

**New York Control Area Reserve Margins**  
**ICAP versus UCAP Summer Margins**  
 Covering the years 2006-2025



**New York Control Area Reserve Margins**  
**ICAP versus UCAP Summer Margins**  
 Covering the years 2006-2024

