

List of Potential Reliability Rule Changes - Outstanding						
Categories: R = Rule; D = Definition; RO = Requirement; P = Procedure/Guideline; C = Compliance Elements; E = Exception						
Status: 1=In RRS for development/review 2=In RCMS for compliance elements 3=To EC for approval to post 4=Approved by EC for posting 5=RRS incorporating comments from posting 6=To EC for final approval 7=Approved by EC 8=Removed						
PRR No.	Existing Rule	Potential Rule Change	Sponsor	Category	Status	RRS Action
PRR 153	New Contingency requirement for B.1 - Transmission System Planning Performance Requirements, R1 - Transmission facilities in the NYS Bulk Power System shall be planned to meet the respective performance requirements in Table B-1 and supplemental performance requirements in Table B-2 for the contingency events as specified in Table B-1.	Include "Sudden loss of fuel delivery system to multiple solar & wind plants" as Category I & II Design Contingencies in Table B-1	NYISO/RRS/ EW WG	R	1	In development
PRR 156	Resource Adequacy A2: Establish Load Serving Entity Installed Capacity Requirements	Modifications to Enhance Resource Adequacy	NYISO/RRS	R	1	In development